

February 2025

CLEAN

SAFE

HEALTHY

SCHOOLS

Amity Regional School
District No. 5

25 Newton Road

Woodbridge, CT 06525

Phone: 203-397-4817

Fax: 203-397-4864



Amity Regional School District No. 5

Facilities Department Monthly Report

Completed Projects:

- The second VFD for air handler one at the high school was replaced by an outside contractor.
- A new circuit was run in the ARHS kitchen to power the new rapid cook oven by our in-house electrician.
- A few door repairs were done at AMSO by our in house building maintainer.
- The walk in cooler door at ARHS was repaired by an outside vendor.
- A motor for an air handler at ARHS was repaired by our in house building mechanics.
- Water filters are being replaced on the bottle filling stations District wide.

Projects in Process:

- Facilities is working with an outside contractor to repair a few areas in the main driveway at ARHS.
- The District is working with the Town of Woodbridge to address concerns with the fuel cell and microgrid. A was a meeting held on January 10, 2025 with UI, Fuel cell, the Town of Woodbridge and Amity. There is another meeting scheduled for February 10, 2025. At this point, the Town is in contact with the state regarding the issue.
- The fire pump in Bethany needs to be replaced. The District is working with Van Zelm engineers to draft specifications so the project can go out to bid.
- Facilities is working with Van Zelm and Silver Petrucelli to design the scope of work for the HVAC improvements as part of the Media Center upgrade.
- The District met with Titan Energy to discuss solar options at ARHS. Another presentation from Titan Energy with the Board of Ed is scheduled for February 10, 2025.

Outstanding issues to be addressed:

- Bid openings for the fire suppression room at the high school will be opened on February 10th. Bids will be reviewed, and a plan to move forward will be presented at a later date.