

VISTA UNIFIED SCHOOL DISTRICT



2025 Summer Playground Surfaces

BID NO. V2425022B

Addendum#01

Bid Packages Due on or Before:

Monday, April 21, 2025 – 2:00 p.m.

RFI #1: Please clarify the color(s) to be used within the new poured-in-place surfacing to be installed?

For example 50% Standard Color / 50% Black or 100% Color Mix of colors TBD

(A): The new poured-in-place surfacing must match the existing playground color(s) as closely as possible, which is currently a 50% standard color and 50% black mix. If the original colors are no longer available, the contractor shall use a color mix that most closely resembles the existing colors.

RFI #2: Please clarify the binder type to be used within the new poured-in-place surfacing to be installed?

For example Aromatic or Aliphatic?

(A): Aromatic Binder.

RFI #3: Please clarify the color(s) to be used within the patches / repairs of existing poured-in-place surfacing?

For example 50% Standard Color / 50% Black or 100% Color Mix of colors TBD

(A): Patches to the poured-in-place surfacing must match the existing playground color(s) as closely as possible, using a 50% standard color and 50% black mix. If the original colors are no longer available, the contractor shall use a color mix that most closely resembles the existing colors.

RFI #4: Please clarify the binder type to be used within the patches / repairs of existing poured-in-place surfacing?

For example Aromatic or Aliphatic?

(A): Aromatic Binder.

RFI #5: SpectraTurf would like to submit our SpectraPour poured-in-place rubberized safety surfacing to be an approved equal product.

Attached is our submittal for reference.

(A): SpectraPour poured-in-place is approved to be an equal replacement.

RFI #6: SpectraTurf would like to submit our SpectraPour Roll-Coat H3608 Aliphatic to be an approved equal product for the maintenance roll-coat scope of work.

Attached is our product data sheet for reference.

(A): SpectraPour Roll-Coat H3608 Aliphatic is approved.

RFI #7: Please confirm the district will require an IPEMA certificate for an 8'-0" critical fall height on playgrounds that are specified to be removed and replaced?

(A): Yes, I can confirm the district will require an IPEMA certificate for an 8'-0" critical fall height on all playgrounds specified to be removed and replaced.

RFI #8: Please confirm the warranty of FIVE (5) years is acceptable for new poured-in-place installation, per industry standard.

(A): Yes, a five (5) year warranty for the new poured-in-place installation is acceptable.

(RFI): Please see the attached image of the playground structure at Hannalei Elementary School. This structure will need to be removed, and Vista USD will retain the equipment.

