

Calvert High School

2024-2025 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Area	Location	Description	Sample Type (Code)	Analysis Date	Lead Sample Result (ppm)	≥ 0.0055 ppm AL?
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	1	DFC	Hallway	Outside Cafeteria	Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	2a	BF	Hallway	Outside Cafeteria	Bottle Filler	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	2b	DFC	Hallway	Outside Cafeteria	Bottle Filler's fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	3	DFC	Hallway	Outside 217	Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	4	DFC	Hallway	Outside 213	Left Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	5	DFC	Hallway	Outside 213	Right Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	6a	BF	Hallway	Outside Nurse's Office	Bottle Filler	FD	3/30/25	<0.0010	No

Water Testing Laboratory of MD	Calvert High School	4/8/25	1	6b	DFC	Hallway	Outside Nurse's Office	Bottle Filler's fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	7	DFC	Hallway	Outside Nurse's Office	Middle Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	8	DFC	Hallway	Outside Nurse's Office	Right Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	9	DFC	Hallway	Outside 402	Left Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	10	DFC	Hallway	Outside 402	Middle Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	11	DFC	Hallway	Outside 402	Right Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	12	DFC	Hallway	Outside 109	Left Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	13a	BF	Hallway	Outside 109	Bottle Filler	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	13b	DFC	Hallway	Outside 109	Bottle Filler's fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory	Calvert High School	4/8/25	1	14	DFC	Hallway	Outside 111	Left Fountain	FD	3/30/25	<0.0010	No

Water Testing Laboratory of MD	Calvert High School	4/8/25	1	15	DFC	Hallway	Outside 111	Right Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	16	DFC	Hallway	Outside 113	Left Fountain	FD	3/30/25	0.0011	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	17	DFC	Hallway	Outside 113	Right Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	18	DFC	Hallway	Outside 115	Left Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	19	DFC	Hallway	Outside 115	Right Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	20	DFC	Locker Room	Boy's	Left Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	21	DFC	Locker Room	Boy's	Right Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	22	DFC	Locker Room	Girl's	Right Fountain	FD	3/30/25	<0.0010	No
Water Testing	Calvert High School	4/8/25	1	23	DFC	Locker Room	Girl's	Left Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	24	DFC	Hallway	Outside 108	Left Fountain	FD	3/30/25	<0.0010	No

Water Testing Laboratory of MD	Calvert High School	4/8/25	1	25	DFC	Hallway	Outside 108	Right Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	26	DFC	Hallway	Outside Stairs 1	Left Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	27a	DFC	Hallway	Outside Stairs 1	Bottle Filler	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	27b	BF	Hallway	Outside Stairs 1	Bottle Filler Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	2	28	DFC	Hallway	Outside 317	Left Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	2	29	DFC	Hallway	Outside 317	Middle Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	2	30a	BF	Hallway	Outside 317	Bottle Filler	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	2	30b	DFC	Hallway	Outside 317	Bottle Filler Fountain	FD	3/30/25	<0.0010	No
Water Testing	Calvert High School	4/8/25	2	31	DFC	Hallway	Outside 326	Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	2	32	DFC	Hallway	Outside Electrical 4	Left Fountain	FD	3/30/25	<0.0010	No

Water Testing Laboratory of MD	Calvert High School	4/8/25	2	33	DFC	Hallway	Outside Electrical 4	Right Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	34a	BF	Weight room	Ball Field	Bottle Filler	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	34b	DFC	Weight Room	Ball Field	Bottle Filler Fountain	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	35	DFC	Weight Room	Outside Bathroom	Fountain	FD	3/30/25	0.0151	Yes
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	36	DFC	Planetarium	Planetarium	Fountain	FD	3/30/25	0.0021	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	37	IM	Kitchen		Ice Machine	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	38	MC	Kitchen		2 Compartment Sink	FD	3/30/25	<0.0010	No
Water Testing	Calvert High School	4/8/25	1	39	MC	Kitchen		Left Faucet 3 Compartment	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	40	MC	Kitchen		Right Faucet 3 Compartment	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	41	SPR	Kitchen	Dish Room	Dish Sprayer	FD	3/30/25	<0.0010	No

Water Testing Laboratory of MD	Calvert High School	4/8/25	1	42	KC	Kitchen		Faucet on solo Kettle	FD	3/30/25	0.0036	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	43	KC	Kitchen		Faucet Left Kettle	FD	3/30/25	0.0029	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	44	KC	Kitchen		Faucet Right Kettle	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	45	IM	Home Economic	Room 222	Ice Machine	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	47	FC	Home Economic	Room 222	Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	48	FC	Home Economic	Room 222	far Left faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	49	FC	Home Economic	Room 222	Left Middle Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	50	FC	Home Economic	Room 222	Middle Left Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	51	FC	Home Economic	Room 222	Middle Right Faucet	FD	3/30/25	0.0012	No
Water Testing Laboratory	Calvert High School	4/8/25	1	52	FC	Home Economic	Room 222	Right Middle Faucet	FD	3/30/25	<0.0010	No

Water Testing	Calvert High School	4/8/25	1	53	FC	Home Economic	Room 222	Far Right Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	54	FC	Lounge	Room 214	Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	55	FC	Media Center Office		Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	56	FC	Mail Room	Room 26	Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	57	FC	Nurse Room	Room 43	Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	59	FC	Visual Arts	Room 402	Front Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	60	FC	Visual Arts	Room 402	Back Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	61	FC	Visual Arts	Room 404	Front Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	62	FC	Visual Arts	Room 404	Back Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	63	FC	Band/Orchestra	Room 109	Faucet	FD	3/30/25	<0.0010	No

Water Testing	Calvert High School	4/8/25	1	64	FC	Training Room		Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	66	IM	Training Room		Right Ice Machine	FD	3/30/25	0.0025	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	67	FC	Set Contruction	Room 104	Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	68	FC	Manufacturing Lab	Room 102	Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	69	FC	Tech Ed	Room 100	Faucet	FD	3/30/25	0.0013	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	2	70	FC	Teacher's Lounge	Room 301	Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	2	71	FC	English Storage	Room 330	Faucet	FD	3/30/25	0.0091	Yes
Water Testing Laboratory of MD	Calvert High School	6/4/25	2	71	FC	English Storage	Room 330	Faucet	FD	5/14/25	<0.0010	NO
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	73	IM	Weight Room		Right Ice Machine	FD	3/30/25	0.0108	Yes
Water Testing Laboratory of MD	Calvert High School	6/4/25	1	73	IM	Weight Room		Right Ice Machine	FD	5/14/25	<0.0010	No

Water Testing Laboratory of MD	Calvert High School	6/4/25	1	74	MC	Concession Stand	Stadium	Faucet 2 Compartment Sink	FD	5/14/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	2	75	IM	Teacher's Lounge	Room 301	Fridge Ice Machine	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	76	IM	Chemistry Storage	Room 203	Ice Machine	FD	3/30/25	0.0992	Yes
Water Testing Laboratory of MD	Calvert High School	6/4/25	1	76	IM	Chemistry Storage	Room 203	Ice Machine	FD	5/14/25	<0.0010	No
Water Testing	Calvert High School	4/8/25	1	77	FC	Chemistry Storage	Room 203	Faucet	FD	3/30/25	0.0019	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	78	FC	Concession Stand	Auditorium	Faucet	FD	3/30/25	0.0031	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	79	IM	Nurse Room	Room 43	Fridge Right Ice Machine	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	80	FC	Exam Room	Room 41	Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	81	FC	Weight room		Faucet	FD	3/30/25	<0.0010	No
Water Testing Laboratory of MD	Calvert High School	4/8/25	1	82	OT	Training Room		Water Cooler Filler	FD	3/30/25	0.0026	No