



FLEWELLING & MOODY
architects for education

Site Boring Work at Westpark Elementary School
SOUTHERN KERN UNIFIED SCHOOL DISTRICT
F&M Project No. 3045
Bid Clarification No. 2; Page 1 of 1

BID CLARIFICATION NO. 2
April 21, 2025

The following changes and/or clarifications shall be made to the drawings and specifications and all other conditions shall remain the same. All changes and/or clarifications provided shall be included in the scope of contracted work. Pursuant to PR13-01 all work that requires approval by the DSA shall not begin until said approvals are obtained.

A. DRAWINGS

1. Sheet E1.01, **Revise** 'Electrical Site Plan Notes' to read, "Provide 12-strand single mode fiber from (E) IDF to MDF. **Revise** note to read, (E) classroom Relo Bldg. 801.
2. Sheet E1.01, **Revise** "Electrical Site Plan Note adjacent to (E) classroom Relo Bldg. 806" to read, "Provide 12-strand single mode fiber from (N) IDF to MDF.
3. Sheet E1.01, **Add** "General Note to Contractors" to read, "All fiber cable shall be District Standard – TF12-OS2-PLO.

Flewellling & Moody, Inc.