

April 22, 2025

Subject: Eastern Trail WIN 019426.00 & 019426.10

Location: Scarborough and South Portland

Amendment No. 4

Dear Sir/Ms.:

The following questions have been received:

Question: What color coating is required for the PVC coated chain link fence? Is the 4' chain link fence to be galvanized or PVC coated?

Response: PVC coated fence shall be black. The 4' chain link fence shall be galvanized.

Question: What are the pipe weights for the chain link fence?

Response: Pipe weights aren't specified, however metal posts, rails, and bracing shall conform to section 710.06 of the MaineDOT Standard Specifications.

Question: Will intermediate posts need to be driven or set in concrete?

Response: Posts may be set in concrete or use metal drive anchors in accordance with MaineDOT Specification Section 607.

Question: Can a detailed spec be provided for the sliding gates?

Response: No additional specification will be provided. A sliding gate meeting the dimensions shown in the plans and meeting the material specification 710.06 will be acceptable.

Question: Can a detailed spec be provided for bracing assembly (607.34 & 607.35)?

Response: No additional specifications will be provided for bracing assembly. Items 607.34 & 607.35 shall conform to MaineDOT Standard Specification Section 607 and 710.06.