

Lead in School Drinking Water Report

Chase Lake Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-03-20

Date(s) analyzed: 2025-03-27, 2025-03-31

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	393285	Unit A - Main Building	Fountain/Tap Combo	Rm106	1 of 1	Tap	center	11
2	393770	Unit A - Main Building	Sink	Community Room	1 of 1	Tap	center	5
3	393287	Unit A - Main Building	Sink	Library Workroom	1 of 1	Tap	center	4
4	393771	Unit A - Main Building	Fountain/Tap Combo	Music	1 of 1	Tap	center	4
5	393768	Unit A - Main Building	Sink	Workroom	1 of 1	Tap	center	3
6	393795	Unit A - Main Building	Sink	Rm234	2 of 2 right side	Tap	center	3
7	393766	Unit A - Main Building	Fountain/Tap Combo	Health Room	1 of 1	Tap	center	2
8	393783	Unit A - Main Building	Fountain/Tap Combo	Rm221	1 of 1	Water Fountain	right	2
9	393307	Unit A - Main Building	Fountain/Tap Combo	Rm205	1 of 1	Tap	center	1
10	393794	Unit A - Main Building	Sink	Rm234	1 of 2 left side	Tap	center	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	393798	Unit A - Main Building	Fountain/Tap Combo	Rm201	1 of 1	Tap	center	1
12	393280	Unit A - Main Building	Fountain/Tap Combo	Rm103	1 of 1	Water Fountain	right	<1
13	393281	Unit A - Main Building	Fountain/Tap Combo	Rm104	1 of 1	Tap	center	<1
14	393282	Unit A - Main Building	Fountain/Tap Combo	Rm104	1 of 1	Water Fountain	right	<1
15	393283	Unit A - Main Building	Fountain/Tap Combo	Rm105	1 of 1	Tap	center	<1
16	393284	Unit A - Main Building	Fountain/Tap Combo	Rm105	1 of 1	Water Fountain	right	<1
17	393286	Unit A - Main Building	Fountain/Tap Combo	Rm106	1 of 1	Water Fountain	right	<1
18	393288	Unit A - Main Building	Fountain/Tap Combo	Rm121	1 of 1	Tap	center	<1
19	393289	Unit A - Main Building	Fountain/Tap Combo	Rm121	1 of 1	Water Fountain	right	<1
20	393290	Unit A - Main Building	Fountain/Tap Combo	Rm122	1 of 1	Tap	center	<1
21	393291	Unit A - Main Building	Fountain/Tap Combo	Rm122	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	393292	Unit A - Main Building	Fountain/Tap Combo	Between 122-123	1 of 1	Tap	center	<1
23	393293	Unit A - Main Building	Fountain/Tap Combo	Between 122-123	1 of 1	Water Fountain	right	<1
24	393294	Unit A - Main Building	Fountain/Tap Combo	Rm123	1 of 1	Tap	left	<1
25	393295	Unit A - Main Building	Fountain/Tap Combo	Rm123	1 of 1	Water Fountain	right	<1
26	393296	Unit A - Main Building	Fountain/Tap Combo	Rm124	1 of 1	Tap	center	<1
27	393297	Unit A - Main Building	Fountain/Tap Combo	Rm124	1 of 1	Water Fountain	right	<1
28	393298	Unit A - Main Building	Fountain/Tap Combo	Rm125	1 of 1	Tap	center	<1
29	393299	Unit A - Main Building	Fountain/Tap Combo	Rm125	1 of 1	Water Fountain	right	<1
30	393300	Unit A - Main Building	Fountain/Tap Combo	Rm202	1 of 1 Fountain off	Tap	center	<1
31	393301	Unit A - Main Building	Fountain/Tap Combo	Between 202-203	1 of 1	Tap	center	<1
32	393302	Unit A - Main Building	Fountain/Tap Combo	Between 202-203	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	393303	Unit A - Main Building	Fountain/Tap Combo	Rm203	1 of 1	Tap	center	<1
34	393304	Unit A - Main Building	Fountain/Tap Combo	Rm203	1 of 1	Water Fountain	right	<1
35	393305	Unit A - Main Building	Fountain/Tap Combo	Rm204	1 of 1	Tap	center	<1
36	393306	Unit A - Main Building	Fountain/Tap Combo	Rm204	1 of 1	Water Fountain	right	<1
37	393308	Unit A - Main Building	Fountain/Tap Combo	Rm205	1 of 1	Water Fountain	right	<1
38	393309	Unit A - Main Building	Fountain/Tap Combo	Rm206	1 of 1	Tap	center	<1
39	393310	Unit A - Main Building	Fountain/Tap Combo	Rm206	1 of 1	Water Fountain	right	<1
40	393760	Unit A - Main Building	Sink	Kitchen	1 of 1	Tap	center	<1
41	393761	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	Outside Gym	1 of 1	Water Fountain	left	<1
42	393762	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	Outside Gym	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
43	393763	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	Outside Gym	1 of 1	Water Bottle Filler	center	<1
44	393764	Unit A - Main Building	Fountain/Tap Combo	Rm224	1 of 1	Tap	center	<1
45	393765	Unit A - Main Building	Fountain/Tap Combo	Rm224	1 of 1	Water Fountain	right	<1
46	393767	Unit A - Main Building	Fountain/Tap Combo	Health Room	1 of 1	Water Fountain	right	<1
47	393769	Unit A - Main Building	Sink - Multi-Compartment	Staff Room	1 of 1	Tap	center	<1
48	393772	Unit A - Main Building	Fountain/Tap Combo	Music	1 of 1	Water Fountain	right	<1
49	393773	Unit A - Main Building	Fountain/Tap Combo	Rm101	1 of 1	Tap	center	<1
50	393774	Unit A - Main Building	Fountain/Tap Combo	Rm101	1 of 1	Water Fountain	right	<1
51	393775	Unit A - Main Building	Fountain/Tap Combo	Rm102	1 of 1	Tap	center	<1
52	393776	Unit A - Main Building	Fountain/Tap Combo	Rm102	1 of 1	Water Fountain	right	<1
53	393777	Unit A - Main Building	Fountain/Tap Combo	Between 102-103	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
54	393778	Unit A - Main Building	Fountain/Tap Combo	Between 102-103	1 of 1	Water Fountain	right	<1
55	393779	Unit A - Main Building	Fountain/Tap Combo	Rm103	1 of 1	Tap	center	<1
56	393780	Unit A - Main Building	Fountain/Tap Combo	Rm126	1 of 1	Tap	center	<1
57	393781	Unit A - Main Building	Fountain/Tap Combo	Rm126	1 of 1	Water Fountain	right	<1
58	393782	Unit A - Main Building	Fountain/Tap Combo	Rm221	1 of 1	Tap	center	<1
59	393784	Unit A - Main Building	Fountain/Tap Combo	Rm222	1 of 1	Tap	center	<1
60	393785	Unit A - Main Building	Fountain/Tap Combo	Rm222	1 of 1	Water Fountain	right	<1
61	393786	Unit A - Main Building	Fountain/Tap Combo	Between 222-223	1 of 1	Tap	center	<1
62	393787	Unit A - Main Building	Fountain/Tap Combo	Between 222-223	1 of 1	Water Fountain	right	<1
63	393788	Unit A - Main Building	Fountain/Tap Combo	Rm223	1 of 1	Tap	center	<1
64	393789	Unit A - Main Building	Fountain/Tap Combo	Rm223	1 of 1	Water Fountain	right	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
65	393790	Unit A - Main Building	Fountain/Tap Combo	Rm225	1 of 1	Tap	center	<1
66	393791	Unit A - Main Building	Fountain/Tap Combo	Rm225	1 of 1	Water Fountain	right	<1
67	393792	Unit A - Main Building	Fountain/Tap Combo	Rm226	1 of 1	Tap	center	<1
68	393793	Unit A - Main Building	Fountain/Tap Combo	Rm226	1 of 1	Water Fountain	right	<1
69	393796	Unit A - Main Building	Fountain - Multi-Level	By Stair A	1 of 1	Water Fountain	left	<1
70	393797	Unit A - Main Building	Fountain - Multi-Level	By Stair A	1 of 1	Water Fountain	right	<1
71	393799	Unit A - Main Building	Fountain/Tap Combo	Rm201	1 of 1	Water Fountain	right	<1