



**Technical Interim Amendment
District Master Specification
SECTION 26 05 33
ELECTRICAL SYSTEM RACEWAY and BOXES
2023 Edition**

Building Code Services BCS issues the following Technical Interim Amendment TIA to the 2023 edition to District Master Specification 26 05 33. This TIA was reviewed by BCS and approved for use in all district facilities and project specifications. This change to the DMS is scheduled for permanent adoption in the 2026 revision of the District Master Specification.

TIA 260533-23-1

Issue Date: May 1st, 2025

Effective Date: June 1st, 2025

Note: The proposed changes are in legislative text format. New wording is underscored and strike-through indicates ~~deleted~~ text. Associated text and section numbers are included to provide context to the change location within the specification.

PART 2 PRODUCTS

2.9 FLOOR BOXES

A. ~~Floor Boxes:~~ GENERALLY NOT ALLOWED

B. When permitted, in writing from the District;

1. Use cast iron floor boxes or nonmetallic floor boxes for installations in slab on grade; formed steel boxes are acceptable for other installations.
2. In meeting rooms (measuring at least 12' wide with a floor area of at least 215 square feet), stub up conduit and box with outlet in the location of the conference table leg furthest from the screen / smart board. (NEC 210.65)
3. Do not use floor boxes for feed through wiring except to another floor box.
4. Set floor boxes level.
5. Adjust floor box flush with finish flooring material.

PART 3 EXECUTION

3.2 INSTALLATION - BOXES

~~Q. Use cast iron floor boxes or nonmetallic floor boxes for installations in slab on grade; formed steel boxes are acceptable for other installations.~~

~~R. Set floor boxes level.~~

~~T. Do not use floor boxes for feed through wiring except to another floor box.~~

3.4 ADJUSTING

~~A. Adjust floor box flush with finish flooring material.~~