

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

April 22, 2025

Freehold Board of Education
280 Park Avenue
Freehold, NJ 07728
Attn.: Mr. Nicholas Davis
Director of Facilities

Re: Lead in Drinking Water Analysis at Freehold Learning Center

Dear Nick:

Pursuant to your request, in regards to the above referenced subject, **RAMM Environmental Services, Inc.** is pleased to submit to you our report including findings, analysis and recommendations.

Should you have any questions or need additional information, please feel free to call upon me at (201) 475-9880. Thank you very much.

Respectfully submitted,
RAMM Environmental Services, Inc.

Rodger Headrick

Rodger Headrick, CMRS
President

fh

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

LEAD IN DRINKING WATER ANALYSIS FOR FREEHOLD LEARNING CENTER APRIL 13, 2025

Prepared for:
Freehold Board of Education
280 Park Avenue
Freehold, NJ 07728
Attn.: Mr. Nicholas Davis
Director of Facilities
Tel: (732) 761-2154
Fax: (732) 462-8954

Prepared by:
RAMM Environmental Services, Inc.
77 Nottingham Road, PO Box 308
Fair Lawn, NJ 07410
Mr. Rodger Headrick
President
Tel: (201) 475-9880
Fax: (201) 475-9881

April 22, 2025

RAMM

REPORT CONTENTS

INTRODUCTION	1
WATER QUALITY MONITORING RESULTS	2
RECOMMENDATIONS	4
APPENDIX	
Lead in Drinking Water Certificate of Analysis	

INTRODUCTION

RAMM Environmental Services, Inc. was requested by the Freehold Board of Education to perform water sampling for lead content at the Freehold Learning Center located in Freehold, New Jersey.

Water quality sampling functions were performed by RAMM at the Freehold Learning Center located in Freehold, New Jersey on April 13, 2025, to determine the quality of drinking water for lead content. Water sampling began in the morning, after all water outlets had remained unused for a minimum of eight (8) hours.

**WATER QUALITY MONITORING RESULTS
LEAD IN DRINKING WATER ANALYSIS**

Lead in drinking water sampling was performed during RAMM’s April 13, 2025 site visit. The (E.P.A.) Environmental Protection Agency has established an enforceable lead concentration action level for public water supplies. The lead action level is 15 micrograms per liter (mg/L) = parts per billion (ppb), which is equivalent to 0.015 milligrams per liter (mg/L) = parts per million (ppm).

Freehold Learning Center

Lead in drinking water measurements were collected in thirty-five (35) locations of the building.

<i>Sample #</i>	<i>Location</i>	<i>Lead Concentration</i>
Field Blank	Field Blank	None Detected
25-0413-01	Kitchen (Sink 01)	2.03 ppb
25-0413-02	Kitchen (Sink 02)	4.82 ppb
25-0413-03	Kitchen (Sink 03)	2.34 ppb
25-0413-04	Room 02 (Sink)	None Detected
25-0413-05	Room 03 (Sink)	None Detected
25-0413-06	Room 04 (Sink)	None Detected
25-0413-07	Room 18 (Sink 01)	None Detected
25-0413-08	Room 18 (Sink 02)	None Detected
25-0413-09	Room 18 (Sink 03)	None Detected
25-0413-10	Room 05 (Sink)	None Detected
25-0413-11	Room 06 (Sink)	None Detected
25-0413-12	Room 07 (Sink)	None Detected
25-0413-13	Faculty Room (Sink)	None Detected
25-0413-14	Room 09 (Sink)	None Detected
25-0413-15	Room 10 (Sink)	None Detected
25-0413-16	Room 11 (Sink)	None Detected
25-0413-17	Room 12 (Sink)	None Detected
25-0413-18	Room 13 (Sink)	None Detected
25-0413-19	Room 14 (Sink)	None Detected
25-0413-20	Room 15 (Sink)	None Detected
25-0413-21	Room 16 (Sink)	1.72 ppb
25-0413-22	Hallway Music Room (Water Fountain)	None Detected
25-0413-23	Hallway Boys Bathroom (Water Fountain)	None Detected
25-0413-24	Nurse Room (Sink)	1.10 ppb
25-0413-25	Ms. Stewart Class (Sink)	1.10 ppb

RAMM

25-0413-26	Ms. Miller Class (Sink)	1.10 ppb
25-0413-27	Ms. Francke Class (Sink)	1.41 ppb
25-0413-28	Ms. Sohatl Class (Sink)	3.12 ppb
25-0413-29	Ms. O'Donnell Class (Sink)	2.81 ppb
25-0413-30	New Kitchen (Sink 01)	None Detected
25-0413-31	New Kitchen (Sink 02)	None Detected
25-0413-32	Ms. Guarino Class (Sink)	9.32 ppb
25-0413-33	Ms. Traynor Class (Sink)	3.43 ppb
25-0413-34	Ms. Hanenberg Class (Sink)	7.61 ppb
25-0413-35	Ms. Lazaro Class (Sink)	11.3 ppb

All results report less than the United States Environmental Protection Agency (U.S.E.P.A.) Guidelines and the New Jersey Department of Environmental Protection (N.J.D.E.P.) for safe drinking water (15 ppb). Currently the drinking water is safe and poses no health hazard to building occupants.

RECOMMENDATIONS

Continue operation and maintenance as normal. Re-test all drinking water outlets during the 2027-2028 school year.