

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

April 22, 2025

Freehold Board of Education
280 Park Avenue
Freehold, NJ 07728
Attn.: Mr. Nicholas Davis
Director of Facilities

Re: Lead in Drinking Water Analysis at Park Avenue Elementary School

Dear Nick:

Pursuant to your request, in regards to the above referenced subject, **RAMM Environmental Services, Inc.** is pleased to submit to you our report including findings, analysis and recommendations.

Should you have any questions or need additional information, please feel free to call upon me at (201) 475-9880. Thank you very much.

Respectfully submitted,
RAMM Environmental Services, Inc.

Rodger Headrick

Rodger Headrick, CMRS
President

fh

Written Program Indoor Air Quality Standard - PEOSH
Indoor Air Quality Survey & Testing for Sick Building Syndrome
Remediation/Cleanup of Mold & Moisture Problems in Schools & Commercial Buildings
Indoor Air Quality in Schools Awareness Training for Administrative/Maintenance Personnel
Asbestos Surveys and AHERA Management Plans
AHERA 2 Hour Awareness Training
"Non-Friable" Asbestos Final Air Clearance Sampling
Right to Know Survey, Compliance & PEOSHA Training
Written Hazard Communication Program (PEOSHA HCS)

RAMM Environmental Services, Inc.

Commitment, Excellence, Integrity

77 Nottingham Road, PO Box 308
Fair Lawn, New Jersey 07410
Phone: (201) 475-9880
Fax: (201) 475-9881

**LEAD IN DRINKING WATER ANALYSIS
FOR
PARK AVENUE ELEMENTARY SCHOOL
APRIL 13, 2025**

**Prepared for:
Freehold Board of Education
280 Park Avenue
Freehold, NJ 07728
Attn.: Mr. Nicholas Davis
Director of Facilities
Tel: (732) 761-2154
Fax: (732) 462-8954**

**Prepared by:
RAMM Environmental Services, Inc.
77 Nottingham Road, PO Box 308
Fair Lawn, NJ 07410
Mr. Rodger Headrick
President
Tel: (201) 475-9880
Fax: (201) 475-9881**

April 22, 2025

REPORT CONTENTS

INTRODUCTION	1
WATER QUALITY MONITORING RESULTS	2
RECOMMENDATIONS	4
APPENDIX	
Lead in Drinking Water Certificate of Analysis	

INTRODUCTION

RAMM Environmental Services, Inc. was requested by the Freehold Board of Education to perform water sampling for lead content at the Park Avenue Elementary School located in Freehold, New Jersey.

Water quality sampling functions were performed by RAMM at the Park Avenue Elementary School located in Freehold, New Jersey on April 13, 2025, to determine the quality of drinking water for lead content. Water sampling began in the morning, after all water outlets had remained unused for a minimum of eight (8) hours.

**WATER QUALITY MONITORING RESULTS
LEAD IN DRINKING WATER ANALYSIS**

Lead in drinking water sampling was performed during RAMM’s April 13, 2025 site visit. The (E.P.A.) Environmental Protection Agency has established an enforceable lead concentration action level for public water supplies. The lead action level is 15 micrograms per liter (mg/L) = parts per billion (ppb), which is equivalent to 0.015 milligrams per liter (mg/L) = parts per million (ppm).

Park Avenue Elementary School

Lead in drinking water measurements were collected in twenty-two (22) locations of the building.

<i>Sample #</i>	<i>Location</i>	<i>Lead Concentration</i>
Field Blank	Field Blank	None Detected
25-0413-01	Nurse Room (Sink)	None Detected
25-0413-02	Hallway by New Gym (Water Fountain)	None Detected
25-0413-03	Boys Locker Room (Water Fountain)	None Detected
25-0413-04	Girls Locker Room (Water Fountain)	None Detected
25-0413-05	Library Office (Sink)	None Detected
25-0413-06	7 th Grade Hallway Intermediate (Water Fountain)	None Detected
25-0413-07	Kitchen (Sink 01)	None Detected
25-0413-08	Kitchen (Sink 02)	None Detected
25-0413-09	Kitchen (Sink 03)	None Detected
25-0413-10	Cafeteria (Water Fountain 1)	None Detected
25-0413-11	Cafeteria (Water Fountain 2)	None Detected
25-0413-12	Intermediate Faculty Room (Sink)	None Detected
25-0413-13	8 th Grade Hallway (Water Fountain)	None Detected
25-0413-14	Park Avenue Faculty Room (Sink)	None Detected
25-0413-15	BOE Office Kitchen (Sink)	None Detected
25-0413-16	5 th Grade Hallway (Water Fountain)	None Detected
25-0413-17	Hallway by Room A-18 (Water Fountain)	None Detected
25-0413-18	Room A-12 (Sink)	None Detected
25-0413-19	Tech Office Bathroom (Sink)	1.55 ppb
25-0413-20	Art Room (Water Fountain)	5.64 ppb
25-0413-21	Art Room (Bubbler 01)	None Detected
25-0413-22	Art Room (Bubbler 02)	None Detected

RAMM

All results report less than the United States Environmental Protection Agency (U.S.E.P.A.) Guidelines and the New Jersey Department of Environmental Protection (N.J.D.E.P.) for safe drinking water (15 ppb). Currently the drinking water is safe and poses no health hazard to building occupants.

RECOMMENDATIONS

Continue operation and maintenance as normal. Re-test all drinking water outlets during the 2027-2028 school year.