



CERTIFICATE OF ANALYSIS

Customer : RAMM Environmental Services, INC
77 Nottingham Road
Fair Lawn, NJ 07410

Project ID : Freehold Learning Center, 30 Dutch Lane Road Freehold, NJ 07728
PAS Project ID : P25-03071

Matrix : Drinking Water
Report Date : 4/21/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03071-01	Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:30	4/17/25 14:13
P25-03071-02	Kitchen Sink 01	Lead	2.03	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:32	4/17/25 14:18
P25-03071-03	Kitchen Sink 02	Lead	4.82	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:34	4/17/25 14:22
P25-03071-04	Kitchen Sink 03	Lead	2.34	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:36	4/17/25 14:26
P25-03071-05	Room # 02 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:38	4/17/25 14:31
P25-03071-06	Room # 03 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:40	4/17/25 14:35
P25-03071-07	Room # 04 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:42	4/17/25 14:40
P25-03071-08	Room # 18 Sink 01	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:45	4/17/25 14:53
P25-03071-09	Room # 18 Sink 02	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:47	4/17/25 14:58
P25-03071-10	Room # 18 Sink 03	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:50	4/17/25 15:02
P25-03071-11	Room # 05 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:52	4/17/25 15:07
P25-03071-12	Room # 06 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:54	4/17/25 15:11
P25-03071-13	Room # 07 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:56	4/17/25 15:16
P25-03071-14	Faculty Room Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:58	4/17/25 15:21
P25-03071-15	Room # 09 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:00	4/17/25 15:25
P25-03071-16	Room # 10 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:02	4/17/25 15:30
P25-03071-17	Room # 11 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:05	4/17/25 15:43
P25-03071-18	Room # 12 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:07	4/17/25 15:48
P25-03071-19	Room # 13 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:09	4/17/25 15:52
P25-03071-20	Room # 14 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:12	4/17/25 16:10
P25-03071-21	Room # 15 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:14	4/17/25 16:14
P25-03071-22	Room # 16 Sink	Lead	1.72 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:16	4/17/25 16:19
P25-03071-23	Hallway (Music Room) Water Fountain	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:16	4/17/25 16:32
P25-03071-24	Hallway (Boys BR) Water Fountain	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:18	4/17/25 16:37
P25-03071-25	Nurse Room Sink	Lead	1.10 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:20	4/17/25 16:41
P25-03071-26	Ms. Stewart Class Sink	Lead	1.10 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:22	4/17/25 16:45
P25-03071-27	Ms. Miller Class Sink	Lead	1.10 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:24	4/17/25 16:50
P25-03071-28	Ms. Francke Class Sink	Lead	1.41 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:26	4/17/25 16:54
P25-03071-29	Ms. Sohatl Class Sink	Lead	3.12	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:28	4/17/25 16:59
P25-03071-30	Ms. O'Donnell Class Sink	Lead	2.81	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:30	4/17/25 17:03
P25-03071-31	New Kitchen Sink 01	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:34	4/17/25 17:08
P25-03071-32	New Kitchen Sink 02	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:36	4/17/25 17:28
P25-03071-33	Ms. Guarino Class Sink	Lead	9.32	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:40	4/17/25 17:32
P25-03071-34	Ms. Traynor Class Sink	Lead	3.43	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:42	4/17/25 17:36
P25-03071-35	Ms. Hanenberg Class Sink	Lead	7.61	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:44	4/17/25 17:41
P25-03071-36	Ms. Lazaro Class Sink	Lead	11.3	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 10:46	4/17/25 18:00

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

CHAIN OF CUSTODY

✓ LE

##

#VALUE!

Customer: RAMM Environmental Services
 Address: 77 Nottingham Road, PO Box 308
 Fair Lawn, NJ 07410
 Phone: 201-475-9880

School Name: Frederick Learning Center
 School Address: 30 Dutch Lane, Fair Lawn, NJ 07410
 Sampled By: [Signature]
 Print Name: VLADO VICOLOSKI
 RESULTS TO: rammenvironmental@gmail.com

Sample ID	Location	Date / Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
B.	BLANK	04/16/25 8:30	DW	Grab	Yes		1	250 ml Plastic	Lead	P25-03071-0
01	Kitchen - Sink # 01	8:32	DW	Grab	Y		1	250 ml Plastic	Lead	-02
02	Kitchen - Sink # 02	8:34	DW	Grab	Y		1	250 ml Plastic	Lead	-03
03	Kitchen - Sink # 03	8:31	DW	Grab	Y		1	250 ml Plastic	Lead	-04
04	Room # 02 - Sink	8:38	DW	Grab	Y		1	250 ml Plastic	Lead	-05
05	Room # 03 - Sink	8:40	DW	Grab	Y		1	250 ml Plastic	Lead	-06
06	Room # 04 - Sink	8:42	DW	Grab	Y		1	250 ml Plastic	Lead	-07
07	Room # 18 - Sink # 01	8:45	DW	Grab	Y		1	250 ml Plastic	Lead	-08
08	Room # 18 - Sink # 02	8:47	DW	Grab	Y		1	250 ml Plastic	Lead	-09
09	Room # 18 - Sink # 03	8:50	DW	Grab	Y		1	250 ml Plastic	Lead	-10
10	Room # 05 - Sink	8:52	DW	Grab	Y		1	250 ml Plastic	Lead	-11
11	Room # 06 - Sink	8:54	DW	Grab	Y		1	250 ml Plastic	Lead	-12
12	Room # 07 - Sink	8:56	DW	Grab	Y		1	250 ml Plastic	Lead	-13
13	Faculty room - Sink	8:58	DW	Grab	Y		1	250 ml Plastic	Lead	-14
14	Room # 09 - Sink	10:00	DW	Grab	Y		1	250 ml Plastic	Lead	P25-03071-15

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

PDF Std. Reduce Full EDD

1 week TAT

Page 1 of 3

Deliverables:

X

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):
 Note: All samples preserved with HNO3

PRESERVATIVE CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

Relinquished:	Print Name:	Signature:	Company:	Date + Time
Relinquished:	VLADO VICOLOSKI	[Signature]	RAMM	04/16/25 4:11
Received:	Bob Grotta	[Signature]	YAL	14:30 4/16/25
Relinquished:	Bob Grotta	[Signature]	YAL	4/16/25 18:00
Received:	Lauren Palumbo	[Signature]	YAL	4/16/25 9:00

Total of 30 samples plus 1 BLANK

CHAIN OF CUSTODY

VLP

##

#VALUE!

Customer:	RAMM Environmental Services
Address:	77 Nottingham Road, PO Box 308
	Fair Lawn, NJ 07410
Phone:	201-475-9880

School Name:	Freemild Learning Center
School Address:	30 Dutch Lane Road, Freemild, NJ
Sampled By:	<i>[Signature]</i>
Print Name:	Waldo Vicosky
RESULTS TO:	rammenvironmental@gmail.com

Sample ID	Location	Date / Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
15	Room # 10 - Sink	04/13/25 10:02	DW	Grab	Yes		1	250 ml Plastic	Lead	P25-03011-16
16	Room # 11 - Sink	10:05	DW	Grab	X		1	250 ml Plastic	Lead	-17
17	Room # 12 - Sink	10:07	DW	Grab	X		1	250 ml Plastic	Lead	-18
18	Room # 13 - Sink	10:09	DW	Grab	X		1	250 ml Plastic	Lead	-19
19	Room # 14 - Sink	10:12	DW	Grab	X		1	250 ml Plastic	Lead	-20
20	Room # 15 - Sink	10:14	DW	Grab	X		1	250 ml Plastic	Lead	-21
21	Room # 16 - Sink	10:16	DW	Grab	X		1	250 ml Plastic	Lead	-22
22	Hallway / Gymnasium (water fountain)	10:18	DW	Grab	X		1	250 ml Plastic	Lead	-23
23	Hallway / Boys Bathroom (water fountain)	10:20	DW	Grab	X		1	250 ml Plastic	Lead	-24
24	Nurse room - Sink	10:22	DW	Grab	X		1	250 ml Plastic	Lead	-25
25	Ms. Stewart class - Sink	10:24	DW	Grab	X		1	250 ml Plastic	Lead	-26
26	Ms. Miller class - Sink	10:26	DW	Grab	X		1	250 ml Plastic	Lead	-27
27	Ms. Franck class - Sink	10:28	DW	Grab	X		1	250 ml Plastic	Lead	-28
28	Ms. Sotatz class - Sink	10:30	DW	Grab	X		1	250 ml Plastic	Lead	-29
29	Ms. O'Donwell class - Sink		DW	Grab	X		1	250 ml Plastic	Lead	P25-03011-30

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

PDF Std. Reduce Full EDD

1 week TAT

Page 2 of 3

Deliverables: X

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

None of the samples preserved with HNO3

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

Relinquished:	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Waldo Vicosky	<i>[Signature]</i>	Ramm	04/13/25 4:30
Received:				
Relinquished:				
Received:	Bob Grotta	<i>[Signature]</i>	York	4/15/25 12:00
Relinquished:	Bob Grotta	<i>[Signature]</i>	York	4/15/25 1:00
Received:	Lauren Palumbo	<i>[Signature]</i>	YAL	4/16/25 9:00

CHAIN OF CUSTODY

##

#VALUE!

✓/LP

Customer: RAMM Environmental Services
 Address: 77 Nottingham Road, PO Box 308
 Fair Lawn, NJ 07410
 Phone: 201-475-9880

School Name: Friends Learning Center
 School Address: 30 Durbin Lane, Fair Lawn, NJ
 Sampled By: [Signature]
 Print Name: Vlado Vicanosky
 RESULTS TO: rammenvironmental@gmail.com

Sample ID	Location	Date / Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
30	New Kitchen - <u>SINK # 01</u>	<u>04/13/16</u> <u>10:31</u>	DW	Grab	✓		1	250 ml Plastic	Lead	<u>P25-03071-31</u>
31	New Kitchen - <u>SINK # 02</u>	<u>10:31</u>	DW	Grab	✓		1	250 ml Plastic	Lead	<u>-32</u>
32	<u>MS. GUARINO class</u>	<u>10:40</u>	DW	Grab	✓		1	250 ml Plastic	Lead	<u>-33</u>
33	<u>MS. TRAYNER class</u>	<u>10:42</u>	DW	Grab	✓		1	250 ml Plastic	Lead	<u>-34</u>
34	<u>MS. HANENBERG class</u>	<u>10:44</u>	DW	Grab	✓		1	250 ml Plastic	Lead	<u>P25-03071-35</u>
35	<u>MS. LAZARO class</u>	<u>10:48</u>	DW	Grab	✓		1	250 ml Plastic	Lead	
		<u>10:55</u>	DW	Grab	✓		1	250 ml Plastic	Lead	
			DW	Grab	✓		1	250 ml Plastic	Lead	
			DW	Grab	✓		1	250 ml Plastic	Lead	
			DW	Grab	✓		1	250 ml Plastic	Lead	
			DW	Grab	✓		1	250 ml Plastic	Lead	
			DW	Grab	✓		1	250 ml Plastic	Lead	
			DW	Grab	✓		1	250 ml Plastic	Lead	
			DW	Grab	✓		1	250 ml Plastic	Lead	
			DW	Grab	✓		1	250 ml Plastic	Lead	
			DW	Grab	✓		1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

1 week TAT

Page 3 of 3 Deliverables: PDF Std. PDF Reduce PDF Full EDD Date/Time Preserved with HNO3:

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify): Notes: All samples preserved with HNO3

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

Relinquished:	Print Name:	Signature:	Company:	Date + Time
Relinquished:	<u>Vlado Vicanosky</u>	<u>[Signature]</u>	<u>RAMM</u>	<u>04/13/16</u>
Received:				<u>14:30</u>
Relinquished:				<u>4/15/16 12:00</u>
Received:	<u>Bob Conth</u>	<u>[Signature]</u>	<u>Tark</u>	<u>4/15/16 18:55</u>
Relinquished:	<u>Bob Conth</u>	<u>[Signature]</u>	<u>Tark</u>	
Received:	<u>Lauren Palumbo</u>	<u>[Signature]</u>	<u>YAL</u>	<u>4/16/16 9:00</u>