



CERTIFICATE OF ANALYSIS

Customer : RAMM Environmental Services, INC
77 Nottingham Road
Fair Lawn, NJ 07410

Project ID : Park Avenue Elementary School, 280 Park Avenue Freehold, NJ 07728

Matrix : Drinking Water

PAS Project ID : P25-03070

Report Date : 4/21/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03070-01	Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:00	4/17/25 13:29
P25-03070-02	Nurse Room - Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:00	4/17/25 13:33
P25-03070-03	Hallway By New Gym Water Fountain	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:02	4/17/25 13:37
P25-03070-04	Boys Locker Room Water Fountain	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:05	4/17/25 13:50
P25-03070-05	Girls Locker Room Water Fountain	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:07	4/17/25 13:54
P25-03070-06	Library Office Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:09	4/17/25 13:58
P25-03070-07	7th Grade Hallway Intermediate WF	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:11	4/17/25 14:02
P25-03070-08	Kitchen Sink 01	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:14	4/17/25 14:06
P25-03070-09	Kitchen Sink 02	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:15	4/17/25 14:10
P25-03070-10	Kitchen Sink 03	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:16	4/17/25 14:14
P25-03070-11	Cafeteria Water Fountain 01	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:18	4/17/25 14:38
P25-03070-12	Cafeteria Water Fountain 02	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:20	4/17/25 14:42
P25-03070-13	Intermediate Faculty Room Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:22	4/17/25 14:46
P25-03070-14	8th Grade Hallway Water Fountain	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:24	4/17/25 14:50
P25-03070-15	Park Ave School Faculty Room Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:28	4/17/25 14:54
P25-03070-16	BOE Office Kitchen Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:31	4/17/25 14:58
P25-03070-17	5th Grade Hallway Water Fountain	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:33	4/17/25 15:02
P25-03070-18	Hallway By Room A-18 Water Fountain	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:36	4/17/25 15:06
P25-03070-19	Room # A-12 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:39	4/17/25 15:23
P25-03070-20	Tech Office Bathroom Sink	Lead	1.55 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:42	4/17/25 15:27
P25-03070-21	Art Room Water Fountain	Lead	5.64	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:44	4/17/25 15:31
P25-03070-22	Art Room Bubbler #1	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:46	4/17/25 15:35
P25-03070-23	Art Room Bubbler #2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/13/25 08:47	4/17/25 15:39

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

CHAIN OF CUSTODY

#VALUE!

✓ LR

Customer: RAMM Environmental Services
 Address: 77 Nottingham Road, PO Box 308
 Fair Lawn, NJ 07410
 Phone: 201-475-9880

School Name: Park Ave. Elem. School
 School Address: 230 Park Ave. Fairhold, NJ 07410
 Sampled By: [Signature]
 Print Name: VLADO VICOROSKI
 RESULTS TO: rammenviro@gmail.com

Sample ID	Location	Date / Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
B	BLANK	04/13/25	DW	Grab	Yes		1	250 ml Plastic	Lead	P25-03070-0
01	Nurse room - sink	8:00	DW	Grab	Yes		1	250 ml Plastic	Lead	-02
02	Hallway (by new Gym) water fountain	8:02	DW	Grab	yes		1	250 ml Plastic	Lead	-03
03	Boys Locker room - water foun	8:05	DW	Grab	yes		1	250 ml Plastic	Lead	-04
04	Girls Locker room - water foun	8:07	DW	Grab	yes		1	250 ml Plastic	Lead	-05
05	Library office - sink	8:09	DW	Grab	yes		1	250 ml Plastic	Lead	-06
06	3rd Grade room - water foun	8:11	DW	Grab	yes		1	250 ml Plastic	Lead	-07
07	Kitchen - sink - 01	8:14	DW	Grab	yes		1	250 ml Plastic	Lead	-08
08	Kitchen - sink - 02	8:15	DW	Grab	yes		1	250 ml Plastic	Lead	-09
09	Kitchen - sink - 03	8:16	DW	Grab	yes		1	250 ml Plastic	Lead	-10
10	Copier room - water foun #01	8:18	DW	Grab	yes		1	250 ml Plastic	Lead	-11
11	Copier - water foun #02	8:20	DW	Grab	yes		1	250 ml Plastic	Lead	-12
12	Faculty room - sink	8:22	DW	Grab	yes		1	250 ml Plastic	Lead	-13
13	3rd-Grade room - water foun	8:24	DW	Grab	yes		1	250 ml Plastic	Lead	-14
14	Pink Ave. School - FACULTY ROOM - sink	8:28	DW	Grab	yes		1	250 ml Plastic	Lead	P25-03070-15

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

PDF Full EDD
 PDF Reduce
 PDF Full

1 WEEK TAT

Page 1 of 2

Deliverables: X

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

Notes: All samples preserved with HNO3

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Vlado Vicoroski	[Signature]	RAMM	04/13/25
Received:	Bob Gratton	[Signature]	Yank	4/15/25 12:00
Relinquished:	Bob Gratton	[Signature]	Yank	4/15/25 18:30
Received:	Lauren Palumbo	[Signature]	YAL	4/16/25 9:00
Relinquished:				
Received:				

Total of 22 samples plus 1-blank

CHAIN OF CUSTODY

✓LP

Park Ave.

#VALUE!

Customer:	RAMM Environmental Services
Address:	77 Nottingham Road, PO Box 308 Fair Lawn, NJ 07410
Phone:	201-475-9880

School Name:	Freemold Intermediate School
School Address:	220 Park Ave, Freemold, NJ, 07728
Sampled By:	<i>[Signature]</i>
Print Name:	Vlado Vicholas
RESULTS TO:	rammenvironmental@gmail.com

15.
16.
17.
18.
19.
20.
21.
22.

Sample ID Location	Date / 125 Time sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
BOE - OFFICE KITCHEN - SWM	4/15/25 8:31	DW	Grab	Yes		1	250 ml Plastic	Lead	P25-03010-16
5th-Grade Hallway - water fount.	8:33	DW	Grab	Y		1	250 ml Plastic	Lead	-17
Hallway (by room A-13)	8:36	DW	Grab	Y		1	250 ml Plastic	Lead	-18
Room A-12 - SWM	8:35	DW	Grab	Y		1	250 ml Plastic	Lead	-19
TECH. OFFICE - SWM	8:42	DW	Grab	Y		1	250 ml Plastic	Lead	-20
ART ROOM # WATER Fountain	8:44	DW	Grab	Y		1	250 ml Plastic	Lead	-21
ART ROOM - Bubble # 01	8:46	DW	Grab	Y		1	250 ml Plastic	Lead	-22
ART ROOM - Bubble # 02	8:47	DW	Grab	Y		1	250 ml Plastic	Lead	P25-03010-23
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

1 week TAT

Page 2 of 2	Deliverables:	PDF Std. X	PDF Reduce	PDF Full	EDD	Date/Time Preserved with HNO3:
-------------	---------------	------------	------------	----------	-----	--------------------------------

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

None of the samples preserved with HNO3

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company	Date + Time
Relinquished:	Vlado Vicholas	<i>[Signature]</i>	Ramm	4/15/25
Received:	Bob Grotta	<i>[Signature]</i>	York	4/15/25 12:00
Relinquished:	Bob Grotta	<i>[Signature]</i>	York	4/15/25 18:55
Received:	Lauren Palumbo	<i>[Signature]</i>	YAL	4/16/25 9:00
Relinquished:				
Received:				

Total of 22 samples plus 1 - Blank