

Holland Patent CSD

<u>Sample Location</u>	<u>Sample Identification #</u>	<u>Site Description</u>	<u>Common name of outlet (1st floor drinking fountain)</u>	<u>Analyte</u>	<u>UNITS: 1 UG/L=1PPB</u>	<u>Date Analyzed</u>	<u>Results</u>	<u>NYSDOH Action Level</u>	<u>Actions taken by district (out of service, signage, filter, etc)</u>
GWF Elementary	HPGWF10	Room 2	Classroom Sink	LEAD	UG/L	5/17/2024	17.4	5.0 PPB	Signage
GWF Elementary	HPGWF15	Room 4	Classroom Sink	LEAD	UG/L	5/17/2024	7.7	5.0 PPB	Signage
GWF Elementary	HPGWF78	Room 18	Classroom Sink	LEAD	UG/L	5/17/2024	165	5.0 PPB	Signage
GWF Elementary	HPGWF195	Library	Classroom Sink	LEAD	UG/L	5/17/2024	148	5.0 PPB	Signage
Middle School	HPMS47	Health Office - Exam Room	Sink 1	LEAD	UG/L	5/17/2024	7.7	5.0 PPB	Signage
Middle School	HPMS73	Room 211	Classroom Sink 3	LEAD	UG/L	5/17/2024	19.1	5.0 PPB	Signage
Middle School	HPMS78	Room 209 - Faculty Room	Classroom Sink 1	LEAD	UG/L	5/17/2024	5.9	5.0 PPB	Signage
Middle School	HPMS79	Room 209 - Faculty Room (No	Classroom Sink 2	LEAD	UG/L	5/17/2024	13.6	5.0 PPB	Signage
High School	HPHS5	Coach's Office	Bathroom Sink	LEAD	UG/L	5/16/2024	5.6	5.0 PPB	Signage
High School	HPHS12	Nurse's Office	Classroom Sink	LEAD	UG/L	5/16/2024	7.7	5.0 PPB	Signage
High School	HPHS24	Room 136	Classroom Sink 1	LEAD	UG/L	5/16/2024	7.2	5.0 PPB	Signage
High School	HPHS31	Kitchen	Kitchen Sink 3	LEAD	UG/L	5/16/2024	9	5.0 PPB	Signage
High School	HPHS32	Kitchen	Kitchen Sink 4	LEAD	UG/L	5/16/2024	5.8	5.0 PPB	Signage
High School	HPHS95	Band Room	Classroom Sink	LEAD	UG/L	5/16/2024	5.2	5.0 PPB	Signage
High School	HPHS117	Coach's Office	Sink	LEAD	UG/L	5/16/2024	5.2	5.0 PPB	Signage
Annex	HPA7	Pupil Services Sink	Sink	LEAD	UG/L	5/16/2024	5.5	5.0 PPB	Signage
Holland Patent Elementary	HPE3	Room 1	Classroom Sink	LEAD	UG/L	5/16/2024	14.7	5.0 PPB	Signage
Holland Patent Elementary	HPE6	Room 3	Classroom Sink	LEAD	UG/L	5/16/2024	5.4	5.0 PPB	Signage
Holland Patent Elementary	HPE9	Room 5	Classroom Sink	LEAD	UG/L	5/16/2024	11.7	5.0 PPB	Signage
Holland Patent Elementary	HPE12	Room 7	Classroom Sink	LEAD	UG/L	5/16/2024	14.8	5.0 PPB	Signage
Holland Patent Elementary	HPE15	Room 8	Classroom Sink	LEAD	UG/L	5/16/2024	9.3	5.0 PPB	Signage
Holland Patent Elementary	HPE17	Room 6	Classroom Sink	LEAD	UG/L	5/16/2024	9	5.0 PPB	Signage
Holland Patent Elementary	HPE18	Room 6	Drinking Fountain	LEAD	UG/L	5/16/2024	10	5.0 PPB	Out Of Service
Holland Patent Elementary	HPE20	Room 4	Classroom Sink	LEAD	UG/L	5/16/2024	6.5	5.0 PPB	Signage
Holland Patent Elementary	HPE21	Room 4	Drinking Fountain	LEAD	UG/L	5/16/2024	7.2	5.0 PPB	Out Of Service
Holland Patent Elementary	HPE23	Room 2 - Art	Classroom Sink	LEAD	UG/L	5/16/2024	9.4	5.0 PPB	Signage
Holland Patent Elementary	HPE24	Room 2 - Art	Drinking Fountain	LEAD	UG/L	5/16/2024	6.1	5.0 PPB	Out Of Service
Holland Patent Elementary	HPE30	Kitchen	Kitchen Sink 1	LEAD	UG/L	5/16/2024	13.2	5.0 PPB	Signage
Holland Patent Elementary	HPE37	Room 11	Classroom Sink	LEAD	UG/L	5/16/2024	10.5	5.0 PPB	Signage
Holland Patent Elementary	HPE35	Room 13	Drinking Fountain	LEAD	UG/L	5/16/2024	9.9	5.0 PPB	Out Of Service
Holland Patent Elementary	HPE41	Room 12	Drinking Fountain	LEAD	UG/L	5/16/2024	8.3	5.0 PPB	Out Of Service
Holland Patent Elementary	HPE43	Room 14	Classroom Sink	LEAD	UG/L	5/16/2024	8.5	5.0 PPB	Signage
Holland Patent Elementary	HPE46	Room 16	Classroom Sink	LEAD	UG/L	5/16/2024	7	5.0 PPB	Signage
Holland Patent Elementary	HPE47	Room 16	Drinking Fountain	LEAD	UG/L	5/16/2024	10.4	5.0 PPB	Out Of Service
Holland Patent Elementary	HPE49	Room 18	Classroom Sink	LEAD	UG/L	5/16/2024	8.1	5.0 PPB	Signage
Holland Patent Elementary	HPE50	Room 18	Drinking Fountain	LEAD	UG/L	5/16/2024	10.5	5.0 PPB	Out Of Service
Holland Patent Elementary	HPE52	Room 20	Classroom Sink	LEAD	UG/L	5/16/2024	11.1	5.0 PPB	Signage
Holland Patent Elementary	HPE55	Room 22	Classroom Sink	LEAD	UG/L	5/16/2024	11.9	5.0 PPB	Signage
Holland Patent Elementary	HPE65	Room 15/ Faculty	Sink	LEAD	UG/L	5/16/2024	5.9	5.0 PPB	Signage
Concession Stand	HPCS1	Concession Stand	Sink	LEAD	UG/L	5/16/2024	31.1	5.0 PPB	Signage