

Lead in School Drinking Water Report

Edmonds Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-03-27

Date(s) analyzed: 2025-04-02, 2025-04-08

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	393838	Unit A - Admin	Fountain/Tap Combo	Library Office	1 of 1	Water Fountain	right	43
2	393903	Unit C - Classrooms	Fountain/Tap Combo	Rm18	1 of 1	Tap	left	12
3	393837	Unit A - Admin	Fountain/Tap Combo	Library Office	1 of 1	Tap	left	9
4	393887	Unit C - Classrooms	Fountain/Tap Combo	Rm8	1 of 1	Tap	left	9
5	394397	Unit C - Classrooms	Fountain/Tap Combo	16-20 Pod	1 of 1	Tap	left	8
6	394387	Unit B - Classrooms	Fountain/Tap Combo	Rm11	1 of 1	Tap	left	6
7	393881	Unit C - Classrooms	Fountain/Tap Combo	6-10 Pod	1 of 1	Tap	left	5
8	393885	Unit C - Classrooms	Fountain/Tap Combo	Rm7	1 of 1	Tap	left	4
9	393891	Unit C - Classrooms	Fountain/Tap Combo	Rm10	1 of 1	Tap	left	4
10	393907	Unit C - Classrooms	Fountain/Tap Combo	Rm20	1 of 1	Tap	left	4

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	394389	Unit B - Classrooms	Fountain/Tap Combo	Rm12	1 of 1	Tap	left	4
12	394391	Unit B - Classrooms	Fountain/Tap Combo	Rm13	1 of 1	Tap	left	4
13	393893	Unit B - Classrooms	Fountain/Tap Combo	1-5 Pod	1 of 1	Tap	left	3
14	394381	Unit B - Classrooms	Fountain/Tap Combo	Rm2	1 of 1	Tap	left	3
15	394383	Unit B - Classrooms	Fountain/Tap Combo	Rm1	1 of 1	Tap	left	3
16	393880	Unit A - Admin	Sink	Staff Room	1 of 1	Tap	center	2
17	393883	Unit C - Classrooms	Fountain/Tap Combo	Rm6	1 of 1	Tap	left	2
18	393889	Unit C - Classrooms	Fountain/Tap Combo	Rm9	1 of 1	Tap	left	2
19	393895	Unit B - Classrooms	Fountain/Tap Combo	Rm5	1 of 1	Tap	left	2
20	393899	Unit B - Classrooms	Fountain/Tap Combo	Rm3	1 of 1	Tap	left	2
21	393901	Unit C - Classrooms	Fountain/Tap Combo	Rm17	1 of 1	Tap	left	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	393905	Unit C - Classrooms	Fountain/Tap Combo	Rm19	1 of 1	Tap	left	2
23	394393	Unit B - Classrooms	Fountain/Tap Combo	Rm14	1 of 1	Tap	left	2
24	394394	Unit B - Classrooms	Fountain/Tap Combo	Rm14	1 of 1	Water Fountain	right	2
25	394399	Unit C - Classrooms	Fountain/Tap Combo	Rm16	1 of 1	Tap	left	2
26	393839	Unit A - Admin	Sink	Health Room	1 of 1	Tap	center	1
27	393882	Unit C - Classrooms	Fountain/Tap Combo	6-10 Pod	1 of 1	Water Fountain	right	1
28	393904	Unit C - Classrooms	Fountain/Tap Combo	Rm18	1 of 1	Water Fountain	right	1
29	394385	Unit B - Classrooms	Fountain/Tap Combo	11-15 Pod	1 of 1	Tap	left	1
30	393835	Unit D - Multipurpose	Fountain with Bottle Filler	Outside Kitchen	1 of 1	Water Fountain	center	<1
31	393836	Unit D - Multipurpose	Fountain with Bottle Filler	Outside Kitchen	1 of 1	Water Bottle Filler	center	<1
32	393884	Unit C - Classrooms	Fountain/Tap Combo	Rm6	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	393886	Unit C - Classrooms	Fountain/Tap Combo	Rm7	1 of 1	Water Fountain	right	<1
34	393888	Unit C - Classrooms	Fountain/Tap Combo	Rm8	1 of 1	Water Fountain	right	<1
35	393890	Unit C - Classrooms	Fountain/Tap Combo	Rm9	1 of 1	Water Fountain	right	<1
36	393892	Unit C - Classrooms	Fountain/Tap Combo	Rm10	1 of 1	Water Fountain	right	<1
37	393894	Unit B - Classrooms	Fountain/Tap Combo	1-5 Pod	1 of 1	Water Fountain	right	<1
38	393896	Unit B - Classrooms	Fountain/Tap Combo	Rm5	1 of 1	Water Fountain	right	<1
39	393897	Unit B - Classrooms	Fountain/Tap Combo	Rm4	1 of 1	Tap	left	<1
40	393898	Unit B - Classrooms	Fountain/Tap Combo	Rm4	1 of 1	Water Fountain	right	<1
41	393900	Unit C - Classrooms	Fountain/Tap Combo	Rm16	1 of 1	Water Fountain	right	<1
42	393902	Unit C - Classrooms	Fountain/Tap Combo	Rm17	1 of 1	Water Fountain	right	<1
43	393906	Unit C - Classrooms	Fountain/Tap Combo	Rm19	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	393908	Unit B - Classrooms	Fountain/Tap Combo	Rm20	1 of 1	Water Fountain	right	<1
45	394380	Unit B - Classrooms	Fountain/Tap Combo	Rm3	1 of 1	Water Fountain	right	<1
46	394382	Unit B - Classrooms	Fountain/Tap Combo	Rm2	1 of 1	Water Fountain	right	<1
47	394384	Unit B - Classrooms	Fountain/Tap Combo	Rm1	1 of 1	Water Fountain	right	<1
48	394386	Unit B - Classrooms	Fountain/Tap Combo	11-15 Pod	1 of 1	Water Fountain	right	<1
49	394388	Unit B - Classrooms	Fountain/Tap Combo	Rm11	1 of 1	Water Fountain	right	<1
50	394390	Unit B - Classrooms	Fountain/Tap Combo	Rm12	1 of 1	Water Fountain	right	<1
51	394392	Unit B - Classrooms	Fountain/Tap Combo	Rm13	1 of 1	Water Fountain	right	<1
52	394395	Unit B - Classrooms	Fountain/Tap Combo	Rm15	1 of 1	Tap	left	<1
53	394396	Unit B - Classrooms	Fountain/Tap Combo	Rm15	1 of 1	Water Fountain	right	<1
54	394398	Unit C - Classrooms	Fountain/Tap Combo	16-20 Pod	1 of 1	Water Fountain	right	<1