DEXTER COMMUNITY SCHOOLS
Craig McCalla, Principal for Operations
2704 Baker Road, Dexter, Michigan 48130
(734) 424-4100 ext. 1344 fax (734) 424-4108
mccallac@dexterschools.org

PRE-BID MEETING QUESTIONS AND ANSWERS

PROJECT: Al Ritt Scoreboard Power RFP

OWNER: Dexter Community Schools

DATE: April 25, 2025

BID DUE DATE: May 5th, 2025 (unchanged)

Questions or follow up comments:
Can we direct bore rather than trench? - Yes

Can we direct bore under the track? - No

There are required handholds. Can an alternate be given for the type of handheld boxes we use? - Yes

Using a #6 wire is close to the voltage drop for the distance required. Would you rather us bid a #4 wire? - In the main bid use #6 wire and companies can give an alternate for using #4 wire.

We would recommend using a 2” conduit for the wire. Should this be in the original bid or as an alternate? - Follow what the specs call and companies can give an alternate for using 2” conduit.