

CPE - Water Testing Results

Result Line number	Sample Order Number	ICOS Building Name	Physical Building Name	Fixture Location	 Fixture Type	Result - Entered manually, check DOH report.
1	4	Unit B - Admin	Bldg A	Library work room	Sink faucet	28
2	8	Unit C - Classroom	Bldg G	Hall near Rms 20, 21, 22	Sink faucet	22
3	50	Unit F - Music	Bldg B	Classroom 1	Sink faucet	18
4	15	Unit C - Classroom	Bldg G	Hall near Rms 23, 24, 25	Sink faucet	17
5	30	Unit D - Classroom	Bldg E	Hall near Rms 14, 15, 16	Sink faucet	16
6	5	Unit A Gym	Bldg F	Kitchen	Sink faucet	13
7	52	Unit E - Classroom	Bldg C	Hall near Rms 5, 6, 7	Sink faucet	12
8	55	Unit E - Classroom	Bldg C	Classroom 6	Sink faucet	10
9	1	Unit B - Admin	Bldg A	Health Room	Sink faucet	9
10	33	Unit D - Classroom	Bldg E	Classroom 15	Sink faucet	9
11	17	Unit C - Classroom	Bldg G	Classroom 23	Sink faucet	9
12	19	Unit C - Classroom	Bldg G	Classroom 24	Sink faucet	9
13	26	Unit D - Classroom	Bldg E	Classroom 18	Sink faucet	9
14	64	Unit E - Classroom	Bldg C	Classroom 4	Sink faucet	9
15	47	Unit B - Admin	Bldg A	Classroom 9	Water fountain	8
16	11	Unit C - Classroom	Bldg G	Classroom 21	Sink faucet	8
17	21	Unit C - Classroom	Bldg G	Classroom 25	Sink faucet	8
18	23	Unit D - Classroom	Bldg E	Hall near Rms 17, 18, 19	Sink faucet	8
19	13	Unit C - Classroom	Bldg G	Classroom 22	Sink faucet	7
20	20	Unit C - Classroom	Bldg G	Classroom 24	Water fountain	7
21	53	Unit E - Classroom	Bldg C	Classroom 5	Sink faucet	7
22	34	Unit D - Classroom	Bldg E	Classroom 15	Water fountain	6
23	57	Unit E - Classroom	Bldg C	Classroom 7	Sink faucet	6
24	58	Unit E - Classroom	Bldg C	Classroom 7	Water fountain	6

CPE - Water Testing Results

Result Line number	Sample Order Number	ICOS Building Name	Physical Building Name	Fixture Location	 Fixture Type	Result - Entered manually, check DOH report.
25	59	Unit E - Classroom	Bldg C	Hall near Rms 2, 3, 4	Sink faucet	6
26	35	Unit D - Classroom	Bldg E	Classroom 16	Sink faucet	5
27	48	Unit B - Admin	Bldg A	Classroom 8	Sink faucet	5
28	12	Unit C - Classroom	Bldg G	Classroom 21	Water fountain	5
29	16	Unit C - Classroom	Bldg G	Hall near Rms 23, 24, 25	Water fountain	5
30	24	Unit D - Classroom	Bldg E	Classroom 17	Sink faucet	5
31	54	Unit E - Classroom	Bldg C	Classroom 5	Water fountain	5
32	60	Unit E - Classroom	Bldg C	Classroom 2	Sink faucet	5
33	62	Unit E - Classroom	Bldg C	Classroom 3	Sink faucet	5
34	9	Unit C - Classroom	Bldg G	Classroom 20	Sink faucet	4
35	43	Unit G - Kindergarten Addition	Bldg D	Classroom 13	Sink faucet	4
36	22	Unit C - Classroom	Bldg G	Classroom 25	Water fountain	4
37	56	Unit E - Classroom	Bldg C	Classroom 6	Water fountain	4
38	65	Unit E - Classroom	Bldg C	Classroom 4	Water fountain	4
39	31	Unit D - Classroom	Bldg E	Classroom 14	Sink faucet	3
40	39	Unit G - Kindergarten Addition	Bldg D	Classroom 11	Sink faucet	3
41	41	Unit G - Kindergarten Addition	Bldg D	Classroom 12	Sink faucet	3
42	46	Unit B - Admin	Bldg A	Classroom 9	Sink faucet	3
43	49	Unit B - Admin	Bldg A	Classroom 8	Water fountain	3
44	27	Unit D - Classroom	Bldg E	Classroom 18	Water fountain	3
45	51	Unit F - Music	Bldg B	Classroom 1	Water fountain	3
46	3	Unit B - Admin	Bldg A	staff lounge	Water fountain	2
47	36	Unit D - Classroom	Bldg E	Classroom 16	Water fountain	2
48	42	Unit G - Kindergarten Addition	Bldg D	Classroom 12	Water fountain	2

CPE - Water Testing Results

Result Line number	Sample Order Number	ICOS Building Name	Physical Building Name	Fixture Location	 Fixture Type	Result - Entered manually, check DOH report.
49	45	Unit G - Kindergarten Addition	Bldg D	Classroom 10	Sink faucet	2
50	10	Unit C - Classroom	Bldg G	Classroom 20	Water fountain	2
51	18	Unit C - Classroom	Bldg G	Classroom 23	Water fountain	2
52	25	Unit D - Classroom	Bldg E	Classroom 17	Water fountain	2
53	28	Unit D - Classroom	Bldg E	Classroom 19	Sink faucet	2
54	32	Unit D - Classroom	Bldg E	Classroom 14	Water fountain	1
55	40	Unit G - Kindergarten Addition	Bldg D	Classroom 11	Water fountain	1
56	14	Unit C - Classroom	Bldg G	Classroom 22	Water fountain	1
57	29	Unit D - Classroom	Bldg E	Classroom 19	Water fountain	1
58	63	Unit E - Classroom	Bldg C	Classroom 3	Water fountain	1
59	2	Unit B - Admin	Bldg A	Health Room	Water fountain	<1
60	6	Unit A Gym	Bldg F	Gym lobby	Water fountain	<1
61	7	Unit A Gym	Bldg F	Gym lobby	Bottle filler	<1
62	38	Unit G - Kindergarten Addition	Bldg D	Hall near Rms 10, 11, 12, 13	Water fountain	<1
63	44	Unit G - Kindergarten Addition	Bldg D	Classroom 13	Water fountain	<1
64	61	Unit E - Classroom	Bldg C	Classroom 2	Water fountain	<1
Off - Not sampled	37	Unit G - Kindergarten Addition	Bldg D	Classroom 10	Water fountain	--