

DOH Result Line Number	Sample Order Number	ICOS Building Name	Site Map Building Name	Fixture Location	 Fixture Type	Result - Entered manually, check DOH report
1	20	Bldg B	Main Building	Unit 900 (Between Rms 901 & 905)	Water fountain	34
2	4	Bldg F	Main Building	Rm 417	Sink faucet	14
3	13	Bldg A	Main Building	Rm 105	Water fountain	13
4	61	Bldg E	Main Building	Rm 501	Sink faucet	13
5	29	Bldg E	Main Building	Unit 800 (across from Rm 801)	Water fountain	12
6	63	Bldg E	Main Building	Rm 502	Sink faucet	11
7	11	Bldg A	Main Building	Unit 100 (Between Rms 105 & 105)	Water fountain	9
8	15	Bldg A	Main Building	Rm 101	Water fountain	9
9	52	Bldg E	Main Building	Rm 603	Sink faucet	9
10	8	Bldg F	Main Building	hall Library	Water fountain	8
11	65	Bldg E	Main Building	Rm 503	Sink faucet	8
12	30	Bldg E	Main Building	Rm 801	Sink faucet	8
13	40	Bldg E	Main Building	Rm 702	Sink faucet	8
14	9	Bldg F	Main Building	Rm 211	Sink faucet	7
15	34	Bldg E	Main Building	Rm 803	Sink faucet	7
16	38	Bldg E	Main Building	Rm 701	Sink faucet	7
17	25	Bldg B	Main Building	Rm 907	Sink faucet	6
18	48	Bldg E	Main Building	Rm 602	Sink faucet	6
19	60	Bldg E	Main Building	Unit 500 (across from Rm 501)	Water fountain	6
20	64	Bldg E	Main Building	Rm 502	Water fountain	6
21	46	Bldg E	Main Building	Rm 601	Sink faucet	6
22	12	Bldg A	Main Building	Rm 105	Sink faucet	5
23	16	Bldg A	Main Building	Rm 106	Sink faucet	5

DOH Result Line Number	Sample Order Number	ICOS Building Name	Site Map Building Name	Fixture Location	 Fixture Type	Result - Entered manually, check DOH report
24	42	Bldg E	Main Building	Rm 703	Sink faucet	5
25	17	Bldg A	Main Building	Rm 106	Water fountain	4
26	23	Bldg B	Main Building	Rm 905	Sink faucet	4
27	49	Bldg E	Main Building	Rm 602	Water fountain	4
28	58	Bldg F	Main Building	Staff lounge 304	Sink faucet	4
29	5	Bldg F	Main Building	Rm 417	Water fountain	4
30	37	Bldg E	Main Building	Unit 700 (across from 701)	Water fountain	4
31	10	Bldg F	Main Building	Rm 211	Water fountain	3
32	14	Bldg A	Main Building	Rm 101	Sink faucet	3
33	18	Bldg A	Main Building	Rm 110	Sink faucet	3
34	19	Bldg A	Main Building	Rm 110	Water fountain	3
35	62	Bldg E	Main Building	Rm 501	Water fountain	3
36	--	Bldg D	Main Building	Kitchen (3 compartment sink - Labeled)	Sink faucet	3
37	27	Bldg B	Main Building	Rm 911	Sink faucet	3
38	31	Bldg E	Main Building	Rm 801	Water fountain	3
39	32	Bldg E	Main Building	Rm 802	Sink faucet	3
40	44	Bldg F	Main Building	Rm 704	Sink faucet	3
41	21	Bldg B	Main Building	Rm 901	Sink faucet	2
42	22	Bldg B	Main Building	Rm 901	Water fountain	2
43	24	Bldg B	Main Building	Rm 905	Water fountain	2
44	26	Bldg B	Main Building	Rm 907	Water fountain	2
45	51	Bldg F	Main Building	Rm 604	Water fountain	2
46	59	Bldg F	Main Building	Rm 506	Sink faucet	2

DOH Result Line Number	Sample Order Number	ICOS Building Name	Site Map Building Name	Fixture Location	 Fixture Type	Result - Entered manually, check DOH report
47	66	Bldg E	Main Building	Rm 503	Water fountain	2
48	1	Bldg D	Main Building	Kitchen (near dish machine)	Sink faucet sprayer	2
49	28	Bldg B	Main Building	Rm 911	Water fountain	2
50	33	Bldg E	Main Building	Rm 802	Water fountain	2
51	35	Bldg E	Main Building	Rm 803	Water fountain	2
52	41	Bldg E	Main Building	Rm 702	Water fountain	2
53	43	Bldg E	Main Building	Rm 703	Water fountain	2
54	50	Bldg F	Main Building	Rm 604	Sink faucet	1
55	53	Bldg E	Main Building	Rm 603	Water fountain	1
56	55	Bldg G	Gym	Gym (Left to right, 2 of 4)	Water fountain	1
57	2	Bldg D	Main Building	Commons	Water fountain	1
58	39	Bldg E	Main Building	Rm 701	Water fountain	1
59	45	Bldg F	Main Building	Rm 704	Water fountain	1
60	7	Bldg F	Main Building	Rm 306 - inside lib	Sink faucet	<1
61	47	Bldg E	Main Building	Rm 601	Water fountain	<1
62	54	Bldg G	Gym	Gym (Left to right, 1 of 4)	Water fountain	<1
63	56	Bldg G	Gym	Gym (left to right, 3 of 4)	Water fountain	<1
64	57	Bldg G	Gym	Gym (left to right, 4 of 4)	Water fountain	<1
65	3	Bldg D	Main Building	Commons	Bottle filler	<1
66	6	Bldg F	Main Building	main office	Water fountain	<1
67	36	Bldg F	Main Building	Hall 312	Water fountain	<1
Off - Not sampled	--	Bldg F	Main Building	Rm 215	Sink faucet	<1
Off - Not sampled	--	Bldg F	Main Building	Rm 215	Water fountain	<1