



2/4 – Friday 2/7 due to 4 kits missing or tampered with by students. The 4 additional areas resampled all came back below 4 picocuries per liter.

- Indoor Air Quality Walkthroughs 1/22 – 1/24, 1/27 – 1/28
  - IEA conducted annual IAQ assessment of all rooms and offices in the district to measure different IAQ parameters (Temperature, Humidity, CO, CO<sub>2</sub>) and observe any moisture issues. These measurements and observations help the district identify any ventilation issues and concerns. We identified no major concerns. We had more rooms with elevated (1200 ppm) CO<sub>2</sub> levels and exceeding the recommended temperature range (68-75 degrees) than in past years. Jason Bichler and Rick Aulwes are working on corrections with the district HVAC controller.
- HS Science Pod, Art Pod, and Business Pod
  - Security will be increased for these pod areas within the High School. The work will be completed in the summer. The security improvements will include fire doors to pods will be tied into the fire/emergency buttons through magnetic release. Further down the road we will explore options for the glass on these doors. The LTFM budget went to the board this past Monday and was approved. The work will begin after July 1<sup>st</sup>.
- Playground Repairs - Update
  - 90% of repairs were completed over spring break. Fieldstone and Community Ed have a few repairs to be completed over the summer.
- MedCompass Scheduling (Respirator Fit-Testing and Hearing Tests)
  - Medcompass will be on-site Wednesday 4/9 to conduct respirator fit-testing (for authorized respirator users) and annual audiograms (employees on the district's Hearing Conservation program). Respirator Fit-Testing is required for custodian staff that clean boilers and hearing tests (audiograms) are for Grounds and HS Choir.
- Big Woods Parking Lot Improvements – Summer 2025
  - Budgeting for the improvements was approved. The front and back parking lots will be completed. The district received 10-11 contractor sealed bids. The board has approved the contractor bid.
- Middle School East Door Lettering - Update
  - The indoor letters were installed over winter break. The exterior letters were installed over spring break. This will help Emergency Personnel navigate all schools for a quicker response time.
- Security & Safety Visits
  - The district has partnered with Homeland Security to walkthrough district buildings to discuss building security. The district is in process on scheduling the Elementary walkthroughs.

## New Business

- Mock OSHA Inspection (HS, BW) 3/10
  - This inspection occurs annually with schools being on a rotation to be completed. Violations identified during the walkthrough include: OSHA 300A Form not posted (required OSHA posting from 2/1 – 4/30), machine guarding concerns, fall protection concerns (platforms not having proper guardrails/midrails), non-functioning automatic reverse mechanism on garage doors, improper chemical labeling, and first aid kits with expired supplies.
- End of Year Hazardous Waste Disposal
  - Email will be sent out to various departments in May to take a look at their inventory of chemicals and determine if they want any of them to be disposed. We will have a hazardous waste pick-up this summer to take out the chemicals in storage in the MSW warehouse.
- Fire Marshal Reports
  - The walkthroughs occurred the week before and the week of spring break. These occur every 3 years and this was with a new fire marshal. The overall findings were a lot less than past reports. The district is currently working on corrections identified in the report.
- Flooring Improvements on Pool Deck and Locker Room
  - The floors were re-epoxied and coated with non-slip grit. There are concerns with the floor being too slippery. The district is having the contractor come out to add another coat of non-slip grit.

## Open Discussion

None

**If you have health and safety questions or suggestions – feel free to contact your buildings safety committee representative!**

**This is the last meeting of the school year. Enjoy the summer! We hope you join us next fall!**

**Next Meeting: TBD**

**Location: TBD**

**Time: TBD**