

Iroquois Middle School

Sample Number		Location	Fixture Type	Detail	Date	Time	Result (mg/L)	Result (ug/L)
IM	10R	Room 036	Sink	Dishwasher double left sink	3/17/2025	0611	4.78	4780
IM	12R	Room 036	Sprayer	Dishwasher sprayer	3/17/2025	0613	0.0013	1.3
IM	13R	Room 041	Sink	Front Left	3/17/2025	0616	0.0071	7.1
IM	14R	Room 041	Sink	Front Right	3/17/2025	0616	0.0089	8.9
IM	25R	Room 316	Sink	Left	3/17/2025	0625	0.0048	4.8

Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-01
 Client ID: IM-10R-ROOM 036, KITCHEN-SINK-
 Sample Location: DISHWASH DOUBLE LEFT
 Not Specified

Date Collected: 03/17/25 06:11
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	4.780		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 20:42	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-02
 Client ID: IM-12R-ROOM 036, KITCHEN-SPRAYER-
 Sample Location: DISHWASHER SPRAYE
 Not Specified

Date Collected: 03/17/25 06:13
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0013		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 21:11	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-03
 Client ID: IM-13R-ROOM 041, ART ROOM-SINK-
 Sample Location: FRONT LEFT
 Not Specified

Date Collected: 03/17/25 06:16
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0071		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 21:16	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-04
 Client ID: IM-14R-ROOM 041, ART ROOM-SINK-
 Sample Location: FRONT RIGHT
 Not Specified

Date Collected: 03/17/25 06:16
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.00890		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 23:05	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-05
 Client ID: IM-25R-ROOM 312, CLASSROOM-SINK-
 Sample Location: LEFT SINK
 Not Specified

Date Collected: 03/17/25 06:25
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0048		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 23:10	NA	3,200.8	BLR



Irondequoit High School

Sample Number		Location	Fixture Type	Detail	Date	Time	Result (mg/L)	Result (ug/L)
IH	1R	Room 1000	Sink		3/17/2025	0510	0.0071	7.10
IH	4R	Room 1010	Sink	Left of rear exit door	3/17/2025	0512	0.0222	22.20
IH	13R	Room 1030	Sink	Double sink under ansul unit	3/17/2025	0515	0.1579	157.90
IH	17R	Room 1030	Sink	Near locker room 1032	3/17/2025	0516	0.0107	10.70
IH	18R	Room 1030	Pot Filler	Right of Gas Stove	3/17/2025	0518	0.0253	25.30
IH	19R	Room 1030	Pot Filler	Right of Gas Stove	3/17/2025	0519	0.0091	9.10
IH	22R	Room 1030	Pot Filler	Right of ovens	3/17/2025	0521	0.0039	3.90
IH	24R	Room 1032	Sink	Left	3/17/2025	0524	0.0041	4.10
IH	27R	Room 1039	Sink	Serving line	3/17/2025	0526	0.0065	6.50
IH	33R	Room 1071	Sink		3/17/2025	0529	0.0175	17.50
IH	55-BR	Room 2004	Sink		3/17/2025	0534	0.0049	4.90
IH	56R	Room 2021	Drinking Fountain	Next to 2021	3/17/2025	0535	0.0263	26.30
IH	67R	Room 3031	Sink		3/17/2025	0538	0.0543	54.30
IH	68R	Room 3032	Sink		3/17/2025	0539	0.0096	9.60
IH	69R	Room 3033	Drinking Fountain	across from 3033	3/17/2025	0540	0.062	62.00

Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-06
 Client ID: IH-01R-ROOM 1000, CLASSROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/17/25 05:10
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0071		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 23:15	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-07
 Client ID: IH-04R-ROOM 1010, CLASSROOM-SINK-
 Sample Location: LEFT OF THE EXIT
 Not Specified

Date Collected: 03/17/25 05:12
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0222		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 23:29	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-08
 Client ID: IH-13R-ROOM 1030-5, KITCHEN-SINK-
 Sample Location: UNDER ANSUL SYSTE
 Not Specified

Date Collected: 03/17/25 05:15
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.1579		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 23:34	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-09
 Client ID: IH-17R-ROOM 1030-9, KITCHEN-SINK-
 Sample Location: NEAR LOCKER ROOM
 Not Specified

Date Collected: 03/17/25 05:16
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0107		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 23:39	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-10
 Client ID: IH-18R-ROOM 1030-10, KITCHEN-POT
 Sample Location: FILLER-RIGHT OF G
 Not Specified

Date Collected: 03/17/25 05:18
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0253		mg/l	0.0010	0.0003	1	03/26/25 10:25	03/26/25 17:46	EPA 3005A	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-11
 Client ID: IH-19R-ROOM 1030-11, KITCHEN-POT
 Sample Location: FILLER-RIGHT OF G
 Not Specified

Date Collected: 03/17/25 05:19
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0091		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 20:57	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-12
 Client ID: IH-22R-ROOM 1030-13, KITCHEN-POT
 Sample Location: FILLER-RIGHT OF G
 Not Specified

Date Collected: 03/17/25 05:21
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0039		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 23:44	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-13
 Client ID: IH-24R-ROOM 1032, KITCHEN-SINK-
 Sample Location: LOCKER ROOM
 Not Specified

Date Collected: 03/17/25 05:24
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0041		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 23:49	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-14
 Client ID: IH-27R-ROOM 1039, KITCHEN-SINK-
 Sample Location: SERVING LINE
 Not Specified

Date Collected: 03/17/25 05:26
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0065		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 23:53	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-15
 Client ID: IH-33R-ROOM 1071, CLASSROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/17/25 05:29
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0175		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 23:58	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-16
 Client ID: IH-55-BR-ROOM 2004, OFFICE-SINK
 Sample Location: Not Specified

Date Collected: 03/17/25 05:34
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0049		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 19:48	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-17
 Client ID: IH-56R-HALLWAY BY ROOM 2021-
 Sample Location: DRINKING FOUNTAIN-NEXT
 Not Specified

Date Collected: 03/17/25 05:35
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0263		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 19:52	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-18
 Client ID: IH-67R-ROOM 3031, CLASSROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/17/25 05:38
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0543		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 19:57	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-19
 Client ID: IH-68R-ROOM 3032, CLASSROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/17/25 05:39
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0096		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 20:02	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-20
 Client ID: IH-69R-HALLWAY BY ROOM 3033-
 Sample Location: DRINKING FOUNTAIN-ACRO
 Not Specified

Date Collected: 03/17/25 05:40
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0620		mg/l	0.0010	0.0003	1	03/25/25 16:24	03/25/25 20:07	NA	3,200.8	BLR



Dake Junior High School

Sample Number		Location	Fixture Type	Detail	Date	Time	Result (mg/L)	Result (ug/L)
DJ	6R	Room 133	Sink	Back wall left sink	3/17/2025	0548	0.021	21.00
DJ	7R	Room 133	Sink	Back wall right sink	3/17/2025	0549	0.0077	7.70
DJ	8R	Room 133	Sink	Right Wall left sink	3/17/2025	0549	0.0619	61.90
DJ	20R	Room 170	Sink	Left double sink	3/18/2025	0505	0.0654	65.40
DJ	26R	Room 170	Pot Filler		3/17/2025	0554	0.0448	44.80
DJ	27R	Room 170	Sprayer	Convotherm sprayer	3/17/2025	0555	0.008	8.00

Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-21
 Client ID: DJ-06R-ROOM 133-1, CLASSROOM-
 Sample Location: SINK-BACK WALL LEFT
 Not Specified

Date Collected: 03/17/25 05:48
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0210		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 21:33	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-22
 Client ID: DJ-07R-ROOM 133-2, CLASSROOM-
 Sample Location: SINK-BACK WALL RIGHT
 Not Specified

Date Collected: 03/17/25 05:49
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0077		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:05	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-23
 Client ID: DJ-08R-ROOM 133-3, CLASSROOM-
 Sample Location: SINK-RIGHT WALL LEFT
 Not Specified

Date Collected: 03/17/25 05:49
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0619		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:09	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-24
 Client ID: DJ-26R-ROOM 170-7, KITCHEN-POT
 Sample Location: FILLER
 Not Specified

Date Collected: 03/17/25 05:54
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0448		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:20	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-25
 Client ID: DJ-27R-ROOM 170-6, KITCHEN-
 Sample Location: SPRAYER
 Not Specified

Date Collected: 03/17/25 05:55
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0080		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:24	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-29
 Client ID: DJ-20R-ROOM 170-1, KITCHEN-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 05:05
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0654		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:39	NA	3,200.8	BLR



Seneca Elementary School

Sample Number		Location	Fixture Type	Detail	Date	Time	Result (mg/L)	Result (ug/L)
SI	8R	Room 002	Sink		3/17/2025	0639	0.0047	4.70
SI	9R	Room 106	Sink		3/17/2025	0634	0.0105	10.50
SI	17R	Room 121	Sink		3/17/2025	0635	0.0654	65.40

Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-26
 Client ID: SI-08R-ROOM 002, FACULTY ROOM-
 Sample Location: SINK
 Not Specified

Date Collected: 03/17/25 06:39
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0047		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:28	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-27
 Client ID: SI-09R-ROOM 106, NURSE OFFICE-SINK
 Sample Location: Not Specified

Date Collected: 03/17/25 06:34
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0083		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:32	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-28
 Client ID: SI-17R-ROOM 121, CLASSROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/17/25 06:35
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0105		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:35	NA	3,200.8	BLR



Oakview (Sunshine Daycare)

Sample Number		Location	Fixture Type	Detail	Date	Time	Result (mg/L)	Result (ug/L)
OV	1R	Room 5, Staff Room Sink	Sink		3/18/2025	0626	0.0101	10.10

Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-30
 Client ID: OV-01R-ROOM 5, STAFF ROOM SINK-
 Sample Location: SINK
 Not Specified
 Sample Depth:
 Matrix: Dw

Date Collected: 03/18/25 06:26
 Date Received: 03/18/25
 Field Prep: Not Specified

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0101		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:43	NA	3,200.8	BLR



Rogers Middle School

Sample Number		Location	Fixture Type	Detail	Date	Time	Result (mg/L)	Result (ug/L)
RM	01R	Room 007, Classroom	Sink		3/18/2025	0520	0.0048	4.80
RM	09R	Room 012, Classroom	Sink		3/18/2025	0524	0.0625	62.50
RM	13R	Room 138, Bathroom	Sink		3/18/2025	0553	0.0121	12.10
RM	14R	Room 142, Kitchen	Pot Filler		3/18/2025	0515	0.0102	10.20
RM	15R	Room 142, Kitchen	Sink	Center Island handwash	3/18/2025	0516	0.0171	17.10
RM	19R	Room 142, Kitchen	Sprayer	Dishwash Sprayer	3/18/2025	0517	0.0548	54.80
RM	29R	Room 120, Classroom	Sink		3/18/2025	0540	0.0154	15.40
RM	30R	Room 310, Classroom	Sink		3/18/2025	0547	0.0169	16.90
RM	31R	Room 312, Classroom	Sink	Right	3/18/2025	0546	0.0172	17.20
RM	39R	Room 319, Classroom	Sink		3/18/2025	0557	0.0119	11.90
RM	43R	Room 124, Gym	Drinking Fountain	N Side of Gym	3/18/2025	0533	0.0082	8.20

Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-31
 Client ID: RM-01R-ROOM 007, CLASSROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 05:20
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0048		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 21:44	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-32
 Client ID: RM-09R-ROOM 012, CLASSROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 05:24
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0625		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:46	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-33
 Client ID: RM-13R-ROOM 138, BATHROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 05:53
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0121		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:50	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-34
 Client ID: RM-14R-ROOM 142, KITCHEN-POT
 Sample Location: FILLER
 Not Specified
 Sample Depth:
 Matrix: Dw

Date Collected: 03/18/25 05:15
 Date Received: 03/18/25
 Field Prep: Not Specified

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0102		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 22:54	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-35
 Client ID: RM-15R-ROOM 142, KITCHEN-SINK-
 Sample Location: CENTER ISLAND HANDWA
 Not Specified

Date Collected: 03/18/25 05:16
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0171		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 23:05	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-36
 Client ID: RM-19R-ROOM 142, KITCHEN-
 Sample Location: SPRAYER-DISHWASH SPRAYER
 Not Specified
 Sample Depth:
 Matrix: Dw

Date Collected: 03/18/25 05:17
 Date Received: 03/18/25
 Field Prep: Not Specified

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0548		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 23:09	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-37
 Client ID: RM-29R-ROOM 120, CLASSROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 05:40
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0154		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 23:13	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-38
 Client ID: RM-30R-ROOM 310, CLASSROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 05:47
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0169		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 23:16	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-39
 Client ID: RM-31R-ROOM 312, CLASSROOM-SINK-
 Sample Location: RIGHT
 Not Specified

Date Collected: 03/18/25 05:46
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0172		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 23:20	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-40
 Client ID: RM-39R-ROOM 319, CLASSROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 05:57
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0119		mg/l	0.0010	0.0003	1	03/25/25 18:10	03/25/25 23:24	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-41
 Client ID: RM-43R-ROOM 124, GYM-DRINKING
 Sample Location: FOUNTAIN-N SIDE OF G
 Not Specified

Date Collected: 03/18/25 05:33
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0082		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 13:24	NA	3,200.8	BLR



Southlawn Elementary School

Sample Number		Location	Fixture Type	Detail	Date	Time	Result (mg/L)	Result (ug/L)
SL	13R	Room 166, Classroom	Sink		3/18/2025	529	0.0017	1.70

Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-42
 Client ID: SL-13R-ROOM 166, CLASSROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 05:29
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0017		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 14:27	NA	3,200.8	BLR



Evans McGraw Learning Center

Sample Number		Location	Fixture Type	Detail	Date	Time	Result (mg/L)	Result (ug/L)
EM	04R	Room 114, Tutoring Center	Sink		3/18/2025	613	0.0402	40.20

Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-43
 Client ID: EM-04R-ROOM 114, TUTORING CENTER-
 Sample Location: SINK
 Not Specified

Date Collected: 03/18/25 06:13
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0402		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 14:31	NA	3,200.8	BLR



Pinegrove Building

Sample Number		Location	Fixture Type	Detail	Date	Time	Result (mg/L)	Result (ug/L)
PG	08R	Room 128, Bathroom	Sink		3/18/2025	0640	0.0087	8.70
PG	09R	Room 129, Bathroom	Sink		3/18/2025	0641	0.0108	10.80
PG	10R	Room 130, Classroom	Sink	HNC	3/18/2025	0643	0.0048	4.80
PG	16R	Room 109, Bathroom	Sink	Left Sink	3/18/2025	0645	0.0064	6.40
PG	18R	Room 106, Bathroom	Sink		3/18/2025	0650	0.0322	32.20
PG	19R	Room 142, Bathroom	Sink		3/18/2025	0651	0.0293	29.30
PG	20R	Room 143, Bathroom	Sink		3/18/2025	0652	0.0174	17.40
PG	21R	Room 141, Workspace	Sink		3/18/2025	0653	0.0225	22.50

Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-44
 Client ID: PG-08R-ROOM 128, BATHROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 06:40
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0087		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 14:35	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-45
 Client ID: PG-09R-ROOM 129, BATHROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 06:41
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0108		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 14:40	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-46
 Client ID: PG-10R-ROOM 130, CLASSROOM-SINK-
 Sample Location: HNC
 Not Specified

Date Collected: 03/18/25 06:43
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0048		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 14:44	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-47
 Client ID: PG-16R-ROOM 109, BATHROOM-SINK-
 Sample Location: LEFT SINK
 Not Specified

Date Collected: 03/18/25 06:45
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0064		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 15:11	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-48
 Client ID: PG-18R-ROOM 106, BATHROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 06:50
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0322		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 15:17	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-49
 Client ID: PG-19R-ROOM 142, BATHROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 06:51
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0293		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 15:21	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-50
 Client ID: PG-20R-ROOM 143, BATHROOM-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 06:52
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0174		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 15:26	NA	3,200.8	BLR



Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-51
 Client ID: PG-21R-ROOM 141, WORKSPACE-SINK
 Sample Location: Not Specified

Date Collected: 03/18/25 06:53
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0225		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 13:47	NA	3,200.8	BLR



Environmental Services

Sample Number		Location	Fixture Type	Detail	Date	Time	Result (ug/L)	Result (ug/L)
ES	07R	Service Bay	Sink	Matt's Area	3/18/2025	0705	0.0107	10.7

Project Name: WEST IRONDEQUOIT CSD LIDW TEST
Project Number: 2244674.01

Lab Number: L2515417
Report Date: 03/27/25

SAMPLE RESULTS

Lab ID: L2515417-52
 Client ID: ES-07R-SERVICE BAY-SINK-MATT'S
 Sample Location: AREA
 Not Specified

Date Collected: 03/18/25 07:05
 Date Received: 03/18/25
 Field Prep: Not Specified

Sample Depth:
 Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0107		mg/l	0.0010	0.0003	1	03/27/25 12:30	03/27/25 15:30	NA	3,200.8	BLR

