Technical Report

prepared for:

QuES & T
1376 Rt. 9
Wappingers Falls NY, 12590
Attention: Zachary P. Timpano

Report Date: 04/22/2025
Client Project ID: 256663 Rye Neck UFSD- FEB 1/Athletic
York Project (SDG) No.: 25D0950

Stratford, CT Laboratory IDs:
NY:10854, NJ: CT005, PA: 68-0440, CT: PH-0723

Richmond Hill, NY Laboratory IDs:
NY:12058, NJ: NY037, CT: PH-0721, NH: 2097,
EPA: NY01600

120 RESEARCH DRIVE STRATFORD, CT 06615 ■ 132-02 89th AVENUE RICHMOND HILL, NY 11418
www.YORKLAB.com (203) 325-1371 FAX (203) 357-0166 ClientServices@yorklab.com

Report Date: 04/22/2025
Client Project ID: 256663 Rye Neck UFSD- FEB 1/Athletic
York Project (SDG) No.: 25D0950

QuES & T
1376 Rt. 9
Wappingers Falls NY, 12590
Attention: Zachary P. Timpano

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on April 15, 2025 and listed below. The project was identified as your project: **256663 Rye Neck UFSD- FEB 1/Athletic**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

York Sample ID	Client Sample ID	Matrix	Date Collected	Date Received
25D0950-01	6663-A-01-Vestibule WF	Drinking Water	04/12/2025	04/15/2025
25D0950-02	6663-A-02-Vestibule WF Bottle Fill	Drinking Water	04/12/2025	04/15/2025
25D0950-03	6663-A-03 Right WF	Drinking Water	04/12/2025	04/15/2025
25D0950-04	6663-A-04 Right WF Bottle Fill	Drinking Water	04/12/2025	04/15/2025
25D0950-05	6663-A-05 Boy's Locker Room Left	Drinking Water	04/12/2025	04/15/2025
25D0950-06	6663-A-06 Boy's Locker Room Center	Drinking Water	04/12/2025	04/15/2025
25D0950-07	6663-A-07 Boy's Locker Room Right	Drinking Water	04/12/2025	04/15/2025
25D0950-08	6663-A-08 Girls Locker Room Left	Drinking Water	04/12/2025	04/15/2025
25D0950-09	6663-A-09 Girls Locker Room Center	Drinking Water	04/12/2025	04/15/2025
25D0950-10	6663-A-10 Girls Locker Room Right	Drinking Water	04/12/2025	04/15/2025
25D0950-11	6663-A-11 Gender Neutral	Drinking Water	04/12/2025	04/15/2025
25D0950-12	6663-A-12 Girl's Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0950-13	6663-A-13 Girl's Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0950-14	6663-A-14 Boy's Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0950-15	6663-A-15 Boy's Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0950-16	6663-A-16 Water Fountain	Drinking Water	04/12/2025	04/15/2025
25D0950-17	6663-A-17 Bottle Filler	Drinking Water	04/12/2025	04/15/2025
25D0950-18	6663-A-18 Girl's Bathroom Left 1	Drinking Water	04/12/2025	04/15/2025
25D0950-19	6663-A-19 Girl's Bathroom Right 1	Drinking Water	04/12/2025	04/15/2025
25D0950-20	6663-A-20 Girl's Bathroom Left 2	Drinking Water	04/12/2025	04/15/2025
25D0950-21	6663-A-21 Girl's Bathroom Right 2	Drinking Water	04/12/2025	04/15/2025
25D0950-22	6663-A-22 Boy's Bathroom Left 1	Drinking Water	04/12/2025	04/15/2025

York Sample ID	Client Sample ID	Matrix	Date Collected	Date Received
25D0950-23	6663-A-23 Boy's Bathroom Right 1	Drinking Water	04/12/2025	04/15/2025
25D0950-24	6663-A-24 Boy's Bathroom Left 2	Drinking Water	04/12/2025	04/15/2025
25D0950-25	6663-A-25 Boy's Bathroom Right 2	Drinking Water	04/12/2025	04/15/2025
25D0950-26	6663-A-26 Coach's Bathroom Sink	Drinking Water	04/12/2025	04/15/2025
25D0950-27	6663-FEB-27 Main Floor Water Fountain	Drinking Water	04/12/2025	04/15/2025
25D0950-28	6663-FEB-28 Main Floor WF Bottle Fill	Drinking Water	04/12/2025	04/15/2025
25D0950-29	6663-FEB-29 Boy's Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0950-30	6663-FEB-30 Boy's Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0950-31	6663-FEB-31 Girl's Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0950-32	6663-FEB-32 Girl's Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0950-33	6663-FEB-33 Nurse's Bathroom	Drinking Water	04/12/2025	04/15/2025
25D0950-34	6663-FEB-34 Nurse's Sink	Drinking Water	04/12/2025	04/15/2025
25D0950-35	6663-FEB-35 Dada Coordinator's Office	Drinking Water	04/12/2025	04/15/2025
25D0950-36	6663-FEB-36 3AC/EL Sink	Drinking Water	04/12/2025	04/15/2025
25D0950-37	6663-FEB-37 3FK Sink	Drinking Water	04/12/2025	04/15/2025
25D0950-38	6663-FEB-38 Room 207 Sink	Drinking Water	04/12/2025	04/15/2025
25D0950-39	6663-FEB-39 Water Fountain	Drinking Water	04/12/2025	04/15/2025
25D0950-40	6663-FEB-40 WF Bottle Fill	Drinking Water	04/12/2025	04/15/2025
25D0950-41	6663-FEB-41 Kitchenette Sink	Drinking Water	04/12/2025	04/15/2025
25D0950-42	6663-FEB-42 Room 203 Sink	Drinking Water	04/12/2025	04/15/2025
25D0950-43	6663-FEB-43 Room 204	Drinking Water	04/12/2025	04/15/2025
25D0950-44	6663-FEB-44 Gender Neutral Bathroom	Drinking Water	04/12/2025	04/15/2025
25D0950-45	6663-FEB-45 2nd Fl Water Fountain	Drinking Water	04/12/2025	04/15/2025
25D0950-46	6663-FEB-46 2nd Fl WF Bottle Fill	Drinking Water	04/12/2025	04/15/2025
25D0950-47	6663-FEB-47 Boy's Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0950-48	6663-FEB-48 Boy's Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0950-49	6663-FEB-49 Room 308 Sink	Drinking Water	04/12/2025	04/15/2025
25D0950-50	6663-FEB-50 Water Fountain	Drinking Water	04/12/2025	04/15/2025
25D0950-51	6663-FEB-51 WF Bottle Fill	Drinking Water	04/12/2025	04/15/2025
25D0950-52	6663-FEB-52 Faculty Sink	Drinking Water	04/12/2025	04/15/2025
25D0950-53	6663-FEB-53 Faculty Kitchenette	Drinking Water	04/12/2025	04/15/2025
25D0950-54	6663-FEB-54 Girl's Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0950-55	6663-FEB-55 Girl's Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0950-56	6663-FEB-56 BSMT Boy's BR Left	Drinking Water	04/12/2025	04/15/2025
25D0950-57	6663-FEB-57 Boy's Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0950-58	6663-FEB-58 Water Fountain	Drinking Water	04/12/2025	04/15/2025
25D0950-59	6663-FEB-59 WF Bottle Fill	Drinking Water	04/12/2025	04/15/2025
25D0950-60	6663-FEB-60 Room 103 Sink	Drinking Water	04/12/2025	04/15/2025
25D0950-61	6663-FEB-61 Unnumbered Rm End of Hall	Drinking Water	04/12/2025	04/15/2025
25D0950-62	6663-FEB-62 Room w/ Little Corridor	Drinking Water	04/12/2025	04/15/2025
25D0950-63	6663-FEB-63 Water Fountain BF	Drinking Water	04/12/2025	04/15/2025
25D0950-64	6663-FEB-64 Water Fountain	Drinking Water	04/12/2025	04/15/2025
25D0950-65	6663-FEB-65 Girl's Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0950-66	6663-FEB-66 Girl's Mid Right	Drinking Water	04/12/2025	04/15/2025
25D0950-67	6663-FEB-67 Girl's Right	Drinking Water	04/12/2025	04/15/2025
25D0950-68	6663-FEB-68 Room 108	Drinking Water	04/12/2025	04/15/2025
25D0950-69	6663-FEB-69 Across from 108	Drinking Water	04/12/2025	04/15/2025
25D0950-70	6663-FEB-70 Serving/Kitchen Left	Drinking Water	04/12/2025	04/15/2025
25D0950-71	6663-FEB-71 Serving/Kitchen Right	Drinking Water	04/12/2025	04/15/2025
25D0950-72	6663-FEB-72 Gender Neutral	Drinking Water	04/12/2025	04/15/2025
25D0950-73	6663-FEB-73 Cafe Gender Neutral Right	Drinking Water	04/12/2025	04/15/2025
25D0950-74	6663-FEB-74 Cafe Gender Neutral Left	Drinking Water	04/12/2025	04/15/2025
25D0952-01	6663-HS-150 Kitchen Hand Wash Sink	Drinking Water	04/12/2025	04/15/2025
25D0952-02	6663-HS-151 Kitchen Bathroom	Drinking Water	04/12/2025	04/15/2025
25D0952-03	6663-HS-152 Kitchen Sink Right	Drinking Water	04/12/2025	04/15/2025
25D0952-04	6663-HS-153 Kitchen Sink Left	Drinking Water	04/12/2025	04/15/2025

York Sample ID	Client Sample ID	Matrix	Date Collected	Date Received
25D0952-05	6663-HS-154 Back Kitchen Handwash	Drinking Water	04/12/2025	04/15/2025
25D0952-06	6663-HS-155 Back Kitchen Sink	Drinking Water	04/12/2025	04/15/2025
25D0952-07	6663-HS-156 Science Wing Gender Neutral	Drinking Water	04/12/2025	04/15/2025
25D0952-08	6663-HS-157 Sci Wing Girls Left	Drinking Water	04/12/2025	04/15/2025
25D0952-09	6663-HS-158 Sci Wing Girls Right	Drinking Water	04/12/2025	04/15/2025
25D0952-10	6663-HS-159 Sci Wing Boys Left	Drinking Water	04/12/2025	04/15/2025
25D0952-11	6663-HS-160 Sci Wing Boys Right	Drinking Water	04/12/2025	04/15/2025
25D0952-12	6663-HS-161 WF Bottle Fills o/s 124	Drinking Water	04/12/2025	04/15/2025
25D0952-13	6663-HS-162 W o/s 124	Drinking Water	04/12/2025	04/15/2025
25D0952-14	6663-HS-163 2nd Fl Sci Wing Girls Left	Drinking Water	04/12/2025	04/15/2025
25D0952-15	6663-HS-164 2nd Fl Sci Wing Girls Mid	Drinking Water	04/12/2025	04/15/2025
25D0952-16	6663-HS-165 2nd Fl Sci Wing Girls Right	Drinking Water	04/12/2025	04/15/2025
25D0952-17	6663-HS-166 2nd Fl Sci Wing Gen Neutral	Drinking Water	04/12/2025	04/15/2025
25D0952-18	6663-HS-167 2nd Fl Sci Wing Boys Right	Drinking Water	04/12/2025	04/15/2025
25D0952-19	6663-HS-168 2nd Fl Sci Wing Boys Mid	Drinking Water	04/12/2025	04/15/2025
25D0952-20	6663-HS-169 2nd Fl Sci Wing Boys Left	Drinking Water	04/12/2025	04/15/2025
25D0952-21	6663-HS-170 2nd Fl Sci Wing BF	Drinking Water	04/12/2025	04/15/2025
25D0952-22	6663-HS-171 2nd Fl Sci Wing WF	Drinking Water	04/12/2025	04/15/2025
25D0952-23	6663-HS-172 WF Outside Nurse	Drinking Water	04/12/2025	04/15/2025
25D0952-24	6663-HS-173 BF Outside Nurse	Drinking Water	04/12/2025	04/15/2025
25D0952-25	6663-HS-174 Nurse Room 1	Drinking Water	04/12/2025	04/15/2025
25D0952-26	6663-HS-175 Nurse Bathroom	Drinking Water	04/12/2025	04/15/2025
25D0952-27	6663-HS-176 Mail Room Sink	Drinking Water	04/12/2025	04/15/2025
25D0952-28	6663-HS-177 Principals Office BR	Drinking Water	04/12/2025	04/15/2025
25D0952-29	6663-HS-178 Boys E Wing Right	Drinking Water	04/12/2025	04/15/2025
25D0952-30	6663-HS-179 Boys E Wing Left	Drinking Water	04/12/2025	04/15/2025
25D0952-31	6663-HS-180 E Wing Teachers BR 1	Drinking Water	04/12/2025	04/15/2025
25D0952-32	6663-HS-181 E Wing Teachers BR 2	Drinking Water	04/12/2025	04/15/2025
25D0952-33	6663-HS-182 E Wing Girls BR Left	Drinking Water	04/12/2025	04/15/2025
25D0952-34	6663-HS-183 E Wing Girls BR Mid	Drinking Water	04/12/2025	04/15/2025
25D0952-35	6663-HS-184 E Wing Girls BR Right	Drinking Water	04/12/2025	04/15/2025
25D0952-36	6663-MS-185 A Corridor WF	Drinking Water	04/12/2025	04/15/2025
25D0952-37	6663-MS-186 A Corridor BF	Drinking Water	04/12/2025	04/15/2025
25D0952-38	6663-MS-187 B Corridor Boys Left	Drinking Water	04/12/2025	04/15/2025
25D0952-39	6663-MS-188 B Corridor Boys Right	Drinking Water	04/12/2025	04/15/2025
25D0952-40	6663-MS-189 B Corridor Girls Left	Drinking Water	04/12/2025	04/15/2025
25D0952-41	6663-MS-190 B Corridor Girls Mid	Drinking Water	04/12/2025	04/15/2025
25D0952-42	6663-MS-191 B Corridor Girls Right	Drinking Water	04/12/2025	04/15/2025
25D0952-43	6663-MS-192 6th Grade Wing Girls Right	Drinking Water	04/12/2025	04/15/2025
25D0952-44	6663-MS-193 6th Grade Wing Girls Left	Drinking Water	04/12/2025	04/15/2025
25D0952-45	6663-MS-194 6th Grade Wing WF	Drinking Water	04/12/2025	04/15/2025
25D0952-46	6663-MS-195 6th Grade Wing BF	Drinking Water	04/12/2025	04/15/2025
25D0952-47	6663-MS-196 6th Grade Wing Boys Left	Drinking Water	04/12/2025	04/15/2025
25D0952-48	6663-MS-197 6th Grade Wing Boys Right	Drinking Water	04/12/2025	04/15/2025
25D0952-49	6663-MS-198 A15 Gen Neutral Front	Drinking Water	04/12/2025	04/15/2025
25D0952-50	6663-MS-199 A15 Gen Neutral Back	Drinking Water	04/12/2025	04/15/2025
25D0952-51	6663-MS-200 C Corridor WF	Drinking Water	04/12/2025	04/15/2025
25D0952-52	6663-MS-201 C Corridor BF	Drinking Water	04/12/2025	04/15/2025
25D0952-53	6663-MS-202 Girls Bathroom	Drinking Water	04/12/2025	04/15/2025
25D0952-54	6663-MS-203 Girls Bathroom	Drinking Water	04/12/2025	04/15/2025
25D0952-55	6663-MS-204 Water Fountain	Drinking Water	04/12/2025	04/15/2025
25D0952-56	6663-MS-205 Bottle Filler	Drinking Water	04/12/2025	04/15/2025
25D0955-01	6663-DWES-75 Ground Floor WF	Drinking Water	04/12/2025	04/15/2025
25D0955-02	6663-DWES-76 WF Bottle Fill	Drinking Water	04/12/2025	04/15/2025
25D0955-03	6663-DWES-77 Boy's Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0955-04	6663-DWES-78 Boy's Bathroom Left	Drinking Water	04/12/2025	04/15/2025

York Sample ID	Client Sample ID	Matrix	Date Collected	Date Received
25D0955-05	6663-DWES-79 Room 110 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-06	6663-DWES-80 Room 110 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-07	6663-DWES-81 Room 117 Bathroom	Drinking Water	04/12/2025	04/15/2025
25D0955-08	6663-DWES-82 Room 117 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-09	6663-DWES-83 Room 117 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-10	6663-DWES-84 Room 110 Bathroom	Drinking Water	04/12/2025	04/15/2025
25D0955-11	6663-DWES-85 Room 111 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-12	6663-DWES-86 Girl's Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0955-13	6663-DWES-87 Girl's Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0955-14	6663-DWES-88 WF BF by Resource rm	Drinking Water	04/12/2025	04/15/2025
25D0955-15	6663-DWES-89 Room 113 Bathroom	Drinking Water	04/12/2025	04/15/2025
25D0955-16	6663-DWES-90 Room 113 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-17	6663-DWES-91 Room 113 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-18	6663-DWES-92 Room 134 Bathroom	Drinking Water	04/12/2025	04/15/2025
25D0955-19	6663-DWES-93 Room 134 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-20	6663-DWES-94 3rd Floor Rm 308 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-21	6663-DWES-95 Room 308 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-22	6663-DWES-96 Girls Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0955-23	6663-DWES-97 Girls Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0955-24	6663-DWES-98 Room 302 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-25	6663-DWES-99 Room 300 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-26	6663-DWES-100 Water Fountain	Drinking Water	04/12/2025	04/15/2025
25D0955-27	6663-DWES-101 WF Bottle Fill	Drinking Water	04/12/2025	04/15/2025
25D0955-28	6663-DWES-102 Boy's Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0955-29	6663-DWES-103 Boy's Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0955-30	6663-DWES-104 Room 300 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-31	6663-DWES-105 Room 303	Drinking Water	04/12/2025	04/15/2025
25D0955-32	6663-DWES-106 Room 303 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-33	6663-DWES-107 Room 301 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-34	6663-DWES-108 Room 302 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-35	6663-DWES-109 Room 304 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-36	6663-DWES-110 Room 304 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-37	6663-DWES-111 Room 306 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-38	6663-DWES-112 Room 306 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-39	6663-DWES-113 2nd Floor Teachers Lounge	Drinking Water	04/12/2025	04/15/2025
25D0955-40	6663-DWES-114 Teachers Lounge BR	Drinking Water	04/12/2025	04/15/2025
25D0955-41	6663-DWES-115 Corridor Bottle Fill	Drinking Water	04/12/2025	04/15/2025
25D0955-42	6663-DWES-116 Room 230 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-43	6663-DWES-117 Room 230 BR	Drinking Water	04/12/2025	04/15/2025
25D0955-44	6663-DWES-118 Room 231 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-45	6663-DWES-119 Room 231 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-46	6663-DWES-120 Room 231 BR	Drinking Water	04/12/2025	04/15/2025
25D0955-47	6663-DWES-121 Room 208 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-48	6663-DWES-122 Room 208 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-49	6663-DWES-123 Library WF	Drinking Water	04/12/2025	04/15/2025
25D0955-50	6663-DWES-124 Library BR	Drinking Water	04/12/2025	04/15/2025
25D0955-51	6663-DWES-125 Boys Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0955-52	6663-DWES-126 Boys Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0955-53	6663-DWES-127 Girls Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0955-54	6663-DWES-128 Girls Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0955-55	6663-DWES-129 Room 201 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-56	6663-DWES-130 Room 201 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-57	6663-DWES-131 Room 206 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-58	6663-DWES-132 Room 206 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-59	6663-DWES-133 Room 203 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-60	6663-DWES-134 Room 203 WF	Drinking Water	04/12/2025	04/15/2025

York Sample ID	Client Sample ID	Matrix	Date Collected	Date Received
25D0955-61	6663-DWES-135 Main Office Gender Neutral	Drinking Water	04/12/2025	04/15/2025
25D0955-62	6663-DWES-136 Nurses Bathroom	Drinking Water	04/12/2025	04/15/2025
25D0955-63	6663-DWES-137 Nurses Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-64	6663-DWES-138 Room 204 Sink	Drinking Water	04/12/2025	04/15/2025
25D0955-65	6663-DWES-139 Room 204 WF	Drinking Water	04/12/2025	04/15/2025
25D0955-66	6663-HS-140 Custodial Office Left	Drinking Water	04/12/2025	04/15/2025
25D0955-67	6663-HS-141 Custodial Office Right	Drinking Water	04/12/2025	04/15/2025
25D0955-68	6663-HS-142 Custodial BR	Drinking Water	04/12/2025	04/15/2025
25D0955-69	6663-HS-143 Dining Hall WF BF	Drinking Water	04/12/2025	04/15/2025
25D0955-70	6663-HS-144 Dining Hall WF	Drinking Water	04/12/2025	04/15/2025
25D0955-71	6663-HS-145 Girls Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0955-72	6663-HS-146 Girls Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0955-73	6663-HS-147 Boys Bathroom Left	Drinking Water	04/12/2025	04/15/2025
25D0955-74	6663-HS-148 Boys Bathroom Right	Drinking Water	04/12/2025	04/15/2025
25D0955-75	6663-HS-149 Kitchen Sink Middle	Drinking Water	04/12/2025	04/15/2025

General Notes for York Project (SDG) No.: 25D0950

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854, NJ Cert No. CT005, PA Cert No. 68-04440, CT Cert No. PH-0723; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058, NJ Cert No. NY037, CT Cert No. PH-0721, NH Cert No. 2097, EPA Cert No. NY01600.

Approved By: 

Date: 04/22/2025

Cassie L. Mosher
Laboratory Manager

Sample Information

Client Sample ID: 6663-A-01-Vestibule WF **York Sample ID:** 25D0950-01

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:08 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:47	04/18/2025 17:42	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-02-Vestibule WF Bottle Fill **York Sample ID:** 25D0950-02

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:08 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:47	04/18/2025 17:46	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-03 Right WF **York Sample ID:** 25D0950-03

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:09 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:47	04/18/2025 17:49	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-04 Right WF Bottle Fill **York Sample ID:** 25D0950-04

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:09 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **6663-A-04 Right WF Bottle Fill** **York Sample ID:** **25D0950-04**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:09 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:47	04/18/2025 17:53	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-A-05 Boy's Locker Room Left** **York Sample ID:** **25D0950-05**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:17 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**1.02**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:47	04/18/2025 17:57	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-A-06 Boy's Locker Room Center** **York Sample ID:** **25D0950-06**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:17 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:47	04/18/2025 18:08	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-A-07 Boy's Locker Room Right** **York Sample ID:** **25D0950-07**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:11 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-A-07 Boy's Locker Room Right **York Sample ID:** 25D0950-07

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:11 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:47	04/18/2025 18:12	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-08 Girls Locker Room Left **York Sample ID:** 25D0950-08

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:13 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**1.25**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:47	04/18/2025 18:15	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-09 Girls Locker Room Center **York Sample ID:** 25D0950-09

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:13 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**1.68**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:47	04/18/2025 18:19	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-10 Girls Locker Room Right **York Sample ID:** 25D0950-10

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:13 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-A-10 Girls Locker Room Right **York Sample ID:** 25D0950-10

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:13 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	7.92		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 19:37	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-11 Gender Neutral **York Sample ID:** 25D0950-11

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:27 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	2.63		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 19:40	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-12 Girl's Bathroom Left **York Sample ID:** 25D0950-12

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:30 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	4.62		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 19:44	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-13 Girl's Bathroom Right **York Sample ID:** 25D0950-13

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:30 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-A-13 Girl's Bathroom Right **York Sample ID:** 25D0950-13

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:30 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	1.98		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 19:48	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-14 Boy's Bathroom Left **York Sample ID:** 25D0950-14

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:31 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	2.25		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 19:51	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-15 Boy's Bathroom Right **York Sample ID:** 25D0950-15

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:31 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	1.84		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 19:55	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-16 Water Fountain **York Sample ID:** 25D0950-16

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:32 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-A-16 Water Fountain **York Sample ID:** 25D0950-16

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:32 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 19:59	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-17 Bottle Filler **York Sample ID:** 25D0950-17

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:32 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:02	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-18 Girl's Bathroom Left 1 **York Sample ID:** 25D0950-18

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:36 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:06	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-19 Girl's Bathroom Right 1 **York Sample ID:** 25D0950-19

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:36 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-A-19 Girl's Bathroom Right 1 **York Sample ID:** 25D0950-19

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:36 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:10	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-20 Girl's Bathroom Left 2 **York Sample ID:** 25D0950-20

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:36 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**1.59**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:21	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-21 Girl's Bathroom Right 2 **York Sample ID:** 25D0950-21

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:36 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**1.58**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:25	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-22 Boy's Bathroom Left 1 **York Sample ID:** 25D0950-22

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:38 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-A-22 Boy's Bathroom Left 1 **York Sample ID:** 25D0950-22

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:38 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	2.13		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:28	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-23 Boy's Bathroom Right 1 **York Sample ID:** 25D0950-23

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:38 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	2.55		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:32	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-24 Boy's Bathroom Left 2 **York Sample ID:** 25D0950-24

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:38 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	3.07		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:36	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-A-25 Boy's Bathroom Right 2 **York Sample ID:** 25D0950-25

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:38 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-A-25 Boy's Bathroom Right 2** **York Sample ID:** **25D0950-25**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:38 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**2.55**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:40	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-A-26 Coach's Bathroom Sink** **York Sample ID:** **25D0950-26**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:39 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**7.04**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:43	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-27 Main Floor Water Fountain** **York Sample ID:** **25D0950-27**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:54 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:47	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-28 Main Floor WF Bottle Fill** **York Sample ID:** **25D0950-28**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:54 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-FEB-28 Main Floor WF Bottle Fill **York Sample ID:** 25D0950-28

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:54 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:51	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-29 Boy's Bathroom Left **York Sample ID:** 25D0950-29

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:55 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**1.07**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:50	04/18/2025 20:54	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-30 Boy's Bathroom Right **York Sample ID:** 25D0950-30

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:55 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 21:24	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-31 Girl's Bathroom Left **York Sample ID:** 25D0950-31

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:57 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-FEB-31 Girl's Bathroom Left **York Sample ID:** 25D0950-31

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:57 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 21:28	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-32 Girl's Bathroom Right **York Sample ID:** 25D0950-32

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:57 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 21:31	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-33 Nurse's Bathroom **York Sample ID:** 25D0950-33

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:58 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 21:35	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-34 Nurse's Sink **York Sample ID:** 25D0950-34

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:59 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-FEB-34 Nurse's Sink **York Sample ID:** 25D0950-34

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 7:59 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 21:39	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-35 Dada Coordinator's Office **York Sample ID:** 25D0950-35

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:04 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**2.58**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 21:50	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-36 3AC/EL Sink **York Sample ID:** 25D0950-36

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:05 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**2.76**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 21:54	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-37 3FK Sink **York Sample ID:** 25D0950-37

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:06 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-FEB-37 3FK Sink** **York Sample ID:** **25D0950-37**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:06 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**3.76**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 21:57	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-38 Room 207 Sink** **York Sample ID:** **25D0950-38**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:06 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**8.31**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:01	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-39 Water Fountain** **York Sample ID:** **25D0950-39**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:11 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:05	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-40 WF Bottle Fill** **York Sample ID:** **25D0950-40**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:11 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-FEB-40 WF Bottle Fill **York Sample ID:** 25D0950-40

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:11 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:08	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-41 Kitchenette Sink **York Sample ID:** 25D0950-41

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:04 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**1.78**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:12	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-42 Room 203 Sink **York Sample ID:** 25D0950-42

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:07 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:16	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-43 Room 204 **York Sample ID:** 25D0950-43

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:08 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-FEB-43 Room 204 **York Sample ID:** 25D0950-43

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:08 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	1.00		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:19	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-44 Gender Neutral Bathroom **York Sample ID:** 25D0950-44

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:15 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:23	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-45 2nd Fl Water Fountain **York Sample ID:** 25D0950-45

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:17 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:34	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-46 2nd Fl WF Bottle Fill **York Sample ID:** 25D0950-46

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:17 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-FEB-46 2nd Fl WF Bottle Fill **York Sample ID:** 25D0950-46

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:17 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:38	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-47 Boy's Bathroom Right **York Sample ID:** 25D0950-47

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:20 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**1.44**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:42	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-48 Boy's Bathroom Left **York Sample ID:** 25D0950-48

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:20 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**1.09**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:45	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-49 Room 308 Sink **York Sample ID:** 25D0950-49

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:18 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-FEB-49 Room 308 Sink** **York Sample ID:** **25D0950-49**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:18 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**10.7**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:51	04/18/2025 22:49	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-50 Water Fountain** **York Sample ID:** **25D0950-50**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:20 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/18/2025 23:19	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-51 WF Bottle Fill** **York Sample ID:** **25D0950-51**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:20 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/18/2025 23:22	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-52 Faculty Sink** **York Sample ID:** **25D0950-52**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:21 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-FEB-52 Faculty Sink **York Sample ID:** 25D0950-52

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:21 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	18.9		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/18/2025 23:26	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-53 Faculty Kitchenette **York Sample ID:** 25D0950-53

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:22 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	3.14		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/18/2025 23:30	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-54 Girl's Bathroom Left **York Sample ID:** 25D0950-54

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:23 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/18/2025 23:33	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-55 Girl's Bathroom Right **York Sample ID:** 25D0950-55

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:23 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-FEB-55 Girl's Bathroom Right** **York Sample ID:** **25D0950-55**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:23 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/18/2025 23:37	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-56 BSMT Boy's BR Left** **York Sample ID:** **25D0950-56**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:28 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**1.70**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/18/2025 23:41	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-57 Boy's Bathroom Right** **York Sample ID:** **25D0950-57**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:28 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**1.23**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/18/2025 23:45	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-58 Water Fountain** **York Sample ID:** **25D0950-58**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:29 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **6663-FEB-58 Water Fountain** **York Sample ID:** **25D0950-58**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:29 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/18/2025 23:48	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-59 WF Bottle Fill** **York Sample ID:** **25D0950-59**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:29 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/18/2025 23:52	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-60 Room 103 Sink** **York Sample ID:** **25D0950-60**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:34 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**47.2**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/19/2025 00:03	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-61 Unnumbered Rm End of Hall** **York Sample ID:** **25D0950-61**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:35 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-FEB-61 Unnumbered Rm End of Hall** **York Sample ID:** **25D0950-61**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:35 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	2.94		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/19/2025 00:07	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-62 Room w/ Little Corridor** **York Sample ID:** **25D0950-62**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:37 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/19/2025 00:10	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-63 Water Fountain BF** **York Sample ID:** **25D0950-63**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:30 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/19/2025 00:14	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-64 Water Fountain** **York Sample ID:** **25D0950-64**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:30 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-FEB-64 Water Fountain **York Sample ID:** 25D0950-64

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:30 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/19/2025 00:18	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-65 Girl's Bathroom Left **York Sample ID:** 25D0950-65

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:34 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/19/2025 00:22	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-66 Girl's Mid Right **York Sample ID:** 25D0950-66

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:34 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/19/2025 00:25	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: 6663-FEB-67 Girl's Right **York Sample ID:** 25D0950-67

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:34 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-FEB-67 Girl's Right** **York Sample ID:** **25D0950-67**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:34 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/19/2025 00:29	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-68 Room 108** **York Sample ID:** **25D0950-68**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:37 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**2.48**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/19/2025 00:33	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-69 Across from 108** **York Sample ID:** **25D0950-69**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:40 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	*** Lead**	**6.50**		ug/L	1.00	1	EPA 200.8	04/18/2025 14:52	04/19/2025 00:36	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-70 Serving/Kitchen Left** **York Sample ID:** **25D0950-70**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:50 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **6663-FEB-70 Serving/Kitchen Left** **York Sample ID:** **25D0950-70**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:50 am	04/15/2025

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	3.37		ug/L	1.00	1	EPA 200.8	04/18/2025 17:26	04/21/2025 14:45	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-71 Serving/Kitchen Right** **York Sample ID:** **25D0950-71**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:50 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	2.28		ug/L	1.00	1	EPA 200.8	04/18/2025 17:26	04/21/2025 14:49	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-72 Gender Neutral** **York Sample ID:** **25D0950-72**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:51 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	6.68		ug/L	1.00	1	EPA 200.8	04/18/2025 17:26	04/21/2025 14:53	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-73 Cafe Gender Neutral Right** **York Sample ID:** **25D0950-73**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:52 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-FEB-73 Cafe Gender Neutral Right** **York Sample ID:** **25D0950-73**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:52 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	1.04		ug/L	1.00	1	EPA 200.8	04/18/2025 17:26	04/21/2025 14:56	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-FEB-74 Cafe Gender Neutral Left** **York Sample ID:** **25D0950-74**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0950	256663 Rye Neck UFSD- FEB 1/Athletic	Drinking Water	April 12, 2025 8:52 am	04/15/2025

N-M-Lead **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: METALS-200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	* Lead	1.09		ug/L	1.00	1	EPA 200.8	04/18/2025 17:26	04/21/2025 15:00	DLW
							Certifications:	CTDOH-PH-0800,NELAC-NY11706		

Sample Information

Client Sample ID: **6663-HS-150 Kitchen Hand Wash Sink** **York Sample ID:** **25D0952-01**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:27 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:38	04/17/2025 14:06	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-HS-151 Kitchen Bathroom** **York Sample ID:** **25D0952-02**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:28 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-HS-151 Kitchen Bathroom **York Sample ID:** 25D0952-02

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:28 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:38	04/17/2025 14:07	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-152 Kitchen Sink Right **York Sample ID:** 25D0952-03

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:29 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:38	04/17/2025 14:08	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-153 Kitchen Sink Left **York Sample ID:** 25D0952-04

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:29 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:38	04/17/2025 14:10	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-154 Back Kitchen Handwash **York Sample ID:** 25D0952-05

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:30 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-HS-154 Back Kitchen Handwash **York Sample ID:** 25D0952-05

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:30 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:38	04/17/2025 14:11	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-155 Back Kitchen Sink **York Sample ID:** 25D0952-06

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:31 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:38	04/17/2025 14:12	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-156 Science Wing Gender Neutral **York Sample ID:** 25D0952-07

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:35 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 14:47	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-157 Sci Wing Girls Left **York Sample ID:** 25D0952-08

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:36 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-HS-157 Sci Wing Girls Left **York Sample ID:** 25D0952-08

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:36 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 14:50	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-158 Sci Wing Girls Right **York Sample ID:** 25D0952-09

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:37 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 14:51	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-159 Sci Wing Boys Left **York Sample ID:** 25D0952-10

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:37 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 14:52	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-160 Sci Wing Boys Right **York Sample ID:** 25D0952-11

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:37 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-HS-160 Sci Wing Boys Right **York Sample ID:** 25D0952-11

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:37 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 14:54	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-161 WF Bottle Fills o/s 124 **York Sample ID:** 25D0952-12

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:38 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 14:55	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-162 W o/s 124 **York Sample ID:** 25D0952-13

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:38 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 14:56	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-163 2nd Fl Sci Wing Girls Left **York Sample ID:** 25D0952-14

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:43 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-HS-163 2nd Fl Sci Wing Girls Left **York Sample ID:** 25D0952-14

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:43 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**5.37**	M-PbE X	ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:00	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-164 2nd Fl Sci Wing Girls Mid **York Sample ID:** 25D0952-15

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:43 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.48**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:02	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-165 2nd Fl Sci Wing Girls Right **York Sample ID:** 25D0952-16

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:43 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.94**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:03	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-166 2nd Fl Sci Wing Gen Neutral **York Sample ID:** 25D0952-17

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:42 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-HS-166 2nd Fl Sci Wing Gen Neutral **York Sample ID:** 25D0952-17

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:42 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.16**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:04	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-167 2nd Fl Sci Wing Boys Right **York Sample ID:** 25D0952-18

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:42 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**13.7**		ug/L	1.00	1	EPA 200.8	04/16/2025 14:50	04/21/2025 13:37	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-168 2nd Fl Sci Wing Boys Mid **York Sample ID:** 25D0952-19

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:42 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.43**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:06	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-169 2nd Fl Sci Wing Boys Left **York Sample ID:** 25D0952-20

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:42 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-HS-169 2nd Fl Sci Wing Boys Left **York Sample ID:** 25D0952-20

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:42 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**4.86**		ug/L	1.00	1	EPA 200.8	04/16/2025 14:50	04/21/2025 13:40	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-170 2nd Fl Sci Wing BF **York Sample ID:** 25D0952-21

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:48 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:07	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-171 2nd Fl Sci Wing WF **York Sample ID:** 25D0952-22

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:48 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:08	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-172 WF Outside Nurse **York Sample ID:** 25D0952-23

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:51 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-HS-172 WF Outside Nurse **York Sample ID:** 25D0952-23

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:51 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:10	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-173 BF Outside Nurse **York Sample ID:** 25D0952-24

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:51 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:11	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-174 Nurse Room 1 **York Sample ID:** 25D0952-25

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:51 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.02**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:12	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-175 Nurse Bathroom **York Sample ID:** 25D0952-26

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:52 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-HS-175 Nurse Bathroom **York Sample ID:** 25D0952-26

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:52 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**6.37**	M-PbE X	ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:17	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-176 Mail Room Sink **York Sample ID:** 25D0952-27

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:52 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.58**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:18	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-177 Principals Office BR **York Sample ID:** 25D0952-28

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:53 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.31**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:19	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-178 Boys E Wing Right **York Sample ID:** 25D0952-29

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:55 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-HS-178 Boys E Wing Right** **York Sample ID:** **25D0952-29**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:55 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.01**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:26	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-HS-179 Boys E Wing Left** **York Sample ID:** **25D0952-30**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:55 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:29	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-HS-180 E Wing Teachers BR 1** **York Sample ID:** **25D0952-31**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:54 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.77**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:33	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-HS-181 E Wing Teachers BR 2** **York Sample ID:** **25D0952-32**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:55 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-HS-181 E Wing Teachers BR 2 **York Sample ID:** 25D0952-32

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:55 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**10.9**	M-PbE X	ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:34	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-182 E Wing Girls BR Left **York Sample ID:** 25D0952-33

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:56 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.08**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:35	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-183 E Wing Girls BR Mid **York Sample ID:** 25D0952-34

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:56 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**4.24**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:37	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-HS-184 E Wing Girls BR Right **York Sample ID:** 25D0952-35

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:56 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-HS-184 E Wing Girls BR Right **York Sample ID:** 25D0952-35

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 10:56 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.62**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:38	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-185 A Corridor WF **York Sample ID:** 25D0952-36

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:03 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:39	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-MS-186 A Corridor BF **York Sample ID:** 25D0952-37

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:03 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:41	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-MS-187 B Corridor Boys Left **York Sample ID:** 25D0952-38

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:04 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-MS-187 B Corridor Boys Left **York Sample ID:** 25D0952-38

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:04 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.60**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:42	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-188 B Corridor Boys Right **York Sample ID:** 25D0952-39

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:04 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**16.5**	M-PbE X	ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:43	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-189 B Corridor Girls Left **York Sample ID:** 25D0952-40

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:06 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:45	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-MS-190 B Corridor Girls Mid **York Sample ID:** 25D0952-41

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:06 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-MS-190 B Corridor Girls Mid **York Sample ID:** 25D0952-41

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:06 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.44**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:49	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-191 B Corridor Girls Right **York Sample ID:** 25D0952-42

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:06 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.02**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:50	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-192 6th Grade Wing Girls Right **York Sample ID:** 25D0952-43

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:04 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**148**	M-PbE X	ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:51	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-193 6th Grade Wing Girls Left **York Sample ID:** 25D0952-44

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:04 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-MS-193 6th Grade Wing Girls Left **York Sample ID:** 25D0952-44

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:04 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**4.59**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:53	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-194 6th Grade Wing WF **York Sample ID:** 25D0952-45

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:05 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.72**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:54	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-195 6th Grade Wing BF **York Sample ID:** 25D0952-46

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:05 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**4.85**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:56	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-196 6th Grade Wing Boys Left **York Sample ID:** 25D0952-47

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:07 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-MS-196 6th Grade Wing Boys Left **York Sample ID:** 25D0952-47

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:07 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**7.94**	M-PbE X	ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:57	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-197 6th Grade Wing Boys Right **York Sample ID:** 25D0952-48

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:07 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.85**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:41	04/17/2025 15:58	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-198 A15 Gen Neutral Front **York Sample ID:** 25D0952-49

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:08 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**4.66**		ug/L	1.00	1	EPA 200.8	04/16/2025 15:57	04/17/2025 13:35	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-199 A15 Gen Neutral Back **York Sample ID:** 25D0952-50

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:09 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-MS-199 A15 Gen Neutral Back **York Sample ID:** 25D0952-50

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:09 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.14**		ug/L	1.00	1	EPA 200.8	04/17/2025 10:38	04/17/2025 14:14	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-200 C Corridor WF **York Sample ID:** 25D0952-51

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:13 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:11	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-MS-201 C Corridor BF **York Sample ID:** 25D0952-52

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:13 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:14	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-MS-202 Girls Bathroom **York Sample ID:** 25D0952-53

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:14 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-MS-202 Girls Bathroom **York Sample ID:** 25D0952-53

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:14 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:15	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-MS-203 Girls Bathroom **York Sample ID:** 25D0952-54

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:14 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**4.79**	M-CCV 1	ug/L	1.00	1	EPA 200.8	04/16/2025 14:50	04/21/2025 13:51	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-MS-204 Water Fountain **York Sample ID:** 25D0952-55

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:16 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:16	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-MS-205 Bottle Filler **York Sample ID:** 25D0952-56

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:16 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-MS-205 Bottle Filler **York Sample ID:** 25D0952-56

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0952	256663 Rye Neck UFSD- HS 1/ HS 2/ MS 1	Drinking Water	April 12, 2025 11:16 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:18	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-75 Ground Floor WF **York Sample ID:** 25D0955-01

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:07 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:19	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-76 WF Bottle Fill **York Sample ID:** 25D0955-02

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:07 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:20	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-77 Boy's Bathroom Right **York Sample ID:** 25D0955-03

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:07 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-DWES-77 Boy's Bathroom Right** **York Sample ID:** **25D0955-03**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:07 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.24**		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:24	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-DWES-78 Boy's Bathroom Left** **York Sample ID:** **25D0955-04**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:07 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:26	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-79 Room 110 Sink** **York Sample ID:** **25D0955-05**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:09 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:27	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-80 Room 110 WF** **York Sample ID:** **25D0955-06**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:09 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-DWES-80 Room 110 WF **York Sample ID:** 25D0955-06

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:09 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:28	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-81 Room 117 Bathroom **York Sample ID:** 25D0955-07

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:11 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:29	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-82 Room 117 WF **York Sample ID:** 25D0955-08

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:12 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:31	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-83 Room 117 Sink **York Sample ID:** 25D0955-09

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:12 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-DWES-83 Room 117 Sink **York Sample ID:** 25D0955-09

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:12 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:32	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-84 Room 110 Bathroom **York Sample ID:** 25D0955-10

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:15 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:33	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-85 Room 111 Sink **York Sample ID:** 25D0955-11

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:09 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:35	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-86 Girl's Bathroom Left **York Sample ID:** 25D0955-12

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:08 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-DWES-86 Girl's Bathroom Left **York Sample ID:** 25D0955-12

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:08 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:36	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-87 Girl's Bathroom Right **York Sample ID:** 25D0955-13

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:13 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:40	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-88 WF BF by Resource rm **York Sample ID:** 25D0955-14

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:18 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:41	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-89 Room 113 Bathroom **York Sample ID:** 25D0955-15

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:18 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-DWES-89 Room 113 Bathroom** **York Sample ID:** **25D0955-15**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:18 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.14**		ug/L	1.00	1	EPA 200.8	04/17/2025 14:53	04/18/2025 11:43	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-DWES-90 Room 113 WF** **York Sample ID:** **25D0955-16**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:18 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.04**		ug/L	1.00	1	EPA 200.8	04/17/2025 15:28	04/21/2025 16:02	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-DWES-91 Room 113 Sink** **York Sample ID:** **25D0955-17**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:18 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 11:49	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-92 Room 134 Bathroom** **York Sample ID:** **25D0955-18**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:20 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-DWES-92 Room 134 Bathroom **York Sample ID:** 25D0955-18

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:20 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 11:52	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-93 Room 134 Sink **York Sample ID:** 25D0955-19

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:20 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 11:56	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-94 3rd Floor Rm 308 Sink **York Sample ID:** 25D0955-20

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:28 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 11:57	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-95 Room 308 WF **York Sample ID:** 25D0955-21

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:28 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-DWES-95 Room 308 WF** **York Sample ID:** **25D0955-21**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:28 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 11:58	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-96 Girls Bathroom Left** **York Sample ID:** **25D0955-22**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:30 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.43**		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:00	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-DWES-97 Girls Bathroom Right** **York Sample ID:** **25D0955-23**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:30 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.45**		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:01	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-DWES-98 Room 302 Sink** **York Sample ID:** **25D0955-24**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:29 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-DWES-98 Room 302 Sink **York Sample ID:** 25D0955-24

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:29 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.91**		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:02	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-DWES-99 Room 300 Sink **York Sample ID:** 25D0955-25

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:30 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:04	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-100 Water Fountain **York Sample ID:** 25D0955-26

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:32 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:05	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-101 WF Bottle Fill **York Sample ID:** 25D0955-27

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:32 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-DWES-101 WF Bottle Fill **York Sample ID:** 25D0955-27

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:32 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:06	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-102 Boy's Bathroom Left **York Sample ID:** 25D0955-28

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:34 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.06**		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:08	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-DWES-103 Boy's Bathroom Right **York Sample ID:** 25D0955-29

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:34 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:12	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-104 Room 300 WF **York Sample ID:** 25D0955-30

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:38 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-DWES-104 Room 300 WF **York Sample ID:** 25D0955-30

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:38 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:13	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-105 Room 303 **York Sample ID:** 25D0955-31

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:32 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.54**		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:14	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-DWES-106 Room 303 WF **York Sample ID:** 25D0955-32

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:32 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:16	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-107 Room 301 Sink **York Sample ID:** 25D0955-33

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:33 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-DWES-107 Room 301 Sink **York Sample ID:** 25D0955-33

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:33 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:17	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-108 Room 302 WF **York Sample ID:** 25D0955-34

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:33 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:18	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-109 Room 304 WF **York Sample ID:** 25D0955-35

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:32 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:20	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-110 Room 304 Sink **York Sample ID:** 25D0955-36

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:32 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **6663-DWES-110 Room 304 Sink** **York Sample ID:** **25D0955-36**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:32 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 09:33	04/18/2025 12:21	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-111 Room 306 Sink** **York Sample ID:** **25D0955-37**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:30 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:41	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-112 Room 306 WF** **York Sample ID:** **25D0955-38**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:30 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:44	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-113 2nd Floor Teachers Lounge** **York Sample ID:** **25D0955-39**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:48 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-DWES-113 2nd Floor Teachers Lounge **York Sample ID:** 25D0955-39

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:48 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:45	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-114 Teachers Lounge BR **York Sample ID:** 25D0955-40

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:48 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:46	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-115 Corridor Bottle Fill **York Sample ID:** 25D0955-41

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:49 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:47	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-116 Room 230 Sink **York Sample ID:** 25D0955-42

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:51 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **6663-DWES-116 Room 230 Sink** **York Sample ID:** **25D0955-42**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:51 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:49	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-117 Room 230 BR** **York Sample ID:** **25D0955-43**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:51 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:50	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-118 Room 231 Sink** **York Sample ID:** **25D0955-44**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:53 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:54	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-119 Room 231 WF** **York Sample ID:** **25D0955-45**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:53 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-DWES-119 Room 231 WF **York Sample ID:** 25D0955-45

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:53 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:55	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-120 Room 231 BR **York Sample ID:** 25D0955-46

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:54 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:57	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-121 Room 208 Sink **York Sample ID:** 25D0955-47

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:48 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:58	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-122 Room 208 WF **York Sample ID:** 25D0955-48

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:48 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **6663-DWES-122 Room 208 WF** **York Sample ID:** **25D0955-48**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:48 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**5.94**	M-PbE X	ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 12:59	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-DWES-123 Library WF** **York Sample ID:** **25D0955-49**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:46 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 13:01	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-124 Library BR** **York Sample ID:** **25D0955-50**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:00 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**7.63**	M-PbE X	ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 13:02	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-DWES-125 Boys Bathroom Left** **York Sample ID:** **25D0955-51**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:49 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-DWES-125 Boys Bathroom Left** **York Sample ID:** **25D0955-51**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:49 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 13:03	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-126 Boys Bathroom Right** **York Sample ID:** **25D0955-52**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:49 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 13:05	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-127 Girls Bathroom Left** **York Sample ID:** **25D0955-53**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:50 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.09**		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 13:06	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-DWES-128 Girls Bathroom Right** **York Sample ID:** **25D0955-54**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:50 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **6663-DWES-128 Girls Bathroom Right** **York Sample ID:** **25D0955-54**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:50 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.20**		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 13:10	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-DWES-129 Room 201 Sink** **York Sample ID:** **25D0955-55**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:50 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 13:11	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-130 Room 201 WF** **York Sample ID:** **25D0955-56**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:50 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 12:18	04/18/2025 13:13	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-131 Room 206 Sink** **York Sample ID:** **25D0955-57**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:51 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-DWES-131 Room 206 Sink** **York Sample ID:** **25D0955-57**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:51 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:37	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-132 Room 206 WF** **York Sample ID:** **25D0955-58**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:51 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:39	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-133 Room 203 Sink** **York Sample ID:** **25D0955-59**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:53 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:43	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-134 Room 203 WF** **York Sample ID:** **25D0955-60**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:53 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: 6663-DWES-134 Room 203 WF **York Sample ID:** 25D0955-60

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:53 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:45	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-DWES-135 Main Office Gender Neutral **York Sample ID:** 25D0955-61

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:56 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.52**		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:46	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-DWES-136 Nurses Bathroom **York Sample ID:** 25D0955-62

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:04 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.81**		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:47	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 6663-DWES-137 Nurses Sink **York Sample ID:** 25D0955-63

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:04 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-DWES-137 Nurses Sink** **York Sample ID:** **25D0955-63**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:04 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.94**		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:49	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-DWES-138 Room 204 Sink** **York Sample ID:** **25D0955-64**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:53 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:50	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-DWES-139 Room 204 WF** **York Sample ID:** **25D0955-65**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 9:53 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:52	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-HS-140 Custodial Office Left** **York Sample ID:** **25D0955-66**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:25 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **6663-HS-140 Custodial Office Left** **York Sample ID:** **25D0955-66**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:25 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:53	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-HS-141 Custodial Office Right** **York Sample ID:** **25D0955-67**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:25 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:54	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-HS-142 Custodial BR** **York Sample ID:** **25D0955-68**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:25 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.85**		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 13:56	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-HS-143 Dining Hall WF BF** **York Sample ID:** **25D0955-69**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:28 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: 6663-HS-143 Dining Hall WF BF **York Sample ID:** 25D0955-69

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:28 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 14:00	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-144 Dining Hall WF **York Sample ID:** 25D0955-70

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:28 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 14:01	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-145 Girls Bathroom Left **York Sample ID:** 25D0955-71

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:28 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 14:02	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 6663-HS-146 Girls Bathroom Right **York Sample ID:** 25D0955-72

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:28 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **6663-HS-146 Girls Bathroom Right** **York Sample ID:** **25D0955-72**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:28 am	04/15/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 14:04	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-HS-147 Boys Bathroom Left** **York Sample ID:** **25D0955-73**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:30 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 14:05	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: **6663-HS-148 Boys Bathroom Right** **York Sample ID:** **25D0955-74**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:30 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.04**		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 14:06	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: **6663-HS-149 Kitchen Sink Middle** **York Sample ID:** **25D0955-75**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:26 am	04/15/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **6663-HS-149 Kitchen Sink Middle** **York Sample ID:** **25D0955-75**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25D0955	256663 Rye Neck UFSD- DWES 1/ DWES 2/ HS	Drinking Water	April 12, 2025 10:26 am	04/15/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	04/18/2025 13:15	04/18/2025 14:08	JWT
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Analytical Batch Summary

Batch ID: BD51216 **Preparation Method:** EPA 200.8 **Prepared By:** DHD

YORK Sample ID	Client Sample ID	Preparation Date
25D0952-18	6663-HS-167 2nd Fl Sci Wing I	04/16/25
25D0952-20	6663-HS-169 2nd Fl Sci Wing I	04/16/25
25D0952-54	6663-MS-203 Girls Bathroom	04/16/25
BD51216-BLK1	Blank	04/16/25
BD51216-BLK2	Blank	04/16/25
BD51216-BS1	LCS	04/16/25
BD51216-BS2	LCS	04/16/25
BD51216-DUP1	Duplicate	04/16/25
BD51216-MS1	Matrix Spike	04/16/25

Batch ID: BD51229 **Preparation Method:** EPA 200.8 **Prepared By:** cw

YORK Sample ID	Client Sample ID	Preparation Date
25D0952-49	6663-MS-198 A15 Gen Neutral	04/16/25
BD51229-BLK1	Blank	04/16/25
BD51229-BS1	LCS	04/16/25
BD51229-DUP1	Duplicate	04/16/25
BD51229-MS1	Matrix Spike	04/16/25

Batch ID: BD51302 **Preparation Method:** EPA 200.8 **Prepared By:** cw

YORK Sample ID	Client Sample ID	Preparation Date
25D0952-01	6663-HS-150 Kitchen Hand Wa	04/17/25
25D0952-02	6663-HS-151 Kitchen Bathroor	04/17/25
25D0952-03	6663-HS-152 Kitchen Sink Rig	04/17/25
25D0952-04	6663-HS-153 Kitchen Sink Lef	04/17/25
25D0952-05	6663-HS-154 Back Kitchen Ha	04/17/25
25D0952-06	6663-HS-155 Back Kitchen Sin	04/17/25
25D0952-50	6663-MS-199 A15 Gen Neutral	04/17/25
BD51302-BLK1	Blank	04/17/25
BD51302-BS1	LCS	04/17/25
BD51302-DUP1	Duplicate	04/17/25
BD51302-MS1	Matrix Spike	04/17/25

Batch ID: BD51303 **Preparation Method:** EPA 200.8 **Prepared By:** cw

YORK Sample ID	Client Sample ID	Preparation Date
25D0952-07	6663-HS-156 Science Wing Ge	04/17/25
25D0952-08	6663-HS-157 Sci Wing Girls L	04/17/25
25D0952-09	6663-HS-158 Sci Wing Girls Ri	04/17/25
25D0952-10	6663-HS-159 Sci Wing Boys L	04/17/25
25D0952-11	6663-HS-160 Sci Wing Boys R	04/17/25
25D0952-12	6663-HS-161 WF Bottle Fills o	04/17/25
25D0952-13	6663-HS-162 W o/s 124	04/17/25

25D0952-14	6663-HS-163 2nd Fl Sci Wing (	04/17/25
25D0952-15	6663-HS-164 2nd Fl Sci Wing (	04/17/25
25D0952-16	6663-HS-165 2nd Fl Sci Wing (	04/17/25
25D0952-17	6663-HS-166 2nd Fl Sci Wing (	04/17/25
25D0952-19	6663-HS-168 2nd Fl Sci Wing I	04/17/25
25D0952-21	6663-HS-170 2nd Fl Sci Wing I	04/17/25
25D0952-22	6663-HS-171 2nd Fl Sci Wing '	04/17/25
25D0952-23	6663-HS-172 WF Outside Nurs	04/17/25
25D0952-24	6663-HS-173 BF Outside Nurse	04/17/25
25D0952-25	6663-HS-174 Nurse Room 1	04/17/25
25D0952-26	6663-HS-175 Nurse Bathroom	04/17/25
25D0952-27	6663-HS-176 Mail Room Sink	04/17/25
25D0952-28	6663-HS-177 Principals Office	04/17/25
BD51303-BLK1	Blank	04/17/25
BD51303-BS1	LCS	04/17/25
BD51303-DUP1	Duplicate	04/17/25
BD51303-MS1	Matrix Spike	04/17/25
BD51303-MS2	Matrix Spike	04/17/25

Batch ID: BD51304 **Preparation Method:** EPA 200.8 **Prepared By:** cw

YORK Sample ID	Client Sample ID	Preparation Date
25D0952-29	6663-HS-178 Boys E Wing Rig	04/17/25
25D0952-30	6663-HS-179 Boys E Wing Lef	04/17/25
25D0952-31	6663-HS-180 E Wing Teachers	04/17/25
25D0952-32	6663-HS-181 E Wing Teachers	04/17/25
25D0952-33	6663-HS-182 E Wing Girls BR	04/17/25
25D0952-34	6663-HS-183 E Wing Girls BR	04/17/25
25D0952-35	6663-HS-184 E Wing Girls BR	04/17/25
25D0952-36	6663-MS-185 A Corridor WF	04/17/25
25D0952-37	6663-MS-186 A Corridor BF	04/17/25
25D0952-38	6663-MS-187 B Corridor Boys	04/17/25
25D0952-39	6663-MS-188 B Corridor Boys	04/17/25
25D0952-40	6663-MS-189 B Corridor Girls	04/17/25
25D0952-41	6663-MS-190 B Corridor Girls	04/17/25
25D0952-42	6663-MS-191 B Corridor Girls	04/17/25
25D0952-43	6663-MS-192 6th Grade Wing (	04/17/25
25D0952-44	6663-MS-193 6th Grade Wing (	04/17/25
25D0952-45	6663-MS-194 6th Grade Wing '	04/17/25
25D0952-46	6663-MS-195 6th Grade Wing I	04/17/25
25D0952-47	6663-MS-196 6th Grade Wing I	04/17/25
25D0952-48	6663-MS-197 6th Grade Wing I	04/17/25
BD51304-BLK1	Blank	04/17/25
BD51304-BS1	LCS	04/17/25
BD51304-DUP1	Duplicate	04/17/25
BD51304-MS1	Matrix Spike	04/17/25
BD51304-MS2	Matrix Spike	04/17/25

Batch ID: BD51327 **Preparation Method:** EPA 200.8 **Prepared By:** cw

YORK Sample ID	Client Sample ID	Preparation Date

25D0952-51	6663-MS-200 C Corridor WF	04/17/25
25D0952-52	6663-MS-201 C Corridor BF	04/17/25
25D0952-53	6663-MS-202 Girls Bathroom	04/17/25
25D0952-55	6663-MS-204 Water Fountain	04/17/25
25D0952-56	6663-MS-205 Bottle Filler	04/17/25
25D0955-01	6663-DWES-75 Ground Floor '	04/17/25
25D0955-02	6663-DWES-76 WF Bottle Fill	04/17/25
25D0955-03	6663-DWES-77 Boy's Bathroor	04/17/25
25D0955-04	6663-DWES-78 Boy's Bathroor	04/17/25
25D0955-05	6663-DWES-79 Room 110 Sinl	04/17/25
25D0955-06	6663-DWES-80 Room 110 WF	04/17/25
25D0955-07	6663-DWES-81 Room 117 Batl	04/17/25
25D0955-08	6663-DWES-82 Room 117 WF	04/17/25
25D0955-09	6663-DWES-83 Room 117 Sinl	04/17/25
25D0955-10	6663-DWES-84 Room 110 Batl	04/17/25
25D0955-11	6663-DWES-85 Room 111 Sinl	04/17/25
25D0955-12	6663-DWES-86 Girl's Bathroor	04/17/25
25D0955-13	6663-DWES-87 Girl's Bathroor	04/17/25
25D0955-14	6663-DWES-88 WF BF by Res	04/17/25
25D0955-15	6663-DWES-89 Room 113 Batl	04/17/25
BD51327-BLK1	Blank	04/17/25
BD51327-DUP1	Duplicate	04/17/25
BD51327-MS1	Matrix Spike	04/17/25
BD51327-MS2	Matrix Spike	04/17/25

Batch ID: BD51332 **Preparation Method:** EPA 200.8 **Prepared By:** DHD

YORK Sample ID	Client Sample ID	Preparation Date
25D0955-16	6663-DWES-90 Room 113 WF	04/17/25
BD51332-BLK1	Blank	04/17/25
BD51332-BS1	LCS	04/17/25

Batch ID: BD51383 **Preparation Method:** EPA 200.8 **Prepared By:** JWT

YORK Sample ID	Client Sample ID	Preparation Date
25D0955-17	6663-DWES-91 Room 113 Sinl	04/18/25
25D0955-18	6663-DWES-92 Room 134 Batl	04/18/25
25D0955-19	6663-DWES-93 Room 134 Sinl	04/18/25
25D0955-20	6663-DWES-94 3rd Floor Rm 3	04/18/25
25D0955-21	6663-DWES-95 Room 308 WF	04/18/25
25D0955-22	6663-DWES-96 Girls Bathroon	04/18/25
25D0955-23	6663-DWES-97 Girls Bathroon	04/18/25
25D0955-24	6663-DWES-98 Room 302 Sinl	04/18/25
25D0955-25	6663-DWES-99 Room 300 Sinl	04/18/25
25D0955-26	6663-DWES-100 Water Founta	04/18/25
25D0955-27	6663-DWES-101 WF Bottle Fil	04/18/25
25D0955-28	6663-DWES-102 Boy's Bathroc	04/18/25
25D0955-29	6663-DWES-103 Boy's Bathroc	04/18/25
25D0955-30	6663-DWES-104 Room 300 W	04/18/25
25D0955-31	6663-DWES-105 Room 303	04/18/25
25D0955-32	6663-DWES-106 Room 303 W	04/18/25

25D0955-33	6663-DWES-107 Room 301 Si	04/18/25
25D0955-34	6663-DWES-108 Room 302 W	04/18/25
25D0955-35	6663-DWES-109 Room 304 W	04/18/25
25D0955-36	6663-DWES-110 Room 304 Si	04/18/25
BD51383-BLK1	Blank	04/18/25
BD51383-BS1	LCS	04/18/25
BD51383-DUP1	Duplicate	04/18/25
BD51383-MS1	Matrix Spike	04/18/25
BD51383-MS2	Matrix Spike	04/18/25

Batch ID: BD51390 **Preparation Method:** EPA 200.8 **Prepared By:** JWT

YORK Sample ID	Client Sample ID	Preparation Date
25D0955-37	6663-DWES-111 Room 306 Si	04/18/25
25D0955-38	6663-DWES-112 Room 306 W	04/18/25
25D0955-39	6663-DWES-113 2nd Floor Tea	04/18/25
25D0955-40	6663-DWES-114 Teachers Lou	04/18/25
25D0955-41	6663-DWES-115 Corridor Bott	04/18/25
25D0955-42	6663-DWES-116 Room 230 Si	04/18/25
25D0955-43	6663-DWES-117 Room 230 BF	04/18/25
25D0955-44	6663-DWES-118 Room 231 Si	04/18/25
25D0955-45	6663-DWES-119 Room 231 W	04/18/25
25D0955-46	6663-DWES-120 Room 231 BF	04/18/25
25D0955-47	6663-DWES-121 Room 208 Si	04/18/25
25D0955-48	6663-DWES-122 Room 208 W	04/18/25
25D0955-49	6663-DWES-123 Library WF	04/18/25
25D0955-50	6663-DWES-124 Library BR	04/18/25
25D0955-51	6663-DWES-125 Boys Bathroo	04/18/25
25D0955-52	6663-DWES-126 Boys Bathroo	04/18/25
25D0955-53	6663-DWES-127 Girls Bathroo	04/18/25
25D0955-54	6663-DWES-128 Girls Bathroo	04/18/25
25D0955-55	6663-DWES-129 Room 201 Si	04/18/25
25D0955-56	6663-DWES-130 Room 201 W	04/18/25
BD51390-BLK1	Blank	04/18/25
BD51390-BS1	LCS	04/18/25
BD51390-DUP1	Duplicate	04/18/25
BD51390-MS1	Matrix Spike	04/18/25
BD51390-MS2	Matrix Spike	04/18/25

Batch ID: BD51400 **Preparation Method:** EPA 200.8 **Prepared By:** JWT

YORK Sample ID	Client Sample ID	Preparation Date
25D0955-57	6663-DWES-131 Room 206 Si	04/18/25
25D0955-58	6663-DWES-132 Room 206 W	04/18/25
25D0955-59	6663-DWES-133 Room 203 Si	04/18/25
25D0955-60	6663-DWES-134 Room 203 W	04/18/25
25D0955-61	6663-DWES-135 Main Office (	04/18/25
25D0955-62	6663-DWES-136 Nurses Bathr	04/18/25
25D0955-63	6663-DWES-137 Nurses Sink	04/18/25
25D0955-64	6663-DWES-138 Room 204 Si	04/18/25
25D0955-65	6663-DWES-139 Room 204 W	04/18/25


25D0955-66	6663-HS-140 Custodial Office	04/18/25
25D0955-67	6663-HS-141 Custodial Office	04/18/25
25D0955-68	6663-HS-142 Custodial BR	04/18/25
25D0955-69	6663-HS-143 Dining Hall WF I	04/18/25
25D0955-70	6663-HS-144 Dining Hall WF	04/18/25
25D0955-71	6663-HS-145 Girls Bathroom L	04/18/25
25D0955-72	6663-HS-146 Girls Bathroom R	04/18/25
25D0955-73	6663-HS-147 Boys Bathroom L	04/18/25
25D0955-74	6663-HS-148 Boys Bathroom R	04/18/25
25D0955-75	6663-HS-149 Kitchen Sink Mic	04/18/25
BD51400-BLK1	Blank	04/18/25
BD51400-BS1	LCS	04/18/25
BD51400-MS2	Matrix Spike	04/18/25

Batch ID: ND50309 **Preparation Method:** METALS-200.8 **Prepared By:** DLW

YORK Sample ID	Client Sample ID	Preparation Date
25D0950-01	6663-A-01-Vestibule WF	04/18/25
25D0950-02	6663-A-02-Vestibule WF Bottle	04/18/25
25D0950-03	6663-A-03 Right WF	04/18/25
25D0950-04	6663-A-04 Right WF Bottle Fil	04/18/25
25D0950-05	6663-A-05 Boy's Locker Room	04/18/25
25D0950-06	6663-A-06 Boy's Locker Room	04/18/25
25D0950-07	6663-A-07 Boy's Locker Room	04/18/25
25D0950-08	6663-A-08 Girls Locker Room	04/18/25
25D0950-09	6663-A-09 Girls Locker Room	04/18/25
ND50309-BLK1	Blank	04/18/25
ND50309-BS1	LCS	04/18/25

Batch ID: ND50310 **Preparation Method:** METALS-200.8 **Prepared By:** DLW

YORK Sample ID	Client Sample ID	Preparation Date
25D0950-10	6663-A-10 Girls Locker Room	04/18/25
25D0950-11	6663-A-11 Gender Neutral	04/18/25
25D0950-12	6663-A-12 Girl's Bathroom Lef	04/18/25
25D0950-13	6663-A-13 Girl's Bathroom Rig	04/18/25
25D0950-14	6663-A-14 Boy's Bathroom Lef	04/18/25
25D0950-15	6663-A-15 Boy's Bathroom Rig	04/18/25
25D0950-16	6663-A-16 Water Fountain	04/18/25
25D0950-17	6663-A-17 Bottle Filler	04/18/25
25D0950-18	6663-A-18 Girl's Bathroom Lef	04/18/25
25D0950-19	6663-A-19 Girl's Bathroom Rig	04/18/25
25D0950-20	6663-A-20 Girl's Bathroom Lef	04/18/25
25D0950-21	6663-A-21 Girl's Bathroom Rig	04/18/25
25D0950-22	6663-A-22 Boy's Bathroom Lef	04/18/25
25D0950-23	6663-A-23 Boy's Bathroom Rig	04/18/25
25D0950-24	6663-A-24 Boy's Bathroom Lef	04/18/25
25D0950-25	6663-A-25 Boy's Bathroom Rig	04/18/25
25D0950-26	6663-A-26 Coach's Bathroom S	04/18/25
25D0950-27	6663-FEB-27 Main Floor Water	04/18/25
25D0950-28	6663-FEB-28 Main Floor WF E	04/18/25



25D0950-29	6663-FEB-29 Boy's Bathroom I	04/18/25
ND50310-BLK1	Blank	04/18/25
ND50310-BS1	LCS	04/18/25
ND50310-DUP1	Duplicate	04/18/25
ND50310-MS1	Matrix Spike	04/18/25
ND50310-MS2	Matrix Spike	04/18/25

Batch ID: ND50311 **Preparation Method:** METALS-200.8 **Prepared By:** DLW

YORK Sample ID	Client Sample ID	Preparation Date
25D0950-30	6663-FEB-30 Boy's Bathroom I	04/18/25
25D0950-31	6663-FEB-31 Girl's Bathroom I	04/18/25
25D0950-32	6663-FEB-32 Girl's Bathroom I	04/18/25
25D0950-33	6663-FEB-33 Nurse's Bathroon	04/18/25
25D0950-34	6663-FEB-34 Nurse's Sink	04/18/25
25D0950-35	6663-FEB-35 Dada Coordinato	04/18/25
25D0950-36	6663-FEB-36 3AC/EL Sink	04/18/25
25D0950-37	6663-FEB-37 3FK Sink	04/18/25
25D0950-38	6663-FEB-38 Room 207 Sink	04/18/25
25D0950-39	6663-FEB-39 Water Fountain	04/18/25
25D0950-40	6663-FEB-40 WF Bottle Fill	04/18/25
25D0950-41	6663-FEB-41 Kitchenette Sink	04/18/25
25D0950-42	6663-FEB-42 Room 203 Sink	04/18/25
25D0950-43	6663-FEB-43 Room 204	04/18/25
25D0950-44	6663-FEB-44 Gender Neutral E	04/18/25
25D0950-45	6663-FEB-45 2nd Fl Water Fou	04/18/25
25D0950-46	6663-FEB-46 2nd Fl WF Bottle	04/18/25
25D0950-47	6663-FEB-47 Boy's Bathroom I	04/18/25
25D0950-48	6663-FEB-48 Boy's Bathroom I	04/18/25
25D0950-49	6663-FEB-49 Room 308 Sink	04/18/25
ND50311-BLK1	Blank	04/18/25
ND50311-BS1	LCS	04/18/25
ND50311-DUP1	Duplicate	04/18/25
ND50311-MS1	Matrix Spike	04/18/25
ND50311-MS2	Matrix Spike	04/18/25

Batch ID: ND50312 **Preparation Method:** METALS-200.8 **Prepared By:** DLW

YORK Sample ID	Client Sample ID	Preparation Date
25D0950-50	6663-FEB-50 Water Fountain	04/18/25
25D0950-51	6663-FEB-51 WF Bottle Fill	04/18/25
25D0950-52	6663-FEB-52 Faculty Sink	04/18/25
25D0950-53	6663-FEB-53 Faculty Kitchene	04/18/25
25D0950-54	6663-FEB-54 Girl's Bathroom I	04/18/25
25D0950-55	6663-FEB-55 Girl's Bathroom I	04/18/25
25D0950-56	6663-FEB-56 BSMT Boy's BR	04/18/25
25D0950-57	6663-FEB-57 Boy's Bathroom I	04/18/25
25D0950-58	6663-FEB-58 Water Fountain	04/18/25
25D0950-59	6663-FEB-59 WF Bottle Fill	04/18/25
25D0950-60	6663-FEB-60 Room 103 Sink	04/18/25
25D0950-61	6663-FEB-61 Unnumbered Rm	04/18/25

25D0950-62	6663-FEB-62 Room w/ Little C	04/18/25
25D0950-63	6663-FEB-63 Water Fountain B	04/18/25
25D0950-64	6663-FEB-64 Water Fountain	04/18/25
25D0950-65	6663-FEB-65 Girl's Bathroom I	04/18/25
25D0950-66	6663-FEB-66 Girl's Mid Right	04/18/25
25D0950-67	6663-FEB-67 Girl's Right	04/18/25
25D0950-68	6663-FEB-68 Room 108	04/18/25
25D0950-69	6663-FEB-69 Across from 108	04/18/25
ND50312-BLK1	Blank	04/18/25
ND50312-BS1	LCS	04/18/25
ND50312-DUP1	Duplicate	04/18/25
ND50312-MS1	Matrix Spike	04/18/25
ND50312-MS2	Matrix Spike	04/18/25

Batch ID: ND50317 **Preparation Method:** METALS-200.8 **Prepared By:** DLW

YORK Sample ID	Client Sample ID	Preparation Date
25D0950-70	6663-FEB-70 Serving/Kitchen I	04/18/25
25D0950-71	6663-FEB-71 Serving/Kitchen I	04/18/25
25D0950-72	6663-FEB-72 Gender Neutral	04/18/25
25D0950-73	6663-FEB-73 Cafe Gender Neu	04/18/25
25D0950-74	6663-FEB-74 Cafe Gender Neu	04/18/25
ND50317-BLK1	Blank	04/18/25
ND50317-BS1	LCS	04/18/25

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc. - Stratford

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BD51216 - EPA 200.8											
Blank (BD51216-BLK1)								Prepared: 04/16/2025 Analyzed: 04/17/2025			
Lead	ND	1.00	ug/L								
Blank (BD51216-BLK2)								Prepared: 04/16/2025 Analyzed: 04/18/2025			
Lead	ND	1.00	ug/L								
LCS (BD51216-BS1)								Prepared: 04/16/2025 Analyzed: 04/17/2025			
Lead	65.3		ug/L	50.0		131	80-120	High Bias			
LCS (BD51216-BS2)								Prepared: 04/16/2025 Analyzed: 04/18/2025			
Lead	58.0		ug/L	50.0		116	80-120				
Duplicate (BD51216-DUP1)	*Source sample: 25D0952-54 (6663-MS-203 Girls Bathroom)							Prepared: 04/16/2025 Analyzed: 04/21/2025			
Lead	4.86	1.00	ug/L		4.79				1.44	20	
Matrix Spike (BD51216-MS1)	*Source sample: 25D0952-54 (6663-MS-203 Girls Bathroom)							Prepared: 04/16/2025 Analyzed: 04/21/2025			
Lead	61.3		ug/L	50.0	4.79	113	75-125				
Batch BD51229 - EPA 200.8											
Blank (BD51229-BLK1)								Prepared: 04/16/2025 Analyzed: 04/17/2025			
Lead	ND	1.00	ug/L								
LCS (BD51229-BS1)								Prepared: 04/16/2025 Analyzed: 04/17/2025			
Lead	52.0		ug/L	50.0		104	85-115				
Duplicate (BD51229-DUP1)	*Source sample: 25D0952-49 (6663-MS-198 A15 Gen Neutral Front)							Prepared: 04/16/2025 Analyzed: 04/17/2025			
Lead	4.68	1.00	ug/L		4.66				0.557	20	

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc. - Stratford

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BD51229 - EPA 200.8											
Matrix Spike (BD51229-MS1)	*Source sample: 25D0952-49 (6663-MS-198 A15 Gen Neutral Front)							Prepared: 04/16/2025 Analyzed: 04/17/2025			
Lead	60.3		ug/L	50.0	4.66	111	75-125				
Batch BD51302 - EPA 200.8											
Blank (BD51302-BLK1)								Prepared & Analyzed: 04/17/2025			
Lead	ND	1.00	ug/L								
LCS (BD51302-BS1)								Prepared & Analyzed: 04/17/2025			
Lead	51.7		ug/L	50.0		103	85-115				
Duplicate (BD51302-DUP1)	*Source sample: 25D0952-50 (6663-MS-199 A15 Gen Neutral Back)							Prepared & Analyzed: 04/17/2025			
Lead	3.16	1.00	ug/L		3.14				0.413	20	
Matrix Spike (BD51302-MS1)	*Source sample: 25D0952-50 (6663-MS-199 A15 Gen Neutral Back)							Prepared & Analyzed: 04/17/2025			
Lead	53.3		ug/L	50.0	3.14	100	75-125				
Batch BD51303 - EPA 200.8											
Blank (BD51303-BLK1)								Prepared & Analyzed: 04/17/2025			
Lead	ND	1.00	ug/L								
LCS (BD51303-BS1)								Prepared & Analyzed: 04/17/2025			
Lead	51.6		ug/L	50.0		103	85-115				
Duplicate (BD51303-DUP1)	*Source sample: 25D0952-28 (6663-HS-177 Principals Office BR)							Prepared & Analyzed: 04/17/2025			
Lead	2.29	1.00	ug/L		2.31				0.869	20	

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc. - Stratford

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BD51303 - EPA 200.8											
Matrix Spike (BD51303-MS1)	*Source sample: 25D0952-28 (6663-HS-177 Principals Office BR)							Prepared & Analyzed: 04/17/2025			
Lead	54.5		ug/L	50.0	2.31	104	75-125				
Matrix Spike (BD51303-MS2)	*Source sample: 25D0952-07 (6663-HS-156 Science Wing Gender Neutral)							Prepared & Analyzed: 04/17/2025			
Lead	54.0		ug/L	50.0	0.453	107	75-125				
Batch BD51304 - EPA 200.8											
Blank (BD51304-BLK1)								Prepared & Analyzed: 04/17/2025			
Lead	ND	1.00	ug/L								
LCS (BD51304-BS1)								Prepared & Analyzed: 04/17/2025			
Lead	52.3		ug/L	50.0		105	85-115				
Duplicate (BD51304-DUP1)	*Source sample: 25D0952-48 (6663-MS-197 6th Grade Wing Boys Right)							Prepared & Analyzed: 04/17/2025			
Lead	3.83	1.00	ug/L		3.85				0.469	20	
Matrix Spike (BD51304-MS1)	*Source sample: 25D0952-48 (6663-MS-197 6th Grade Wing Boys Right)							Prepared & Analyzed: 04/17/2025			
Lead	56.4		ug/L	50.0	3.85	105	75-125				
Matrix Spike (BD51304-MS2)	*Source sample: 25D0952-29 (6663-HS-178 Boys E Wing Right)							Prepared & Analyzed: 04/17/2025			
Lead	53.3		ug/L	50.0	1.01	105	75-125				
Batch BD51327 - EPA 200.8											
Blank (BD51327-BLK1)								Prepared: 04/17/2025 Analyzed: 04/18/2025			
Lead	ND	1.00	ug/L								

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc. - Stratford

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BD51327 - EPA 200.8											
Duplicate (BD51327-DUP1)	*Source sample: 25D0955-15 (6663-DWES-89 Room 113 Bathroom)								Prepared: 04/17/2025 Analyzed: 04/18/2025		
Lead	1.14	1.00	ug/L		1.14				0.350	20	
Matrix Spike (BD51327-MS1)	*Source sample: 25D0955-15 (6663-DWES-89 Room 113 Bathroom)								Prepared: 04/17/2025 Analyzed: 04/18/2025		
Lead	51.0		ug/L	50.0	1.14	99.6	75-125				
Matrix Spike (BD51327-MS2)	*Source sample: 25D0952-51 (6663-MS-200 C Corridor WF)								Prepared: 04/17/2025 Analyzed: 04/18/2025		
Lead	50.0		ug/L	50.0	0.279	99.5	75-125				
Batch BD51332 - EPA 200.8											
Blank (BD51332-BLK1)									Prepared: 04/17/2025 Analyzed: 04/21/2025		
Lead	ND	1.00	ug/L								
LCS (BD51332-BS1)									Prepared: 04/17/2025 Analyzed: 04/21/2025		
Lead	51.4		ug/L	50.0		103	80-120				
Batch BD51383 - EPA 200.8											
Blank (BD51383-BLK1)									Prepared & Analyzed: 04/18/2025		
Lead	ND	1.00	ug/L								
LCS (BD51383-BS1)									Prepared & Analyzed: 04/18/2025		
Lead	52.2		ug/L	50.0		104	85-115				
Duplicate (BD51383-DUP1)	*Source sample: 25D0955-36 (6663-DWES-110 Room 304 Sink)								Prepared & Analyzed: 04/18/2025		
Lead	ND	1.00	ug/L		ND					20	

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc. - Stratford

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BD51383 - EPA 200.8											
Matrix Spike (BD51383-MS1)	*Source sample: 25D0955-36 (6663-DWES-110 Room 304 Sink)							Prepared & Analyzed: 04/18/2025			
Lead	51.3		ug/L	50.0	0.386	102	75-125				
Matrix Spike (BD51383-MS2)	*Source sample: 25D0955-17 (6663-DWES-91 Room 113 Sink)							Prepared & Analyzed: 04/18/2025			
Lead	51.6		ug/L	50.0	0.763	102	75-125				
Batch BD51390 - EPA 200.8											
Blank (BD51390-BLK1)								Prepared & Analyzed: 04/18/2025			
Lead	ND	1.00	ug/L								
LCS (BD51390-BS1)								Prepared & Analyzed: 04/18/2025			
Lead	52.3		ug/L	50.0		105	85-115				
Duplicate (BD51390-DUP1)	*Source sample: 25D0955-56 (6663-DWES-130 Room 201 WF)							Prepared & Analyzed: 04/18/2025			
Lead	ND	1.00	ug/L		ND					20	
Matrix Spike (BD51390-MS1)	*Source sample: 25D0955-56 (6663-DWES-130 Room 201 WF)							Prepared & Analyzed: 04/18/2025			
Lead	52.4		ug/L	50.0	0.269	104	75-125				
Matrix Spike (BD51390-MS2)	*Source sample: 25D0955-37 (6663-DWES-111 Room 306 Sink)							Prepared & Analyzed: 04/18/2025			
Lead	52.3		ug/L	50.0	0.355	104	75-125				
Batch BD51400 - EPA 200.8											
Blank (BD51400-BLK1)								Prepared & Analyzed: 04/18/2025			
Lead	ND	1.00	ug/L								

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc. - Stratford

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BD51400 - EPA 200.8											
LCS (BD51400-BS1)								Prepared & Analyzed: 04/18/2025			
Lead	52.2		ug/L	50.0		104	85-115				
Matrix Spike (BD51400-MS2)	*Source sample: 25D0955-57 (6663-DWES-131 Room 206 Sink)							Prepared & Analyzed: 04/18/2025			
Lead	51.8		ug/L	50.0	0.649	102	75-125				
Batch ND50309 - METALS-200.8											
Blank (ND50309-BLK1)								Prepared & Analyzed: 04/18/2025			
Lead	ND	1.00	ug/L								
LCS (ND50309-BS1)								Prepared & Analyzed: 04/18/2025			
Lead	23.1	1.05	ug/L	26.3		87.9	85-115				
Batch ND50310 - METALS-200.8											
Blank (ND50310-BLK1)								Prepared & Analyzed: 04/18/2025			
Lead	ND	1.00	ug/L								
LCS (ND50310-BS1)								Prepared & Analyzed: 04/18/2025			
Lead	24.0	1.05	ug/L	26.3		91.1	85-115				
Duplicate (ND50310-DUP1)	*Source sample: 25D0950-10 (6663-A-10 Girls Locker Room Right)							Prepared & Analyzed: 04/18/2025			
Lead	7.78	1.00	ug/L		7.92				1.79	20	
Matrix Spike (ND50310-MS1)	*Source sample: 25D0950-10 (6663-A-10 Girls Locker Room Right)							Prepared & Analyzed: 04/18/2025			
Lead	31.0	1.05	ug/L	26.3	7.92	87.9	70-130				

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc. - Stratford

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch ND50310 - METALS-200.8											
Matrix Spike (ND50310-MS2)	*Source sample: 25D0950-11 (6663-A-11 Gender Neutral)							Prepared & Analyzed: 04/18/2025			
Lead	25.7	1.05	ug/L	26.3	2.63	87.5	70-130				
Batch ND50311 - METALS-200.8											
Blank (ND50311-BLK1)								Prepared & Analyzed: 04/18/2025			
Lead	ND	1.00	ug/L								
LCS (ND50311-BS1)								Prepared & Analyzed: 04/18/2025			
Lead	23.6	1.05	ug/L	26.3		89.8	85-115				
Duplicate (ND50311-DUP1)	*Source sample: 25D0950-30 (6663-FEB-30 Boy's Bathroom Right)							Prepared & Analyzed: 04/18/2025			
Lead	0.950	1.00	ug/L		0.976				2.74	20	
Matrix Spike (ND50311-MS1)	*Source sample: 25D0950-30 (6663-FEB-30 Boy's Bathroom Right)							Prepared & Analyzed: 04/18/2025			
Lead	24.5	1.05	ug/L	26.3	0.976	89.2	70-130				
Matrix Spike (ND50311-MS2)	*Source sample: 25D0950-31 (6663-FEB-31 Girl's Bathroom Left)							Prepared & Analyzed: 04/18/2025			
Lead	23.9	1.05	ug/L	26.3	ND	90.9	70-130				
Batch ND50312 - METALS-200.8											
Blank (ND50312-BLK1)								Prepared & Analyzed: 04/18/2025			
Lead	ND	1.00	ug/L								
LCS (ND50312-BS1)								Prepared & Analyzed: 04/18/2025			
Lead	24.1	1.05	ug/L	26.3		91.4	85-115				

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc. - Stratford

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch ND50312 - METALS-200.8											
Duplicate (ND50312-DUP1)	*Source sample: 25D0950-50 (6663-FEB-50 Water Fountain)							Prepared & Analyzed: 04/18/2025			
Lead	ND	1.00	ug/L		ND					20	
Matrix Spike (ND50312-MS1)	*Source sample: 25D0950-50 (6663-FEB-50 Water Fountain)							Prepared & Analyzed: 04/18/2025			
Lead	24.0	1.05	ug/L	26.3	ND	91.3	70-130				
Matrix Spike (ND50312-MS2)	*Source sample: 25D0950-51 (6663-FEB-51 WF Bottle Fill)							Prepared & Analyzed: 04/18/2025			
Lead	23.7	1.05	ug/L	26.3	ND	90.1	70-130				
Batch ND50317 - METALS-200.8											
Blank (ND50317-BLK1)								Prepared: 04/18/2025 Analyzed: 04/21/2025			
Lead	ND	1.00	ug/L								
LCS (ND50317-BS1)								Prepared: 04/18/2025 Analyzed: 04/21/2025			
Lead	25.1	1.05	ug/L	26.3		95.4	85-115				

Sample and Data Qualifiers Relating to This Work Order

M-PbEX Lead result exceeds regulatory limit

M-CCV1 The recovery for this element in the Continuing Calibration Verification (CCV) was outside the 90-110% recovery criteria.

Definitions and Other Explanations

*	Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
ND	NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
RL	REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
LOQ	LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon NELAC 2009 Standards and applies to all analyses.
LOD	LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW-846.
MDL	METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
Reported to	This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
NR	Not reported
RPD	Relative Percent Difference
Wet	The data has been reported on an as-received (wet weight) basis
Low Bias	Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
High Bias	High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
Non-Dir.	Non-dir. flag (Non-Directional Bias) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.

If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.

For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0950

Page _____ of _____

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact: Angela Holzapfel
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256663 Rye Neck UFSD - Athletic/FEB 1

PO Number:

Samples Collected From: NY X CT Other: (please specify) / NJ PA

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-A-01 Vestibule WF	4/12/25	7:08	DW				X							X	G/C
6663-A-02 Vestibule WF Bottle Fill	4/12/25	7:08	DW				X							X	G/C
6663-A-03 Right WF	4/12/25	7:09	DW				X							X	G/C
6663-A-04 Right WF Bottle Fill	4/12/25	7:09	DW				X							X	G/C
6663-A-05 Boy's Locker Room Left	4/12/25	7:17	DW				X							X	G/C
6663-A-06 Boy's Locker Room Center	4/12/25	7:17	DW				X							X	G/C
6663-A-07 Boy's Locker Room Right	4/12/25	7:11	DW				X							X	G/C
6663-A-08 Girl's Locker Room Left	4/12/25	7:13	DW				X							X	G/C
6663-A-09 Girl's Locker Room Center	4/12/25	7:13	DW				X							X	G/C
6663-A-10 Girl's Locker Room Right	4/12/25	7:13	DW				X							X	G/C
6663-A-11 Gender Neutral	4/12/25	7:27	DW				X							X	G/C
6663-A-12 Girl's Bathroom Left	4/12/25	7:30	DW				X							X	G/C
6663-A-13 Girl's Bathroom Right	4/12/25	7:30	DW				X							X	G/C
6663-A-14 Boy's Bathroom Left	4/12/25	7:31	DW				X							X	G/C
6663-A-15 Boy's Bathroom Right	4/12/25	7:31	DW				X							X	G/C

Turn-Around Time

- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) X
- PFAS Standard 7-10 Day

Report Type (circle)

- QA Report
- Summary (Results Only)
- NY ASP B Package
- NJ Reduced
- NJ DKQP
- NJ Full
- CT RCP

EDD Type (circle)

- EQuIS (standard)
- NYSDEC EQuIS
- NJDEP SRP Haz Site
- Standard Excel
- CMDP
- Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

- Field Filtered
- Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y (N) Containers Intact: (Y) / N COC/Labels Agree: (Y) / N Preservation Confirmed: (Y) / N
COC Complete: (Y) / N COC Received: (Y) / N Appropriate Sample Volumes: (Y) / N Appropriate Sample Containers: (Y) / N
Cooler Temperature Confirmed: (Y) / N Samples Submitted within Holding Times: (Y) / N Corrective Action Form Required: Y / (N)

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
QuES&T	4/14/25 14:30	Chris C	4-15-25 8:45	Chris C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
				[signature]	4-15-25 1510 / Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0950

Page ____ of ____

Report To:	Invoice To:	YOUR Project Name / Number
Company: QuES&T	Company: Same	256663 Rye Neck UFSD - Athletic/FEB 1
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:	PO Number
Phone.: 845-298-6031	Phone.:	
Contact: Zach Timpano	Contact: Angela Holzapfel	
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com	

Samples Collected From: NY X, NJ, CT, PA, Other: (please specify)

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-A-16 Water Fountain	4/12/25	7:32	DW				X							X	G/C
6663-A-17 Bottle Filler	4/12/25	7:32	DW				X							X	G/C
6663-A-18 Girl's Bathroom Left 1	4/12/25	7:36	DW				X							X	G/C
6663-A-19 Girl's Bathroom Right 1	4/12/25	7:36	DW				X							X	G/C
6663-A-20 Girl's Bathroom Left 2	4/12/25	7:36	DW				X							X	G/C
6663-A-21 Girl's Bathroom Right 2	4/12/25	7:36	DW				X							X	G/C
6663-A-22 Boy's Bathroom Left 1	4/12/25	7:38	DW				X							X	G/C
6663-A-23 Boy's Bathroom Right 1	4/12/25	7:38	DW				X							X	G/C
6663-A-24 Boy's Bathroom Left 2	4/12/25	7:38	DW				X							X	G/C
6663-A-25 Boy's Bathroom Right 2	4/12/25	7:38	DW				X							X	G/C
6663-A-26 Coach's Bathroom Sink	4/12/25	7:39	DW				X							X	G/C
6663-FEB-27 Main Floor Water Fountain	4/12/25	7:54	DW				X							X	G/C
6663-FEB-28 Main Floor WF Bottle Fill	4/12/25	7:54	DW				X							X	G/C
6663-FEB-29 Boy's Bathroom Left	4/12/25	7:55	DW				X							X	G/C
6663-FEB-30 Boy's Bathroom Right	4/12/25	7:55	DW				X							X	G/C

Turn-Around Time

- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) X
- PFAS Standard 7-10 Day

Report Type (circle)

- QA Report
- Summary (Results Only)
- NY ASP B Package
- NJ Reduced
- NJ DKQP
- NJ Full
- CT RCP

EDD Type (circle)

- EQuIS (standard)
- NYSDEC EQuIS
- NJDEP SRP Haz Site
- Standard Excel
- CMDP
- Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

Field Filtered

Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y (N) Containers Intact: (Y) / N COC/Labels Agree: (Y) / N Preservation Confirmed: (Y) / N
COC Complete (Y) / N COC Received: (Y) / N Appropriate Sample Volumes: (Y) / N Appropriate Sample Containers: (Y) / N
Cooler Temperature Confirmed: (Y) / N Samples Submitted within Holding Times: (Y) / N Corrective Action Form Required: Y (N)

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
QuES&T	4/14/25 14:30	Chris C	4-15-25 8:45	Chris C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
					4-15-25 1510 Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0950

Page _____ of _____

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact: Angela Holzapfel
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256663 Rye Neck UFSD - Athletic/FEB 1

PO Number:

Samples Collected From: NY X, NJ, CT, PA, Other: (please specify)

Analyses Requested

Turn-Around Time: RUSH - Next Day; RUSH - Two Day; RUSH - Three Day; RUSH - Four Day; RUSH - Five Day; Standard (6-9 Day) X; PFAS Standard 7-10 Day

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp. G/C
6663-FEB-31 Girl's Bathroom Left	4/12/25	7:57	DW				X							X	
6663-FEB-32 Girl's Bathroom Right	4/12/25	7:57	DW				X							X	
6663-FEB-33 Nurse's Bathroom	4/12/25	7:58	DW				X							X	
6663-FEB-34 Nurse's Sink	4/12/25	7:59	DW				X							X	
6663-FEB-35 Dada Coordinator's Office	4/12/25	8:04	DW				X							X	
6663-FEB-36 3AC/EL Sink	4/12/25	8:05	DW				X							X	
6663-FEB-37 3FK Sink	4/12/25	8:06	DW				X							X	
6663-FEB-38 Room 207 Sink	4/12/25	8:06	DW				X							X	
6663-FEB-39 Water Fountain	4/12/25	8:11	DW				X							X	
6663-FEB-40 WF Bottle Fill	4/12/25	8:11	DW				X							X	
6663-FEB-41 Kitchenette Sink	4/12/25	8:04	DW				X							X	
6663-FEB-42 Room 203 Sink	4/12/25	8:07	DW				X							X	
6663-FEB-43 Room 204	4/12/25	8:08	DW				X							X	
6663-FEB-44 Gender Neutral Bathroom	4/12/25	8:15	DW				X							X	
6663-FEB-45 2nd Fl Water Fountain	4/12/25	8:17	DW				X							X	

Report Type (circle): QA Report; Summary (Results Only); NY ASP B Package; NJ Reduced; NJ DKQP; NJ Full; CT RCP

EDD Type (circle): EQuIS (standard); NYSDEC EQuIS; NJDEP SRP Haz Site; Standard Excel; CMDP; Other:

Regulatory Comparative: Compared to the following Regulation(s): (please fill in)

Field Filtered

Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N

COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N

Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
QuES&T	4/14/25 14:30	Chris C	4-15-25 8:45	Chris C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
					4-15-25 1510 Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0950

Page _____ of _____

Report To:	Invoice To:	YOUR Project Name / Number
Company: QuES&T	Company: Same	256663 Rye Neck UFSD - FEB 1
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:	
Phone.: 845-298-6031	Phone.:	PO Number
Contact: Zach Timpano	Contact: Angela Holzapfel	
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com	

Samples Collected From: NY X | CT | NJ | PA | Other: (please specify)

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-FEB-46 2nd Fl WF Bottle Fill	4/12/25	8:17	DW				X							X	G/C
6663-FEB-47 Boy's Bathroom Right	4/12/25	8:20	DW				X							X	G/C
6663-FEB-48 Boy's Bathroom Left	4/12/25	8:20	DW				X							X	G/C
6663-FEB-49 Room 308 Sink	4/12/25	8:18	DW				X							X	G/C
6663-FEB-50 Water Fountain	4/12/25	8:20	DW				X							X	G/C
6663-FEB-51 WF Bottle Fill	4/12/25	8:20	DW				X							X	G/C
6663-FEB-52 Faculty Sink	4/12/25	8:21	DW				X							X	G/C
6663-FEB-53 Faculty Kitchenette	4/12/25	8:22	DW				X							X	G/C
6663-FEB-54 Girl's Bathroom Left	4/12/25	8:23	DW				X							X	G/C
6663-FEB-55 Girl's Bathroom Right	4/12/25	8:23	DW				X							X	G/C
6663-FEB-56 BSMT Boy's BR Left	4/12/25	8:28	DW				X							X	G/C
6663-FEB-57 Boy's Bathroom Right	4/12/25	8:28	DW				X							X	G/C
6663-FEB-58 Water Fountain	4/12/25	8:29	DW				X							X	G/C
6663-FEB-59 WF Bottle Fill	4/12/25	8:29	DW				X							X	G/C
6663-FEB-60 Room 103 Sink	4/12/25	8:34	DW				X							X	G/C

Turn-Around Time

- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) X
- PFAS Standard 7-10 Day

Report Type (circle)

QA Report (circled)
Summary (Results Only)
NY ASP B Package
NJ Reduced
NJ DKQP
NJ Full
CT RCP

EDD Type (circle)

EQuIS (standard) (circled)
NYSDEC EQuIS
NJDEP SRP Haz Site
Standard Excel
CMDP
Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

Field Filtered
Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y (N) Containers Intact: (Y) / N COC/Labels Agree: (Y) / N Preservation Confirmed: (Y) / N
COC Complete: (Y) / N COC Received: (Y) / N Appropriate Sample Volumes: (Y) / N Appropriate Sample Containers: (Y) / N
Cooler Temperature Confirmed: (Y) / N Samples Submitted within Holding Times: (Y) / N Corrective Action Form Required: Y / (N)

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
Client Request	4/14/25 14:30	Chris C	4-15-25 8:45	Chris C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
				[signature]	4-15-25 1510 / Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0950

Page ____ of ____

Report To:	Invoice To:	YOUR Project Name / Number
Company: QuES&T	Company: Same	256663 Rye Neck UFSD - FEB 1
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:	
Phone.: 845-298-6031	Phone.:	PO Number
Contact: Zach Timpano	Contact: Angela Holzapfel	
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com	

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Samples Collected From: NY X; NJ; CT; PA; Other: (please specify)

Analyses Requested

Preservative (please list number of containers)

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-FEB-61 Unnumbered Rm End of Hall	4/12/25	8:35	DW				X							X	G/C
6663-FEB-62 Room w/ Little Corridor	4/12/25	8:37	DW				X							X	G/C
6663-FEB-63 Water Fountain BF	4/12/25	8:30	DW				X							X	G/C
6663-FEB-64 Water Fountain	4/12/25	8:30	DW				X							X	G/C
6663-FEB-65 Girl's Bathroom Left	4/12/25	8:34	DW				X							X	G/C
6663-FEB-66 Girl's Mid Right	4/12/25	8:34	DW				X							X	G/C
6663-FEB-67 Girl's Right	4/12/25	8:34	DW				X							X	G/C
6663-FEB-68 Room 108	4/12/25	8:37	DW				X							X	G/C
6663-FEB-69 Across from 108	4/12/25	8:40	DW				X							X	G/C
6663-FEB-70 Serving/Kitchen Left	4/12/25	8:50	DW				X							X	G/C
6663-FEB-71 Serving/Kitchen Right	4/12/25	8:50	DW				X							X	G/C
6663-FEB-72 Gender Neutral	4/12/25	8:51	DW				X							X	G/C
6663-FEB-73 Café Gender Neutral Right	4/12/25	8:52	DW				X							X	G/C
6663-FEB-74 Café Gender Neutral Left	4/12/25	8:52	DW				X							X	G/C

Turn-Around Time: RUSH - Next Day; RUSH - Two Day; RUSH - Three Day; RUSH - Four Day; RUSH - Five Day; Standard (6-9 Day) X; PFAS Standard 7-10 Day

Report Type (circle): QA Report; Summary (Results Only); NY ASP B Package; NJ Reduced; NJ DKQP; NJ Full; CT RCP

EDD Type (circle): EQuIS (standard); NYSDEC EQuIS; NJDEP SRP Haz Site; Standard Excel; CMDP; Other:

Regulatory Comparative: Compared to the following Regulation(s): (please fill in)

Field Filtered

Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N

COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N

Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
QuES&T	4/14/25 14:30	Chris C	4-15-25 8:45	Chris C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
					4-15-25 1510 Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0952

Page ____ of ____

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact: Angela Holzapfel
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256663 Rye Neck UFSD - HS 1

PO Number:

Samples Collected From: NY X | CT | Other: (please specify) | NJ | PA

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-HS-150 Kitchen Hand Wash Sink	4/12/25	10:27	DW				X							X	G/C
6663-HS-151 Kitchen Bathroom	4/12/25	10:28	DW				X							X	
6663-HS-152 Kitchen Sink Right	4/12/25	10:29	DW				X							X	
6663-HS-153 Kitchen Sink Left	4/12/25	10:29	DW				X							X	
6663-HS-154 Back Kitchen Handwash	4/12/25	10:30	DW				X							X	
6663-HS-155 Back Kitchen Sink	4/12/25	10:31	DW				X							X	
6663-HS-156 Science Wing Gender Neutral	4/12/25	10:35	DW				X							X	
6663-HS-157 Sci Wing Girl's Left	4/12/25	10:36	DW				X							X	
6663-HS-158 Sci Wing Girl's Right	4/12/25	10:37	DW				X							X	
6663-HS-159 Sci Wing Boy's Left	4/12/25	10:37	DW				X							X	
6663-HS-160 Sci Wing Boy's Right	4/12/25	10:37	DW				X							X	
6663-HS-161 WF Bottle Fill o/s 124	4/12/25	10:38	DW				X							X	
6663-HS-162 WF o/s 124	4/12/25	10:38	DW				X							X	
6663-HS-163 2nd Fl Sci Wing Girls Left	4/12/25	10:43	DW				X							X	
6663-HS-164 2nd Fl Sci Wing Girls Mid	4/12/25	10:43	DW				X							X	

Turn-Around Time

- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) X
- PFAS Standard 7-10 Day

Report Type (circle)

- QA Report
- Summary (Results Only)
- NY ASP B Package
- NJ Reduced
- NJ DKQP
- NJ Full
- CT RCP

EDD Type (circle)

- EQuIS (standard)
- NYSDEC EQuIS
- NJDEP SRP Haz Site
- Standard Excel
- CMDP
- Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

- Field Filtered
- Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
QuES&T	4/14/25 14:30	Chris C	4-15-25 8:45	Chris C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
					4-15-25 1510 Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0952

Page _____ of _____

Report To:	Invoice To:	YOUR Project Name / Number
Company: QuES&T	Company: Same	256663 Rye Neck UFSD- HS 1
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:	PO Number
Phone.: 845-298-6031	Phone.:	
Contact: Zach Timpano	Contact: Angela Holzapfel	
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com	

Samples Collected From: NY X | NJ | CT | PA | Other: (please specify)

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-HS-165 2nd Fl Sci Wing Girl's Right	4/12/25	10:43	DW				X							X	G/C
6663-HS-166 2nd Fl Sci Wing Gen Neutral	4/12/25	10:42	DW				X							X	G/C
6663-HS-167 2nd Fl Sci Wing Boys Right	4/12/25	10:42	DW				X							X	G/C
6663-HS-168 2nd Fl Sci Wing Boys Mid	4/12/25	10:42	DW				X							X	G/C
6663-HS-169 2nd Fl Sci Wing Boys Left	4/12/25	10:42	DW				X							X	G/C
6663-HS-170 2nd Fl Sci Wing BF	4/12/25	10:48	DW				X							X	G/C
6663-HS-171 2nd Fl Sci Wing WF	4/12/25	10:48	DW				X							X	G/C
6663-HS-172 WF Outside Nurse	4/12/25	10:51	DW				X							X	G/C
6663-HS-173 BF Outside Nurse	4/12/25	10:51	DW				X							X	G/C
6663-HS-174 Nurse Room 1	4/12/25	10:51	DW				X							X	G/C
6663-HS-175 Nurse Bathroom	4/12/25	10:52	DW				X							X	G/C
6663-HS-176 Mail Room Sink	4/12/25	10:52	DW				X							X	G/C
6663-HS-177 Principal's Office BR	4/12/25	10:53	DW				X							X	G/C
6663-HS-178 Boy's E Wing Right	4/12/25	10:55	DW				X							X	G/C
6663-HS-179 Boy's E Wing Left	4/12/25	10:55	DW				X							X	G/C

Analyses Requested

Turn-Around Time

- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) X
- PFAS Standard 7-10 Day

Report Type (circle)

- QA Report
- Summary (Results Only)
- NY ASP B Package
- NJ Reduced
- NJ DKQP
- NJ Full
- CT RCP

EDD Type (circle)

- EQuIS (standard)
- NYSDEC EQuIS
- NJDEP SRP Haz Site
- Standard Excel
- CMDP
- Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

- Field Filtered
- Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

1. Samples Relinquished by / Company: QuES&T Date/Time: 4/14/25 14:30	1. Samples Received by / Company: Chris C Date/Time: 4-15-25 8:45	2. Samples Relinquished by / Company: Chris C Date/Time: 4-15-25 1510
2. Samples Received by / Company: Date/Time:	3. Samples Relinquished by / Company: Date/Time:	3. Samples Received by / Company: Date/Time:
4. Samples Relinquished by / Company: Date/Time:	4. Samples Received by / Company: Date/Time:	Samples Received in LAB by: Date/Time: 4-15-20 1510 Temperature: Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0952

Page ____ of ____

Report To:	Invoice To:	YOUR Project Name / Number
Company: QuES&T	Company: Same	256663 Rye Neck UFSD- HS 2/MS 1
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:	PO Number
Phone.: 845-298-6031	Phone.:	
Contact: Zach Timpano	Contact: Angela Holzapfel	
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com	

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes

S - soil/solid/sludge
GW - groundwater
DW - drinking water
SW - surface water
WW - wastewater
O - Oil
Other

Samples Collected From

NY X CT
NJ PA
Other: (please specify)

Turn-Around Time

RUSH - Next Day
RUSH - Two Day
RUSH - Three Day
RUSH - Four Day
RUSH - Five Day
Standard (6-9 Day) X
PFAS Standard 7-10 Day

Report Type (circle)

(QA Report)
Summary (Results Only)
NY ASP B Package
NJ Reduced
NJ DKQP
NJ Full
G/C CT RCP

EDD Type (circle)

(EQuIS (standard))
NYSDEC EQuIS
NJDEP SRP Haz Site
Standard Excel
CMDP
Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-HS-180 E Wing Teacher BR 1	4/12/25	10:54	DW				X							X	G
6663-HS-181 E Wing Teacher BR 2	4/12/25	10:55	DW				X							X	G
6663-HS-182 E Wing Girl's BR Left	4/12/25	10:56	DW				X							X	G
6663-HS-183 E Wing Girl's BR Mid	4/12/25	10:56	DW				X							X	G
6663-HS-184 E Wing Girl's BR Right	4/12/25	10:56	DW				X							X	G
6663-MS-185 A Corridor WF	4/12/25	11:03	DW				X							X	G
6663-MS-186 A Corridor BF	4/12/25	11:03	DW				X							X	G
6663-MS-187 B Corridor Boy's Left	4/12/25	11:04	DW				X							X	G
6663-MS-188 B Corridor Boy's Right	4/12/25	11:04	DW				X							X	G
6663-MS-189 B Corridor Girl's Left	4/12/25	11:06	DW				X							X	G
6663-MS-190 B Corridor Girl's Mid	4/12/25	11:06	DW				X							X	G
6663-MS-191 B Corridor Girl's Right	4/12/25	11:06	DW				X							X	G
6663-MS-192 6th Grade Wing Girl's Right	4/12/25	11:04	DW				X							X	G
6663-MS-193 6th Grade Wing Girl's Left	4/12/25	11:04	DW				X							X	G
6663-MS-194 6th Grade Wing WF	4/12/25	11:05	DW				X							X	G

Field Filtered
Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / (N) Containers Intact: (Y) / N COC/Labels Agree: (Y) / N Preservation Confirmed: (Y) / N
COC Complete: (Y) / N COC Received: (Y) / N Appropriate Sample Volumes: (Y) / N Appropriate Sample Containers: (Y) / N
Cooler Temperature Confirmed: (Y) / N Samples Submitted within Holding Times: (Y) / N Corrective Action Form Required: Y (N)

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
Quest	4/14/25 14:30	Chris C	4-15-25 8:45	Chris C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
				[signature]	4-15-25 1510 / Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0952

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact: Angela Holzapfel
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256663 Rye Neck UFSD - MS 1

PO Number:

Samples Collected From: NY X CT Other: (please specify) / NJ PA

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Turn-Around Time: RUSH - Next Day; RUSH - Two Day; RUSH - Three Day; RUSH - Four Day; RUSH - Five Day; Standard (6-9 Day) X; PFAS Standard 7-10 Day

Report Type (circle): QA Report; Summary (Results Only); NY ASP B Package; NJ Reduced; NJ DKQP; NJ Full; CT RCP

EDD Type (circle): EQuIS (standard); NYSDEC EQuIS; NJDEP SRP Haz Site; Standard Excel; CMDP; Other:

Regulatory Comparative: Compared to the following Regulation(s): (please fill in)

Preservative (please list number of containers)

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp. G/C
6663-MS-195 6th Grade Wing BF	4/12/25	11:05	DW				X							X	
6663-MS-196 6th Grade Wing Boy's Left	4/12/25	11:07	DW				X							X	
6663-MS-197 6th Grade Wing Boy's Right	4/12/25	11:07	DW				X							X	
6663-MS-198 A15 Gen Neutral Front	4/12/25	11:08	DW				X							X	
6663-MS-199 A15 Gen Neutral Back	4/12/25	11:09	DW				X							X	
6663-MS-200 C Corridor WF	4/12/25	11:13	DW				X							X	
6663-MS-201 C Corridor BF	4/12/25	11:13	DW				X							X	
6663-MS-202 Girl's Bathroom	4/12/25	11:14	DW				X							X	
6663-MS-203 Boy's Bathroom	4/12/25	11:14	DW				X							X	
6663-MS-204 Water Fountain	4/12/25	11:16	DW				X							X	
6663-MS-205 Bottle Fill	4/12/25	11:16	DW				X							X	

Field Filtered

Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N

COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N

Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
QuES&T	4/14/25 14:30	Cheri C	4-15-25 8:45	Cheri C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time 4-15-25 1510 Temperature Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0955

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact: Angela Holzapfel
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256663 Rye Neck UFSD - DWES 1

PO Number:

Samples Collected From: NY X | CT | Other: (please specify) | NJ | PA

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-DWES-75 Ground Floor WF	4/12/25	9:07	DW				X							X	G/C
6663-DWES-76 WF Bottle Fill	4/12/25	9:07	DW				X							X	G/C
6663-DWES-77 Boy's Bathroom Right	4/12/25	9:07	DW				X							X	G/C
6663-DWES-78 Boy's Bathroom Left	4/12/25	9:07	DW				X							X	G/C
6663-DWES-79 Room 110 Sink	4/12/25	9:09	DW				X							X	G/C
6663-DWES-80 Room 110 WF	4/12/25	9:09	DW				X							X	G/C
6663-DWES-81 Room 117 Bathroom	4/12/25	9:11	DW				X							X	G/C
6663-DWES-82 Room 117 WF	4/12/25	9:12	DW				X							X	G/C
6663-DWES-83 Room 117 Sink	4/12/25	9:12	DW				X							X	G/C
6663-DWES-84 Room 110 Bathroom	4/12/25	9:15	DW				X							X	G/C
6663-DWES-85 Room 111 Sink	4/12/25	9:09	DW				X							X	G/C
6663-DWES-86 Girl's Bathroom Left	4/12/25	9:08	DW				X							X	G/C
6663-DWES-87 Girl's Bathroom Right	4/12/25	9:13	DW				X							X	G/C
6663-DWES-88 WF BF by Resource rm	4/12/25	9:18	DW				X							X	G/C
6663-DWES-89 Room 113 Bathroom	4/12/25	9:18	DW				X							X	G/C

Turn-Around Time

- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) X
- PFAS Standard 7-10 Day

Report Type (circle)

- QA Report
- Summary (Results Only)
- NY ASP B Package
- NJ Reduced
- NJ DKQP
- NJ Full
- CT RCP

EDD Type (circle)

- EQuIS (standard)
- NYSDEC EQuIS
- NJDEP SRP Haz Site
- Standard Excel
- CMDP
- Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

- Field Filtered
- Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
QuES&T	4/14/25 14:30	Chris C	4-15-25 8:45	Chris C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
					4-15-25 1510 Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0955

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact: Angela Holzapfel
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256663 Rye Neck UFSD - DWES 1

PO Number:

Samples Collected From: NY X | CT | Other: (please specify) | NJ | PA

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-DWES-90 Room 113 WF	4/12/25	9:18	DW				X							X	G/C
6663-DWES-91 Room 113 Sink	4/12/25	9:18	DW				X							X	G/C
6663-DWES-92 Room 134 Bathroom	4/12/25	9:20	DW				X							X	G/C
6663-DWES-93 Room 134 Sink	4/12/25	9:20	DW				X							X	G/C
6663-DWES-94 3rd Floor Rm 308 Sink	4/12/25	9:28	DW				X							X	G/C
6663-DWES-95 Room 308 WF	4/12/25	9:28	DW				X							X	G/C
6663-DWES-96 Girl's Bathroom Left	4/12/25	9:30	DW				X							X	G/C
6663-DWES-97 Girl's Bathroom Right	4/12/25	9:30	DW				X							X	G/C
6663-DWES-98 Room 302 Sink	4/12/25	9:29	DW				X							X	G/C
6663-DWES-99 Room 300 Sink	4/12/25	9:30	DW				X							X	G/C
6663-DWES-100 Water Fountain	4/12/25	9:32	DW				X							X	G/C
6663-DWES-101 WF Bottle Fill	4/12/25	9:32	DW				X							X	G/C
6663-DWES-102 Boy's Bathroom Left	4/12/25	9:34	DW				X							X	G/C
6663-DWES-103 Boy's Bathroom Right	4/12/25	9:34	DW				X							X	G/C
6663-DWES-104 Room 300 WF	4/12/25	9:38	DW				X							X	G/C

Turn-Around Time

- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) X
- PFAS Standard 7-10 Day

Report Type (circle)

- QA Report
- Summary (Results Only)
- NY ASP B Package
- NJ Reduced
- NJ DKQP
- NJ Full
- CT RCP

EDD Type (circle)

- EQuIS (standard)
- NYSDEC EQuIS
- NJDEP SRP Haz Site
- Standard Excel
- CMDP
- Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

- Field Filtered
- Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

1. Samples Relinquished by / Company: QuES&T Date/Time: 4/14/25 14:30	1. Samples Received by / Company: Chris C Date/Time: 4-15-25 8:45	2. Samples Relinquished by / Company: Chris C Date/Time: 4-15-25 1510
2. Samples Received by / Company: Date/Time:	3. Samples Relinquished by / Company: Date/Time:	3. Samples Received by / Company: Date/Time:
4. Samples Relinquished by / Company: Date/Time:	4. Samples Received by / Company: Date/Time:	Samples Received in LAB by: Date/Time: 4-15-25 1510 Temperature Degrees C: 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0955

Page _____ of _____

Report To:	Invoice To:	YOUR Project Name / Number
Company: QuES&T	Company: Same	256663 Rye Neck UFSD - DWES 1
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:	
Phone.: 845-298-6031	Phone.:	PO Number
Contact: Zach Timpano	Contact: Angela Holzapfel	
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com	

Samples Collected From: NY X | NJ | CT | PA | Other: (please specify)

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-DWES-105 Room 303	4/12/25	9:32	DW				X							X	G/C
6663-DWES-106 Room 303 WF	4/12/25	9:32	DW				X							X	G/C
6663-DWES-107 Room 301 Sink	4/12/25	9:33	DW				X							X	G/C
6663-DWES-108 Room 302 WF	4/12/25	9:33	DW				X							X	G/C
6663-DWES-109 Room 304 WF	4/12/25	9:32	DW				X							X	G/C
6663-DWES-110 Room 304 Sink	4/12/25	9:32	DW				X							X	G/C
6663-DWES-111 Room 306 Sink	4/12/25	9:30	DW				X							X	G/C
6663-DWES-112 Room 306 WF	4/12/25	9:30	DW				X							X	G/C
6663-DWES-113 2nd Floor Teachers Lounge	4/12/25	9:48	DW				X							X	G/C
6663-DWES-114 Teachers Lounge BR	4/12/25	9:48	DW				X							X	G/C
6663-DWES-115 Corridor Bottle Fill	4/12/25	9:49	DW				X							X	G/C
6663-DWES-116 Room 230 Sink	4/12/25	9:51	DW				X							X	G/C
6663-DWES-117 Room 230 BR	4/12/25	9:51	DW				X							X	G/C
6663-DWES-118 Room 231 Sink	4/12/25	9:53	DW				X							X	G/C
6663-DWES-119 Room 231 WF	4/12/25	9:53	DW				X							X	G/C

Turn-Around Time

- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) X
- PFAS Standard 7-10 Day

Report Type (circle)

- QA Report
- Summary (Results Only)
- NY ASP B Package
- NJ Reduced
- NJ DKQP
- NJ Full
- CT RCP

EDD Type (circle)

- EQuIS (standard)
- NYSDEC EQuIS
- NJDEP SRP Haz Site
- Standard Excel
- CMDP
- Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

- Field Filtered
- Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
QuES&T	4/14/25 14:30	Chris C	4-15-25 8:45	Chris C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time: 4-15-25 1510 Temperature: Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0955

Page _____ of _____

Report To:	Invoice To:	YOUR Project Name / Number
Company: QuES&T	Company: Same	256663 Rye Neck UFSD- DWES 1
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:	PO Number
Phone.: 845-298-6031	Phone.:	
Contact: Zach Timpano	Contact: Angela Holzapfel	
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com	

Samples Collected From: NY X | NJ | CT | PA | Other: (please specify)

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-DWES-120 Room 231 BR	4/12/25	9:54	DW				X							X	G/C
6663-DWES-121 Room 208 Sink	4/12/25	9:48	DW				X							X	G/C
6663-DWES-122 Room 208 WF	4/12/25	9:48	DW				X							X	G/C
6663-DWES-123 Library WF	4/12/25	9:46	DW				X							X	G/C
6663-DWES-124 Library BR	4/12/25	10:00	DW				X							X	G/C
6663-DWES-125 Boy's Bathroom Left	4/12/25	9:49	DW				X							X	G/C
6663-DWES-126 Boy's Bathroom Right	4/12/25	9:49	DW				X							X	G/C
6663-DWES-127 Girl's Bathroom Left	4/12/25	9:50	DW				X							X	G/C
6663-DWES-128 Girl's Bathroom Right	4/12/25	9:50	DW				X							X	G/C
6663-DWES-129 Room 201 Sink	4/12/25	9:50	DW				X							X	G/C
6663-DWES-130 Room 201 WF	4/12/25	9:50	DW				X							X	G/C
6663-DWES-131 Room 206 Sink	4/12/25	9:51	DW				X							X	G/C
6663-DWES-132 Room 206 WF	4/12/25	9:51	DW				X							X	G/C
6663-DWES-133 Room 203 Sink	4/12/25	9:53	DW				X							X	G/C
6663-DWES-134 Room 203 WF	4/12/25	9:53	DW				X							X	G/C

Turn-Around Time

RUSH - Next Day	
RUSH - Two Day	
RUSH - Three Day	
RUSH - Four Day	
RUSH - Five Day	
Standard (6-9 Day)	X
PFAS Standard 7-10 Day	

Report Type (circle)

QA Report
Summary (Results Only)
NY ASP B Package
NJ Reduced
NJ DKQP
NJ Full
CT RCP

EDD Type (circle)

EQuIS (standard)
NYSDEC EQuIS
NJDEP SRP Haz Site
Standard Excel
CMDP
Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

Field Filtered	
Lab Filtered	

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
QuES&T	4/14/25 14:30	Chris C	4-15-25 8:45	Chris C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
					4-15-25 1510 Degrees C 19.7

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0955

Page _____ of _____

Report To:	Invoice To:	YOUR Project Name / Number
Company: QuES&T	Company: Same	256663 Rye Neck UFSD - DWES 2/HS
Address: 1376 US 9, Wappingers Falls, NY 12590	Address:	PO Number
Phone.: 845-298-6031	Phone.:	
Contact: Zach Timpano	Contact: Angela Holzapfel	
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com	

Samples Collected From: NY X | NJ | CT | PA | Other: (please specify)

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Turn-Around Time: RUSH - Next Day; RUSH - Two Day; RUSH - Three Day; RUSH - Four Day; RUSH - Five Day; Standard (6-9 Day) X; PFAS Standard 7-10 Day

Report Type (circle): QA Report; Summary (Results Only); NY ASP B Package; NJ Reduced; NJ DKQP; NJ Full; CT RCP

EDD Type (circle): EQuIS (standard); NYSDEC EQuIS; NJDEP SRP Haz Site; Standard Excel; CMDP; Other:

Regulatory Comparative: Compared to the following Regulation(s): (please fill in)

Field Filtered

Lab Filtered

Analyses Requested

Preservative (please list number of containers): Unpreserved; HCl (hydrochloric acid); MeOH (methanol); HNO_3 (nitric acid); H_2SO_4 (sulfuric acid); NaOH (sodium hydroxide); $Na_2S_2O_3$ (sodium thio.); Trizma; Ammonium Acetate; Other:

Sample Identification	Date	Time	Matrix	Unpreserved	HCl	MeOH	HNO_3	H_2SO_4	NaOH	$Na_2S_2O_3$	Trizma	Ammonium Acetate	Other:	LEAD	Grab or Comp.
6663-DWES-135 Main Office Gender Neutral	4/12/25	9:56	DW				X							X	G/C
6663-DWES-136 Nurse's Bathroom	4/12/25	10:04	DW				X							X	
6663-DWES-137 Nurse's Sink	4/12/25	10:04	DW				X							X	
6663-DWES-138 Room 204 Sink	4/12/25	9:53	DW				X							X	
6663-DWES-139 Room 204 WF	4/12/25	9:53	DW				X							X	
6663-HS-140 Custodial Office Left	4/12/25	10:25	DW				X							X	
6663-HS-141 Custodial Office Right	4/12/25	10:25	DW				X							X	
6663-HS-142 Custodial BR	4/12/25	10:25	DW				X							X	
6663-HS-143 Dining Hall WF BF	4/12/25	10:28	DW				X							X	
6663-HS-144 Dining Hall WF	4/12/25	10:28	DW				X							X	
6663-HS-145 Girl's Bathroom Left	4/12/25	10:28	DW				X							X	
6663-HS-146 Girl's Bathroom Right	4/12/25	10:28	DW				X							X	
6663-HS-147 Boy's Bathroom Left	4/12/25	10:30	DW				X							X	
6663-HS-148 Boy's Bathroom Right	4/12/25	10:30	DW				X							X	
6663-HS-149 Kitchen Sink Middle	4/12/25	10:26	DW				X							X	

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

1. Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
[illegible]	4/14/25 14:30	Chris C	4-15-25 8:45	Chris C	4-15-25 1510
2. Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
4. Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
				[illegible]	4-15-25 1510 Degrees C 19.7