

**Regulatory Compliance
8 Honeywell Lane
Hyde Park, NY 12538
(914) 439-6513**

**10 NYCRR Subpart 67-4
Testing and Water Management Plan
For
Lead In Drinking Water**

For

**Ardsley Union Free School District
500 Farm Road
Ardsley, NY 10502**

at

**High School
Middle School
Concord Road Elementary School**

Project Number: ARD.1011.25.IH

Dates of Survey:
February 2, 2025

Field Work performed by:
Nicholas Coon, BS

Report Written by:
Ernest Coon, MS, RPIH, HEM

TABLE OF CONTENTS

1. SCOPE OF WORK	3
2. INTRODUCTION	3
3. RECOMMENDED/REQUIRED SAMPLING LOCATIONS	3
4. SAMPLING METHODOLOGY	5
5. SAMPLING LOCATIONS, OBSERVATIONS AND DISCUSSION	6
6. RESPONSE AND CORRECTIVE ACTIONS	7
7. POST-REMEDIATION TESTING	8
8. PUBLIC NOTIFICATION REQUIREMENTS	8
9. ELECTRONIC REPORTING IN HCS/HERDS	9
10. RECORDKEEPING REQUIREMENTS	9
11. BEST MANAGEMENT PRACTICES TO REDUCE LEAD IN DRINKING WATER	9
12. LEAD IN DRINKING WATER SURVEY FACT SHEET	11

Appendix

Appendix A	Tabulated Results
Appendix B	Laboratory Data Reports

1.0 SCOPE OF WORK

Ardasley UFSD retained Regulatory Compliance to test water fixtures in select areas identified by the district for lead content. The overall objective is to determine the lead content in drinking water in the district's buildings.

2.0 INTRODUCTION

Lead is a toxic metal that can be harmful when ingested (or inhaled), and young children are particularly sensitive to the effects of lead. Lead can get into drinking water by being present in the source water, or by interaction of the water with plumbing materials containing lead (through corrosion). Common sources of lead in drinking water include: solder, fluxes, pipes and pipefittings, fixtures, and sediments. Thus, it is possible that different water outlets in a given building could have dissimilar concentrations of lead. Lead in drinking water is regulated under the Safe Drinking Water Act (1974) as amended. The Lead Contamination Control Act (LCCA) amended the Safe Drinking Water Act and is aimed at identifying and reducing lead in drinking water in schools (and day care facilities). In April 1994, EPA prepared two guidance documents to assist municipalities in meeting the requirements of the LCCA. On September 6, 2016 the Department of Health DOH issued emergency regulations for the implementation of the new law, *Lead Testing in School Drinking Water*, the regulations became Subpart 67-4 of Title 10 (Health) of the Official Compilation of Codes, Rule and Regulations of the State of New York.

The following information is provided in sections 3-11 are taken from 10 NYCRR Subpart 67-4 and the NYSDOH slide presentation "Lead Testing in School Drinking Water 2023 Compliance Requirements," 2023.

3.0 RECOMMENDED/REQUIRED SAMPLING LOCATIONS

Outlets that should be sampled may be located anywhere on school property including external outlets (hose bibs) if the outlet may be used for drinking or cooking (including food preparation).

Samples must be collected at all outlets used or potentially used for drinking or cooking, including but not limited to:

- bubblers/drinking fountains
- classroom sinks
- classroom combination sinks and drinking fountains
- kitchen sinks
- kitchen kettle filler outlets
- bathroom sinks
- family and consumer sciences room sinks
- teachers' lounge sinks
- nurse's office sinks
- athletic field outlets and any other sink known to be or potentially used for consumption (e.g., coffeemaker or cups are nearby)

Applicable VS. Non-Applicable Outlets

Superintendents or their designees have the responsibility to identify which outlets on a school property meet the regulation requirements for sampling (“applicable outlets”).

If a Superintendent or their designee determines that they have outlets that fall outside of the scope of the regulation (outlets not used or potentially used for drinking or cooking), the school must have a remedial action plan that includes details on how those outlets will not be accessed and/or utilized for drinking or cooking purposes (“non- applicable outlets”).

- Food washing sinks: Food washing faucets must be sampled as they are used for cooking (including food preparation) and potentially for drinking.
- Ice machines: The ice made in an ice machine should be sampled for lead.
- Combination bottle fill station and drinking fountain: A sample should be collected from both outlets. The Department recommends sampling the outlet that is most frequently used first.
- Hand washing outlets: In general, all hand washing outlets in a bathroom should be sampled as bathroom outlets may be used to obtain water for drinking and/or food preparation.
- Foot level operated multi-outlet gang sink: In general, samples should be collected from each outlet of a gang sink, however, if the gang sink design does not allow sample collection from each outlet, the schools should contact the local health department or the Department to discuss.
- Traditional outlet with hot and cold-water handle: Samples must be collected from each outlet but only the cold water should be turned on for sampling

Non-Applicable Outlets

In general, any outlet in a room or office within a school that is not used by students (pre-kindergarten through grade 12) and does not provide water for drinking or cooking does not require sampling.

Dishwashing sinks: If an outlet is designated for dish washing only and involves no opportunity for drinking or cooking (including food preparation), the outlet does not require sampling

Bus garage: Outlets in bus garage buildings do not require sampling for lead unless the building is occupied by students (e.g., BOCES classes).

Point of entry: Samples from the point of entry are not required under Subpart 67-4. Point of entry is the location where water enters the building from the distribution system of a public water system.

Science/Art sinks: Typically, classrooms in these settings prohibit eating and/or drinking. The school Superintendent has the authority to determine whether these outlets may be used for drinking or cooking and whether they require sampling.

Tempered Outlets: The Department and the US EPA recommend that hot or tempered water not be used for drinking or cooking as warm or hot water increase the leaching of lead into the water. Tempered outlets do not require sampling.

4.0 SAMPLING METHODOLOGY

Samples were collected in accordance with the *Lead Testing in School Drinking Water* – 10 NYCRR Subpart 67-4.3. A first-draw sample was collected in a wide mouth 250 mL bottle and collected from a cold water outlet before the water is used. The water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours prior to collection.

Sampling Collection Guidance:

- Pre-stagnation flushing: The Department does not allow for pre- stagnation flushing prior to sampling unless a school is directed to do so by the Department or local health department.
- Aerators: Aerators should not be removed prior to sampling

5.0 SAMPLING LOCATIONS, OBSERVATIONS AND DISCUSSION

February 2, 2025

Sampling was conducted at the Middle School, High School, Concord Road School. A total of one hundred thirty (130) samples were collected and analyzed for lead contaminants. All of the samples collected were within NYSDOH compliance. The sample results for all water fixtures tested are located in Appendix A.

Building	Non-Compliant Fixtures
High School	1
Middle School	2
Concord Road School	3

In accordance with *Lead Testing in School Drinking Water* – 10 NYCRR Subpart 67-4, outlets that exceed the NYS Action Level are obligated to take corrective action. The required actions, notifications, reporting and recordkeeping requirements are listed in the appropriate sections of this report. For all outlets not used or potentially used for drinking or cooking, the school must have a remedial action plan that includes details on how those outlets will not be accessed and/or utilized for drinking or cooking purposes (“non- applicable outlets”).

When the water fountains, outdoor water fixtures or any other water fixtures, are made operable or new water fixtures are installed, they must be tested prior to use and incorporated into the Water Management Plan.

6-1

OBSERVATIONS:

- Custodians escorted the sampling technician and identified the sampling locations.

6.0 RESPONSE AND CORRECTIVE ACTIONS

Steps following an Action Level Exceedance Immediate Response

- Prohibit the use of the outlet immediately (take outlet out of service or turn off) until:
(1) A lead remedial action plan is implemented to mitigate the lead level at the outlet, and
(2) Post-remediation test results indicate that the lead levels are at or below the action level;
- Provide building occupants with an adequate supply of water for drinking and cooking until remediation is performed;
- Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report;
- Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the School received the laboratory report.

Corrective Actions / Remediation Options

- Permanent removal of an outlet
- Outlet replacement with “lead-free” plumbing materials
- Pipe replacement with “lead-free” plumbing materials
- Remove other sources of lead (lead pipe, lead solder joints, and brass plumbing components with “lead-free” materials)
- Flushing (systematic flushing program)
- Point of Use (POU) Filters*
- Supervision
- Engineering controls
- Education
- Signage

Signage Options:



7.0 Post-Remediation Testing

- Follow-up samples collected after an outlet has been remediated must also be “first-draw” samples. Schools may choose to perform additional sampling (i.e., 30-second flush, etc.) to determine the contribution of lead from plumbing to guide remediation decisions.
- Only those outlets that exceed the action level need to be resampled (following remediation).
- All remediated outlets will likely require flushing prior to being placed back into service.
- Post-remediation tests results need to be reported:
 - in the Department’s HERDS application on HCS, and
 - on the school’s website within the same reporting timeframes/requirements as specified for the initial sampling (addressed in next section).

8.0 Public Notification Requirements

- Within 1 business day of receipt of laboratory reports:
 - Report any and all exceedances (lead result greater than 15 ppb) to the local health department
- Within 10 business days of receipt of laboratory reports:
 - Report all exceedances to all staff, parents, and guardians in writing.

- Report test results (including post-remediation results) in the Department's electronic reporting system, HERDS accessed through HCS. This information is posted on the Department's website for the public
- Within 6 weeks of receipt of laboratory reports:
 - Post numeric test results of all lead testing and information about remediation actions taken to address outlets where lead exceeded the action level on the school's website. This should remain posted on the school's website for the duration of the compliance period (i.e. 2023-2025)
- Report any lead-free buildings on the school's website
- Within 6 weeks of receipt of laboratory reports:
 - Post numeric test results of all lead testing and information about remediation actions taken to address outlets where lead exceeded the action level on the school's website. This should remain posted on the school's website for the duration of the compliance period (i.e. 2023-2025)

9.0 Electronic Reporting in HCS/HERDS

- Within 10 business days of receipt of laboratory reports: Summary data must be reported in the Department's electronic reporting system, HERDS accessed through HCS. Summary data includes:
 - General information (lead-free status, website address)
 - Sampling information
 - Lead analysis results
 - Response and remediation
- Do not submit laboratory reports directly to the Department or local health department unless otherwise directed.

10.0 Recordkeeping Requirements

- Schools must retain all records of:
 - Test results
 - Remedial action plans
 - Determinations that a building is lead-free; and
 - Waiver requests (only applicable to compliance year 2016)
- Per Subpart 67-4, schools must retain records for 10 years following document creation (Note: other agencies may have additional records retention requirements, i.e., NYS Department of Labor)
- Copies of documents must be provided to the Department, the NY State Education Department, or the local health department upon request
- Department recommends that all records be kept in a centrally located and accessible repository for each school building

11.0 Best Management Practices to Reduce Lead in Drinking Water

- Aerator cleaning
- Routine flushing practices (after vacations and long weekends)

- Use only certified lead-free materials when performing plumbing work
- Follow the manufacturer's recommendations for water softener settings to ensure an appropriate level of hardness
- Temperature control
- Educating staff and students of the benefits of running water at a tap briefly prior to using it for drinking or food preparation. Letting the water run for 30- 60 seconds or until the water feels cold can reduce the potential levels of lead in the drinking water

12.0 Lead in Drinking Water Survey Fact Sheet

Name and Address of Building/Structure Owner:

Ardsley Union Free School District
500 Farm Road
Ardsley, NY 10502

Name and Address of Buildings/Structures Surveyed:

Administration Building (Not Surveyed)
500 Farm Road
Ardsley, NY 10502

High School
500 Farm Road
Ardsley, NY 10502

Middle School
700 Ashford Avenue
Ardsley, NY 10502

Concord Road School
2 Concord Road
Ardsley, NY 10502

Name of the Firm & Person Conducting the Survey:

Regulatory Compliance
Nicholas Coon
8 Honeywell Lane
Hyde Park, NY 12538

Date Survey Was Conducted:

February 2, 2025

Tabulated Results

Laboratory Data Reports

Ardsley UFSD**Middle School**

Sample ID #/Location/Description	Date Sampled	Results (ug/L)	Remedial Action	Compliant (Y/N)
10M FACULTY RM 217 SINK	2.1.25	2.42	NA	Y
11M FOUNTAIN BY NURSES RM BOTTLE	2.1.25	ND	NA	Y
12M FOUNTAIN BY NURSES RM BUBBLER	2.1.25	ND	NA	Y
13M NURSES OFFICE SINK 1	2.1.25	ND	NA	Y
14M NURSES OFFICE SINK 2	2.1.25	1.32	NA	Y
15M (A) NURSES ICE MACHINE	2.1.25	ND	NA	Y
15M (B) NURSES ICE MACHINE	2.1.25	ND	NA	Y
16M GYM BOYS SIDE FOUNTAIN BOTTLE	2.1.25	ND	NA	Y
17M GYM BOYS SIDE FOUNTAIN BUBBLER	2.1.25	ND	NA	Y
18M GYM GIRLS SIDE FOUNTAIN BOTTLE	2.1.25	ND	NA	Y
19M GYM GIRLS SIDE FOUNTAIN BUBBLER	2.1.25	ND	NA	Y
1M COMMONS AREA FOUNTAIN BOTTLE	2.1.25	ND	NA	Y
20M HALLWAY IN POOL AREA BY BOYS BOTTLE	2.1.25	ND	NA	Y
21M HALLWAY IN POOL AREA BY BOYS BUBBLER	2.1.25	ND	NA	Y
22M POOL AREA FOUNTAIN 1 BOTTLE	2.1.25	ND	NA	Y
23M POOL AREA FOUNTAIN 1 BUBBLER	2.1.25	ND	NA	Y
24M POOL AREA FOUNTAIN 2 BOTTLE	2.1.25	ND	NA	Y
25M POOL AREA FOUNTAIN 2 BUBBLER	2.1.25	ND	NA	Y
26M FOUNTAIN BY AUDITORIUM LGI BOTTLE	2.1.25	1.23	NA	Y
27M FOUNTAIN BY AUDITORIUM LGI BUBBLER	2.1.25	1.68	NA	Y
28M FOUNTAIN BY MUSIC SUITE BUBBLER	2.1.25	2.32	NA	Y
29M FOUNTAIN BY RM 306 BUBBLER	2.1.25	ND	NA	Y
2M COMMONS AREA FOUNTAIN BUBBLER	2.1.25	ND	NA	Y
30M FOUNTAIN BY RM 405 BUBBLER	2.1.25	4.70	NA	Y
31M RM 400 SINK 1	2.1.25	1.16	NA	Y
32M RM 400 SINK 2	2.1.25	7.50	SP	Y
33M RM 400 SINK 3	2.1.25	3.06	NA	Y
34M RM 400 SINK 4	2.1.25	3.87	NA	Y
35M RM 400 SINK 5.	2.1.25	3.72	NA	Y
36M (A) RM 404B ICE MACHINE	2.1.25	ND	NA	Y
36M (B) RM 404B ICE MACHINE	2.1.25	ND	NA	Y
37M KITCHEN SINK 1	2.1.25	ND	NA	Y
38M KITCHEN SINK 2	2.1.25	1.31	NA	Y
39M KITCHEN SINK 3	2.1.25	3.25	NA	Y
3M COMMONS AREA OFFICE SINK	2.1.25	8.27	SP	Y
40M KITCHEN JUG FILLER	2.1.25	2.46	NA	Y
41M (A) KITCHEN ICE MACHINE	2.1.25	ND	NA	Y
41M (B) KITCHEN ICE MACHINE	2.1.25	ND	NA	Y
4M FOUNTAIN BY RM 206 BUBBLER	2.1.25	1.37	NA	Y
5M FOUNTAIN BY RM 206 BOTTLE	2.1.25	1.06	NA	Y

Sample ID #/Location/Description	Date Sampled	Results (ug/L)	Remedial Action	Compliant (Y/N)
6M FOUNTAIN BY RM 217 BOTTLE	2.1.25	1.23	NA	Y
7M FOUNTAIN BY RM 217 BUBBLER	2.1.25	1.06	NA	Y
8M FACULTY RM 217 BOTTLE FILLER	2.1.25	ND	NA	Y
9M FACULTY RM 217 BUBBLER	2.1.25	ND	NA	Y

SP = Signs Posted in Compliance with Lead Testing Requirements for School Drinking Water under 10 NYCRR Subpart 67-4

NA = Not Applicable

ND = Not Detectable

Ardsley UFSD

High School

Sample ID #/Location/Description	Date Sampled	s (ug/L)	Remedial Action	Compliant (Y/N)
10H FITNESS ROOM BUBBLER	2.1.25	ND	NA	Y
11H (A) FITNESS ROOM ICE MACHINE	2.1.25	ND	NA	Y
11H (B) FITNESS ROOM ICE MACHINE	2.1.25	ND	NA	Y
12H PORCELAIN FOUNTAIN BTWN 113&114	2.1.25	2.39	NA	Y
13H FOUNTAIN BY RM 119 BOTTLE	2.1.25	ND	NA	Y
14H FOUNTAIN BY RM 119 BUBBLER	2.1.25	ND	NA	Y
15H NURSES OFFICE FOUNTAIN BOTTLE	2.1.25	ND	NA	Y
16H NURSES OFFICE FOUNTAIN BUBBLER	2.1.25	ND	NA	Y
17H NURSES OFFICE SINK	2.1.25	1.46	NA	Y
18H TEACHERS LOUNGE FOUNTAIN BOTTLE	2.1.25	ND	NA	Y
19H TEACHERS LOUNGE FOUNTAIN BUBBLER	2.1.25	ND	NA	Y
1H MAINT LUNCH ROOM BOTTLE	2.1.25	ND	NA	Y
20H BY RM 130 FOUNTAIN BOTTLE	2.1.25	ND	NA	Y
21H BY RM 130 FOUNTAIN BUBBLER	2.1.25	ND	NA	Y
22H FOUNTAIN BY RM 142 #1 BUBBLER	2.1.25	ND	NA	Y
23H FOUNTAIN BY RM 142 #2 BUBBLER	2.1.25	ND	NA	Y
24H FOUNTAIN BY RM 200 BOTTLE	2.1.25	ND	NA	Y
25H FOUNTAIN BY RM 200 BUBBLER	2.1.25	ND	NA	Y
26H FOUNTAIN BY RM 215 BOTTLE	2.1.25	ND	NA	Y
27H FOUNTAIN BY RM 215 BUBBLER	2.1.25	ND	NA	Y
28H FOUNTAIN BY RM 223B BOTTLE	2.1.25	ND	NA	Y
29H FOUNTAIN BY RM 223B BUBBLER	2.1.25	ND	NA	Y
2H MAINT LUNCH BUBBLER	2.1.25	ND	NA	Y
30H FOUNTAIN BY RM 244 BOTTLE	2.1.25	ND	NA	Y
31H KITCHEN HANDWASH SINK 1	2.1.25	ND	NA	Y
32H KITCHEN HANDWASH SINK 2	2.1.25	ND	NA	Y
33H KITCHEN HANDWASH SINK 3	2.1.25	ND	NA	Y
34H KITCHEN HANDWASH SINK 4	2.1.25	ND	NA	Y
35H KITCHEN HANDWASH SINK 5	2.1.25	ND	NA	Y
36H SERVING SIDE SINK 6	2.1.25	ND	NA	Y
37H KITCHEN ICE MACHINE	2.1.25	ND	NA	Y
38H DISTRICT OFFICE LOUNGE SINK	2.1.25	ND	NA	Y
39H DISTRICT OFFICE AREA FOUNTAIN BOTTLE	2.1.25	ND	NA	Y
3H BY ROOM 104E BOTTLE	2.1.25	3.25	NA	Y
40H DISTRICT OFFICE AREA FOUNTAIN BUBBLE	2.1.25	ND	NA	Y
41H DISTRICT OFFICE LOUNGE COFFEE SPOUT	2.1.25	4.98	NA	Y
42H GARAGE SINK	2.1.25	ND	NA	Y
4H BY ROOM 104E BOTTLE	2.1.25	ND	NA	Y
5H FOUNTAIN 1 BY ROOM 108 BOTTLE	2.1.25	ND	NA	Y
6H FOUNTAIN 1 BY ROOM 108 BUBBLER	2.1.25	ND	NA	Y
7H FOUNTAIN 2 BY ROOM 108 BOTTLE	2.1.25	ND	NA	Y


Sample ID #/Location/Description	Date Sampled	s (ug/L)	Remedial Action	Compliant (Y/N)
8H FOUNTAIN 2 BY ROOM 108 BUBBLER	2.1.25	ND	NA	Y
9H FITNESS ROOM BOTTLE	2.1.25	ND	NA	Y
43H GARAGE BOTTLE FILLER	2.1.25	6.85	TOS	Y

NA = Not Applicable
ND = Not Detectable
TOS = Taken Out of Service

Ardsley UFSD				
Concord Road Elementary School				
Sample ID #/Location/Description	Date Sampled	Results (ug/L)	Remedial Action	Compliant (Y/N)
1 Bubbler Next to RM S4	2.1.25	ND	NA	Y
2 Bottle filler to RM S4	2.1.25	ND	NA	Y
3 Bubbler Next to RM 50C	2.1.25	ND	NA	Y
4 Bottle Filter Next to RM 50c	2.1.25	ND	NA	Y
5 Bubbler by RM 3	2.1.25	ND	NA	Y
6 Bottle filler RM 3	2.1.25	ND	NA	Y
7 Porcelian Faintain by Rm 31	2.1.25	5.47	TOS	Y
8 Bubbler by RM 31	2.1.25	ND	NA	Y
9 Bottle filler by RM 31	2.1.25	ND	NA	Y
10 Bubbler by Room 35	2.1.25	ND	NA	Y
11 Bottle Filler by room 35	2.1.25	ND	NA	Y
12 Bubbler by RM #25	2.1.25	ND	NA	Y
13 Bottle filler by RM #25	2.1.25	ND	NA	Y
14 Bubbler by RM 41 & 43	2.1.25	ND	NA	Y
15 Bottle filler by RM 41 & 43	2.1.25	ND	NA	Y
16 Staff Lounge sink	2.1.25	ND	NA	Y
17 Staff Lounge water fountain Bubbler	2.1.25	ND	NA	Y
18 Staff lounge Bottle filler	2.1.25	ND	NA	Y
19 Bubbler outside Gym	2.1.25	ND	NA	Y
20 Bottle filler outside Gym	2.1.25	ND	NA	Y
21 Bubbler in upper cafeteria	2.1.25	ND	NA	Y
22 Handwash sink #1 in Kitchen	2.1.25	ND	NA	Y
23 Kitchen sink #2	2.1.25	ND	NA	Y
24 Kitchen sink #3	2.1.25	ND	NA	Y
25 Kitchen Island sink #4	2.1.25	ND	NA	Y
26 Kitchen Island sink #5	2.1.25	2.27	NA	Y
27A Kitchen free machine	2.1.25	ND	NA	Y
27B Kitchen free machine	2.1.25	ND	NA	Y
28 Primary cafe Bubbler	2.1.25	ND	NA	Y
29 Primary cafe Bottle filler	2.1.25	ND	NA	Y
30 Bubbler by Library Lobby	2.1.25	ND	NA	Y
31 Bottle filler by Libarary Lobby	2.1.25	ND	NA	Y
32 Bottle filler by Primary Entrance	2.1.25	ND	NA	Y
33 Bubbler by Primary entrance	2.1.25	ND	NA	Y
34 Bubbler by Rear entrance	2.1.25	ND	NA	Y
35 Bottle filler by rear entrance	2.1.25	ND	NA	Y
36 Nurses sink #1	2.1.25	2.19	NA	Y
37 Nurses sink #2 Bathroom	2.1.25	3.78	NA	Y
38 main office sink	2.1.25	ND	NA	Y
39A Main office ice machine	2.1.25	9.56	TOS	Y
39B Main office ice machine	2.1.25	7.27	TOS	Y

NA = Not Applicable
ND = Not Detectable
TOS = Taken Out of Service

Laboratory Data Reports



Technical Report

prepared for:

Regulatory Compliance

245 Albany Ave.

Thornwood NY, 10594

Attention: Ernest Coon

Report Date: 02/28/2025

Client Project ID: Ardsley Middle/Highschool Water

York Project (SDG) No.: 25B0347

Stratford, CT Laboratory IDs:
NY:10854, NJ: CT005, PA: 68-0440, CT: PH-0723



Richmond Hill, NY Laboratory IDs:
NY:12058, NJ: NY037, CT: PH-0721, NH: 2097,
EPA: NY01600

120 RESEARCH DRIVE
www.YORKLAB.com

STRATFORD, CT 06615
(203) 325-1371



132-02 89th AVENUE
FAX (203) 357-0166

RICHMOND HILL, NY 11418
ClientServices@yorklab.com

Report Date: 02/28/2025
Client Project ID: Ardsley Middle/Highschool Water
York Project (SDG) No.: 25B0347

Regulatory Compliance
245 Albany Ave.
Thornwood NY, 10594
Attention: Ernest Coon

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on February 07, 2025 and listed below. The project was identified as your project: **Ardsley Middle/Highschool Water**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
25B0347-01	1H Maint Lunch Room Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-02	2H Maint Lunch Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-03	3H by Room 104E Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-04	4H by Room 104E Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-05	5H Fountain #1 by Room 108 Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-06	6H Fountain #1 by Room 108 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-07	7H Fountain #2 by Room 108 Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-08	8H Fountain #2 by Room 108 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-09	9H Fitness Room Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-10	10H Fitness Room Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-11	11H (A) Fitness Room Ice Machine	Drinking Water	02/01/2025	02/07/2025
25B0347-12	11H (B) Fitness Room Ice Machine	Drinking Water	02/01/2025	02/07/2025
25B0347-13	12H Porcelian Fountain btwn 113&114	Drinking Water	02/01/2025	02/07/2025
25B0347-14	13H Fountain by Rm 119 bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-15	14H Fountain by Rm 119 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-16	15H Nurses Office Fountain Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-17	16H Nurses Office Fountain Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-18	17H Nurses Office Sink	Drinking Water	02/01/2025	02/07/2025
25B0347-19	18H Teachers Lounge Fountain Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-20	19H Teachers Lounge Fountain Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-21	20H By Rm 130 Fountain Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-22	21H By Rm 130 Fountain Bubbler	Drinking Water	02/01/2025	02/07/2025

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
25B0347-23	22H Fountain by Rm 142 #1 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-24	23H Fountain by Rm 142 #2 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-25	24H Fountain by Rm 200 Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-26	25H Fountain by Rm 200 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-27	26H Fountain by Rm 215 Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-28	27H Fountain by Rm 215 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-29	28H Fountain by Rm 223B Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-30	29H Fountain by Rm 223B Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-31	30H Fountain by Rm 244 Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-32	31H Kitchen Handwash Sink #1	Drinking Water	02/01/2025	02/07/2025
25B0347-33	32H Kitchen Handwash Sink #2	Drinking Water	02/01/2025	02/07/2025
25B0347-34	33H Kitchen Handwash Sink #3	Drinking Water	02/01/2025	02/07/2025
25B0347-35	34H Kitchen Handwash Sink #4	Drinking Water	02/01/2025	02/07/2025
25B0347-36	35H Kitchen Handwash Sink #5	Drinking Water	02/01/2025	02/07/2025
25B0347-37	36H Serving Side Sink #6	Drinking Water	02/01/2025	02/07/2025
25B0347-38	37H Kitchen Ice Machine	Drinking Water	02/01/2025	02/07/2025
25B0347-39	38H District Office Lounge Sink	Drinking Water	02/01/2025	02/07/2025
25B0347-40	39H District Office Area Fountain Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-41	40H District Office Area Fountain Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-42	41H District Office Lounge Coffee Spout	Drinking Water	02/01/2025	02/07/2025
25B0347-43	42H Garage Sink	Drinking Water	02/01/2025	02/07/2025

General Notes for York Project (SDG) No.: 25B0347

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854, NJ Cert No. CT005, PA Cert No. 68-04440, CT Cert No. PH-0723; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058, NJ Cert No. NY037, CT Cert No. PH-0721, NH Cert No. 2097, EPA Cert No. NY01600.


Approved By:



Cassie L. Mosher
Laboratory Manager

Date: 02/28/2025





Sample Information

Client Sample ID: 1H Maint Lunch Room Bottle

York Sample ID: 25B0347-01

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:29	02/13/2025 11:51	cw

Sample Information

Client Sample ID: 2H Maint Lunch Bubbler

York Sample ID: 25B0347-02

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:29	02/13/2025 11:54	cw

Sample Information

Client Sample ID: 3H by Room 104E Bottle

York Sample ID: 25B0347-03

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:29	02/13/2025 11:55	cw

Sample Information

Client Sample ID: 4H by Room 104E Bottle

York Sample ID: 25B0347-04

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received


25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025



Sample Information

Client Sample ID: 4H by Room 104E Bottle

York Sample ID: 25B0347-04

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:29	02/13/2025 11:57	cw

Sample Information

Client Sample ID: 5H Fountain #1 by Room 108 Bottle

York Sample ID: 25B0347-05

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:29	02/13/2025 11:58	cw

Sample Information

Client Sample ID: 6H Fountain #1 by Room 108 Bubbler

York Sample ID: 25B0347-06

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:29	02/13/2025 11:59	cw

Sample Information

Client Sample ID: 7H Fountain #2 by Room 108 Bottle

York Sample ID: 25B0347-07

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water


February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 7H Fountain #2 by Room 108 Bottle

York Sample ID: 25B0347-07

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:29	02/13/2025 12:01	cw

Sample Information

Client Sample ID: 8H Fountain #2 by Room 108 Bubbler

York Sample ID: 25B0347-08

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:29	02/13/2025 12:05	cw

Sample Information

Client Sample ID: 9H Fitness Room Bottle

York Sample ID: 25B0347-09

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:29	02/13/2025 12:06	cw

Sample Information

Client Sample ID: 10H Fitness Room Bubbler

York Sample ID: 25B0347-10

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
120 RESEARCH DRIVE		STRATFORD, CT 06615					132-02 89th AVENUE		RICHMOND HILL, NY 11418	
www.YORKLAB.com		(203) 325-1371					FAX (203) 357-0166		ClientServices@	



Sample Information

Client Sample ID: 10H Fitness Room Bubbler

York Sample ID: 25B0347-10

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

7439-92-1	Lead	ND	ug/L	1.00	1	EPA 200.8	02/13/2025 09:29	02/13/2025 12:07	cw	
						Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044			

Sample Information

Client Sample ID: 11H (A) Fitness Room Ice Machine

York Sample ID: 25B0347-11

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:29	02/13/2025 12:09	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 11H (B) Fitness Room Ice Machine

York Sample ID: 25B0347-12

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:29	02/13/2025 12:10	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 12H Porcelian Fountain btwn 113&114

York Sample ID: 25B0347-13

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	2.39		ug/L	1.00	1	EPA 200.8	02/13/2025 09:29	02/13/2025 12:11	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		



Sample Information

Client Sample ID: 12H Porcelian Fountain btwn 113&114

York Sample ID: 25B0347-13

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Sample Information

Client Sample ID: 13H Fountain by Rm 119 bottle

York Sample ID: 25B0347-14

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:29	02/13/2025 12:13	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044										

Sample Information

Client Sample ID: 14H Fountain by Rm 119 Bubblers

York Sample ID: 25B0347-15

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:29	02/13/2025 12:14	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044										

Sample Information

Client Sample ID: 15H Nurses Office Fountain Bottle

York Sample ID: 25B0347-16

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:29	02/13/2025 12:15	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044										



Sample Information

Client Sample ID: 16H Nurses Office Fountain Bubbler

York Sample ID: 25B0347-17

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:29	02/13/2025 12:17	cw

Sample Information

Client Sample ID: 17H Nurses Office Sink

York Sample ID: 25B0347-18

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.46		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:29	02/13/2025 12:21	cw

Sample Information

Client Sample ID: 18H Teachers Lounge Fountain Bottle

York Sample ID: 25B0347-19

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:29	02/13/2025 12:22	cw

Sample Information

Client Sample ID: 19H Teachers Lounge Fountain Bubbler

York Sample ID: 25B0347-20

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water


February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 19H Teachers Lounge Fountain Bubbler

York Sample ID: 25B0347-20

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:29	02/13/2025 12:23	cw

Sample Information

Client Sample ID: 20H By Rm 130 Fountain Bottle

York Sample ID: 25B0347-21

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 12:30	cw

Sample Information

Client Sample ID: 21H By Rm 130 Fountain Bubbler

York Sample ID: 25B0347-22

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 12:33	cw

Sample Information

Client Sample ID: 22H Fountain by Rm 142 #1 Bubbler

York Sample ID: 25B0347-23

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
120 RESEARCH DRIVE		STRATFORD, CT 06615				132-02 89th AVENUE		RICHMOND HILL, NY 11418		
www.YORKLAB.com		(203) 325-1371				FAX (203) 357-0166		ClientServices@		



Sample Information

Client Sample ID: 22H Fountain by Rm 142 #1 Bubbler

York Sample ID: 25B0347-23

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

7439-92-1	Lead	ND	ug/L	1.00	1	EPA 200.8	02/13/2025 09:32	02/13/2025 12:37	cw	
						Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044			

Sample Information

Client Sample ID: 23H Fountain by Rm 142 #2 Bubbler

York Sample ID: 25B0347-24

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:32	02/13/2025 12:38	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 24H Fountain by Rm 200 Bottle

York Sample ID: 25B0347-25

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:32	02/13/2025 12:39	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 25H Fountain by Rm 200 Bubbler

York Sample ID: 25B0347-26

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:32	02/13/2025 12:41	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		



Sample Information

Client Sample ID: 25H Fountain by Rm 200 Bubbler

York Sample ID: 25B0347-26

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Sample Information

Client Sample ID: 26H Fountain by Rm 215 Bottle

York Sample ID: 25B0347-27

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 12:42	cw

Sample Information

Client Sample ID: 27H Fountain by Rm 215 Bubbler

York Sample ID: 25B0347-28

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 12:43	cw

Sample Information

Client Sample ID: 28H Fountain by Rm 223B Bottle

York Sample ID: 25B0347-29

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 12:45	cw



Sample Information

Client Sample ID: 29H Fountain by Rm 223B Bubbler

York Sample ID: 25B0347-30

York Project (SDG) No.
25B0347

Client Project ID
Ardsley Middle/Highschool Water

Matrix
Drinking Water

Collection Date/Time
February 1, 2025 9:40 am

Date Received
02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 12:46	cw

Sample Information

Client Sample ID: 30H Fountain by Rm 244 Bottle

York Sample ID: 25B0347-31

York Project (SDG) No.
25B0347

Client Project ID
Ardsley Middle/Highschool Water

Matrix
Drinking Water

Collection Date/Time
February 1, 2025 9:40 am

Date Received
02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 12:47	cw

Sample Information

Client Sample ID: 31H Kitchen Handwash Sink #1

York Sample ID: 25B0347-32

York Project (SDG) No.
25B0347

Client Project ID
Ardsley Middle/Highschool Water

Matrix
Drinking Water

Collection Date/Time
February 1, 2025 9:40 am

Date Received
02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 12:49	cw

Sample Information

Client Sample ID: 32H Kitchen Handwash Sink #2

York Sample ID: 25B0347-33

York Project (SDG) No.
25B0347

Client Project ID
Ardsley Middle/Highschool Water

Matrix
Drinking Water


Collection Date/Time
February 1, 2025 9:40 am

Date Received
02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 32H Kitchen Handwash Sink #2

York Sample ID: 25B0347-33

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 12:53	cw

Sample Information

Client Sample ID: 33H Kitchen Handwash Sink #3

York Sample ID: 25B0347-34

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.81		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 12:54	cw

Sample Information

Client Sample ID: 34H Kitchen Handwash Sink #4

York Sample ID: 25B0347-35

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 12:55	cw

Sample Information

Client Sample ID: 35H Kitchen Handwash Sink #5

York Sample ID: 25B0347-36

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
---------	-----------	--------	------	-------	--------------------	----------	------------------	-----------------------	-----------------------	---------



Sample Information

Client Sample ID: 35H Kitchen Handwash Sink #5

York Sample ID: 25B0347-36

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:32	02/13/2025 12:57	cw

Sample Information

Client Sample ID: 36H Serving Side Sink #6

York Sample ID: 25B0347-37

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.66		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:32	02/13/2025 12:58	cw

Sample Information

Client Sample ID: 37H Kitchen Ice Machine

York Sample ID: 25B0347-38

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:32	02/13/2025 12:59	cw

Sample Information

Client Sample ID: 38H District Office Lounge Sink

York Sample ID: 25B0347-39

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water


February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 38H District Office Lounge Sink

York Sample ID: 25B0347-39

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 13:01	cw

Sample Information

Client Sample ID: 39H District Office Area Fountain Bottle

York Sample ID: 25B0347-40

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:32	02/13/2025 13:02	cw

Sample Information

Client Sample ID: 40H District Office Area Fountain Bubbler

York Sample ID: 25B0347-41

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:36	02/13/2025 13:11	cw

Sample Information

Client Sample ID: 41H District Office Lounge Coffee Spout

York Sample ID: 25B0347-42

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
120 RESEARCH DRIVE		STRATFORD, CT 06615					132-02 89th AVENUE		RICHMOND HILL, NY 11418	
www.YORKLAB.com		(203) 325-1371					FAX (203) 357-0166		ClientServices@	



Sample Information

Client Sample ID: 41H District Office Lounge Coffee Spout

York Sample ID: 25B0347-42

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

7439-92-1	Lead	4.98	ug/L	1.00	1	EPA 200.8	02/13/2025 09:36	02/13/2025 13:14	cw
Certifications:							CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 42H Garage Sink

York Sample ID: 25B0347-43

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.46		ug/L	1.00	1	EPA 200.8	02/13/2025 09:36	02/13/2025 13:15	cw
Certifications:							CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04			



Sample and Data Qualifiers Relating to This Work Order

Definitions and Other Explanations

*	Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
ND	NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
RL	REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
LOQ	LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon current NELAC/TNI Standards and applies to all analyses.
LOD	LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW-846.
MDL	METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
Reported to	This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
NR	Not reported
RPD	Relative Percent Difference
Wet	The data has been reported on an as-received (wet weight) basis
Low Bias	Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
High Bias	High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
Non-Dir.	Non-dir. flag (Non-Directional Bias) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.


If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.

For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.



Field Chain-of-Custody Record

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

YORK Project Number

2530347

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

Page _____ of _____

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time	
Company: Reg Com	Company: Reg Com	Ardsley High School		NY	✓	CT	Other: (please specify)	RUSH - Next Day	
Address: 245 Albany Ave	Address: " "	water		NJ		PA		RUSH - Two Day	
Phone: 914-434-6513	Phone: " "	PO Number		Analyses Requested				RUSH - Three Day	
Contact: E. Caon	Contact: " "							RUSH - Four Day	
E-mail: Reg Comp 2@hotmail.com	E-mail: " "	Preservative (please list number of containers)		Grab or Comp. G/C				RUSH - Five Day	
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		Matrix Codes						Report Type (circle)	
Samples Collected by: (print AND sign your name)		S - soil/solid/sludge		QA Report					
		GW - groundwater						Summary (Results Only)	
		DW - drinking water		NY ASP B Package					
		SW - surface water						NJ Reduced	
		WW - wastewater		NJ DKQP					
		O - Oil Other						NJ Full	
				CT RCP					
								EDD Type (circle)	
				EQUIS (standard)					
								NYSDEC EQuIS	
				NJDEP SRP Haz Site					
								Standard Excel	
				CMDP					
								Other:	
				Regulatory Comparative					
								Compared to the following Regulation(s): (please fill in)	
				Field Filtered					
								Lab Filtered	
				Comments:					
								Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N	
				Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N					
								COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N	
				Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N					
								Samples iced/chilled at time of lab pickup? circle Yes or No	
				1. Samples Relinquished by / Company					
								2. Samples Relinquished by / Company	
				3. Samples Relinquished by / Company					
								4. Samples Relinquished by / Company	
				5. Samples Relinquished by / Company					
								6. Samples Relinquished by / Company	
				7. Samples Relinquished by / Company					
								8. Samples Relinquished by / Company	
				9. Samples Relinquished by / Company					
								10. Samples Relinquished by / Company	
				11. Samples Relinquished by / Company					
								12. Samples Relinquished by / Company	
				13. Samples Relinquished by / Company					
								14. Samples Relinquished by / Company	
				15. Samples Relinquished by / Company					
								16. Samples Relinquished by / Company	
				17. Samples Relinquished by / Company					
								18. Samples Relinquished by / Company	
				19. Samples Relinquished by / Company					
								20. Samples Relinquished by / Company	
				21. Samples Relinquished by / Company					
								22. Samples Relinquished by / Company	
				23. Samples Relinquished by / Company					
								24. Samples Relinquished by / Company	
				25. Samples Relinquished by / Company					
								26. Samples Relinquished by / Company	
				27. Samples Relinquished by / Company					
								28. Samples Relinquished by / Company	
				29. Samples Relinquished by / Company					
								30. Samples Relinquished by / Company	
				31. Samples Relinquished by / Company					
								32. Samples Relinquished by / Company	
				33. Samples Relinquished by / Company					
								34. Samples Relinquished by / Company	
				35. Samples Relinquished by / Company					
								36. Samples Relinquished by / Company	
				37. Samples Relinquished by / Company					
								38. Samples Relinquished by / Company	
				39. Samples Relinquished by / Company					
								40. Samples Relinquished by / Company	
				41. Samples Relinquished by / Company					
								42. Samples Relinquished by / Company	
				43. Samples Relinquished by / Company					
								44. Samples Relinquished by / Company	
				45. Samples Relinquished by / Company					
								46. Samples Relinquished by / Company	
				47. Samples Relinquished by / Company					
								48. Samples Relinquished by / Company	
				49. Samples Relinquished by / Company					
								50. Samples Relinquished by / Company	
				51. Samples Relinquished by / Company					
								52. Samples Relinquished by / Company	
				53. Samples Relinquished by / Company					
								54. Samples Relinquished by / Company	
				55. Samples Relinquished by / Company					
								56. Samples Relinquished by / Company	
				57. Samples Relinquished by / Company					
								58. Samples Relinquished by / Company	
				59. Samples Relinquished by / Company					
								60. Samples Relinquished by / Company	
				61. Samples Relinquished by / Company					
								62. Samples Relinquished by / Company	
				63. Samples Relinquished by / Company					
								64. Samples Relinquished by / Company	
				65. Samples Relinquished by / Company					
								66. Samples Relinquished by / Company	
				67. Samples Relinquished by / Company					
								68. Samples Relinquished by / Company	
				69. Samples Relinquished by / Company					
								70. Samples Relinquished by / Company	
				71. Samples Relinquished by / Company					
								72. Samples Relinquished by / Company	
				73. Samples Relinquished by / Company					
								74. Samples Relinquished by / Company	
				75. Samples Relinquished by / Company					
								76. Samples Relinquished by / Company	
				77. Samples Relinquished by / Company					
								78. Samples Relinquished by / Company	
				79. Samples Relinquished by / Company					
								80. Samples Relinquished by / Company	
				81. Samples Relinquished by / Company					
								82. Samples Relinquished by / Company	
				83. Samples Relinquished by / Company					
								84. Samples Relinquished by / Company	
				85. Samples Relinquished by / Company					
								86. Samples Relinquished by / Company	
				87. Samples Relinquished by / Company					
								88. Samples Relinquished by / Company	
				89. Samples Relinquished by / Company					
								90. Samples Relinquished by / Company	
				91. Samples Relinquished by / Company					
								92. Samples Relinquished by / Company	
				93. Samples Relinquished by / Company					
								94. Samples Relinquished by / Company	
				95. Samples Relinquished by / Company					
								96. Samples Relinquished by / Company	
				97. Samples Relinquished by / Company					
								98. Samples Relinquished by / Company	
				99. Samples Relinquished by / Company					
								100. Samples Relinquished by / Company	
				101. Samples Relinquished by / Company					
								102. Samples Relinquished by / Company	
				103. Samples Relinquished by / Company					
								104. Samples Relinquished by / Company	
				105. Samples Relinquished by / Company					
								106. Samples Relinquished by / Company	
				107. Samples Relinquished by / Company					
								108. Samples Relinquished by / Company	
				109. Samples Relinquished by / Company					
								110. Samples Relinquished by / Company	
				111. Samples Relinquished by / Company					
								112. Samples Relinquished by / Company	
				113. Samples Relinquished by / Company					
								114. Samples Relinquished by / Company	
				115. Samples Relinquished by / Company					
								116. Samples Relinquished by / Company	
				117. Samples Relinquished by / Company					
								118. Samples Relinquished by / Company	
				119. Samples Relinquished by / Company					
								120. Samples Relinquished by / Company	
				121. Samples Relinquished by / Company					
								122. Samples Relinquished by / Company	
				123. Samples Relinquished by / Company					
								124. Samples Relinquished by / Company	
				125. Samples Relinquished by / Company					
								126. Samples Relinquished by / Company	
				127. Samples Relinquished by / Company					
								128. Samples Relinquished by / Company	
				129. Samples Relinquished by / Company					
								130. Samples Relinquished by / Company	
				131. Samples Relinquished by / Company					
								132. Samples Relinquished by / Company	
				133. Samples Relinquished by / Company					
								134. Samples Relinquished by / Company	
				135. Samples Relinquished by / Company					
								136. Samples Relinquished by / Company	
				137. Samples Relinquished by / Company					
								138. Samples Relinquished by / Company	
				139. Samples Relinquished by / Company					
								140. Samples Relinquished by / Company	
				141. Samples Relinquished by / Company					
								142. Samples Relinquished by / Company	
				143. Samples Relinquished by / Company					
								144. Samples Relinquished by / Company	
				145. Samples Relinquished by / Company					
								146. Samples Relinquished by / Company	
				147. Samples Relinquished by / Company					
								148. Samples Relinquished by / Company	
				149. Samples Relinquished by / Company					
								150. Samples Relinquished by / Company	
				151. Samples Relinquished by / Company					
								152. Samples Relinquished by / Company	
				153. Samples Relinquished by / Company					
								154. Samples Relinquished by / Company	
				155. Samples Relinquished by / Company					
								156. Samples Relinquished by / Company	
				157. Samples Relinquished by / Company					
								158. Samples Relinquished by / Company	
				159. Samples Relinquished by / Company					
								160. Samples Relinquished by / Company	
				161. Samples Relinquished by / Company					
								162. Samples Relinquished by / Company	
				163. Samples Relinquished by / Company					
								164. Samples Relinquished by / Company	
				165. Samples Relinquished by / Company					
								166. Samples Relinquished by / Company	
				167. Samples Relinquished by / Company					
								168. Samples Relinquished by / Company	
				169. Samples Relinquished by / Company					
								170. Samples Relinquished by / Company	
				171. Samples Relinquished by / Company					
								172. Samples Relinquished by / Company	
				173. Samples Relinquished by / Company					
								174. Samples Relinquished by / Company	
				175. Samples Relinquished by / Company					
								176. Samples Relinquished by / Company	
				177. Samples Relinquished by / Company					
								178. Samples Relinquished by / Company	
				179. Samples Relinquished by / Company					
								180. Samples Relinquished by / Company	
				181. Samples Relinquished by / Company					
								182. Samples Relinquished by / Company	
				183. Samples Relinquished by / Company					
								184. Samples Relinquished by / Company	
				185. Samples Relinquished by / Company					
								186. Samples Relinquished by / Company	
				187. Samples Relinquished by / Company					
								188. Samples Relinquished by / Company	
				189. Samples Relinquished by / Company					
								190. Samples Relinquished by / Company	
				191. Samples Relinquished by / Company					
								192. Samples Relinquished by / Company	
				193. Samples Relinquished by / Company					
								194. Samples Relinquished by / Company	
				195. Samples Relinquished by / Company					
								196. Samples Relinquished by / Company	
				197. Samples Relinquished by / Company					
								198. Samples Relinquished by / Company	
				199. Samples Relinquished by / Company					
								200. Samples Relinquished by / Company	
				201. Samples Relinquished by / Company					
								202. Samples Relinquished by / Company	
				203. Samples Relinquished by / Company					
								204. Samples Relinquished by / Company	
				205. Samples Relinquished by / Company					
								206. Samples Relinquished by / Company	
				207. Samples Relinquished by / Company					
								208. Samples Relinquished by / Company	
				209. Samples Relinquished by / Company					
								210. Samples Relinquished by / Company	
				211. Samples Relinquished by / Company					
								212. Samples Relinquished by / Company	
				213. Samples Relinquished by / Company					
								214. Samples Relinquished by / Company	
				215. Samples Relinquished by / Company					
								216. Samples Relinquished by / Company	
				217. Samples Relinquished by / Company					
								218. Samples Relinquished by / Company	
				219. Samples Relinquished by / Company					
								220. Samples Relinquished by / Company	
				221. Samples Relinquished by / Company					
								222. Samples Relinquished by / Company	
				223. Samples Relinquished by / Company					
								224. Samples Relinquished by / Company	
				225. Samples Relinquished by / Company					
								226. Samples Relinquished by / Company	
				227. Samples Relinquished by / Company					
								228. Samples Relinquished by / Company	
				229. Samples Relinquished by / Company					
								230. Samples Relinquished by / Company	
				231. Samples Relinquished by / Company					
								232. Samples Relinquished by / Company	
				233. Samples Relinquished by / Company					
								234. Samples Relinquished by / Company	
				235. Samples Relinquished by / Company					
								236. Samples Relinquished by / Company	
				237. Samples Relinquished by / Company					
								238. Samples Relinquished by / Company	
				239. Samples Relinquished by / Company					
								240. Samples Relinquished by / Company	
				241. Samples Relinquished by / Company					
								242. Samples Relinquished by / Company	
				243. Samples Relinquished by / Company					
								244. Samples Relinquished by / Company	
				245. Samples Relinquished by / Company					
								246. Samples Relinquished by / Company	
				247. Samples Relinquished by / Company					
								248. Samples Relinquished by / Company	
				249. Samples Relinquished by / Company					
								250. Samples Relinquished by / Company	
				251. Samples Relinquished by / Company					
								252. Samples Relinquished by / Company	
				253. Samples Relinquished by / Company					
								254. Samples Relinquished by / Company	
				255. Samples Relinquished by / Company					
								256. Samples Relinquished by / Company	
				257. Samples Relinquished by / Company					
								258. Samples Relinquished by / Company	
				259. Samples Relinquished by / Company					
								260. Samples Relinquished by / Company</	



Field Chain-of-Custody Record

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.


YORK Project Number

25B0347

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

Page _____ of _____

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time							
Company: RegCom	Company: RegCom			NY	CT	Other: (please specify)		RUSH - Next Day							
Address:	Address:			NJ	PA			RUSH - Two Day							
Phone.:	Phone.:			Analyses Requested				RUSH - Three Day							
Contact:	Contact:							RUSH - Four Day							
E-mail:	E-mail:							RUSH - Five Day							
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		PO Number						Standard (6-9 Day)							
		Preservative (please list number of containers)						PFAS Standard 7-10 Day							
		Matrix Codes						Report Type (circle)							
Samples Collected by: (print AND sign your name)		S - soil/solid/sludge	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO ₃ (nitric acid)	H ₂ SO ₄ (sulfuric acid)	NaOH (sodium hydroxide)	Na ₂ S ₂ O ₃ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Grab or Comp.	QA Report	
		GW - groundwater											G/C	Summary (Results Only)	
		DW - drinking water												NY ASP B Package	
		SW - surface water												NJ Reduced	
		WW - wastewater												NJ DKQP	
		O - Oil	Other:											NJ Full	
														CT RCP	
Sample Identification		Date	Time	Matrix										EDD Type (circle)	
15 H - Nurses Office Fountain Bottle		2/1	AM	DW										EquiS (standard)	
16 H " " " Bubbler														NYSDEC EquiS	
17 H Nurses Office Sink														NJDEP SRP Haz Site	
18 H Teachers Lounge Fountain Bottle														Standard Excel	
19 H " " " Bubbler														CMDP	
20 H By RM 130 Fountain Bottle														Other:	
21 H " " " Bubbler														Regulatory Comparative	
22 H Fountain by RM 142 #1 Bubbler														Compared to the following Regulation(s): (please fill in)	
23 H " " " #2 Bubbler															
24 H Fountain by RM 200 Bottle															
25 H " " " Bubbler															
26 H Fountain By RM 215 Bottle															
27 H " " " Bubbler															
28 H Fountain by RM 233 Bottle														Field Filtered	
29 H " " " Bubbler														Lab Filtered	
Comments:					Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N										
Samples iced/chilled at time of lab pickup? circle YES or NO					Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N										
					COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N										
					Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N										
1. Samples Relinquished by / Company		Date/Time		1. Samples Received by / Company		Date/Time		2. Samples Relinquished by / Company		Date/Time		2. Samples Received by / Company		Date/Time	
				2-7-25 9:40						2-7-25 14:50					
2. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time		3. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time	
4. Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company		Date/Time		Samples Received in LAB by DANIEL FOR CORALES		Date/Time		Temperature		Degrees C	
								2/4/25 20:50				20.0			



Field Chain-of-Custody Record

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.


YORK Project Number

2506347

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

Page _____ of _____

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time							
Company: Reg Com	Company: Regcom			NY	CT	Other: (please specify)		RUSH - Next Day							
Address:	Address:			NJ	PA			RUSH - Two Day							
Phone.:	Phone.:			Analyses Requested				RUSH - Three Day							
Contact:	Contact:							RUSH - Four Day							
E-mail:	E-mail:							RUSH - Five Day							
								Standard (6-9 Day)							
								PFAS Standard 7-10 Day							
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		Matrix Codes		(please list number of containers)				Report Type (circle)							
		S - soil/solid/sludge						QA Report							
		GW - groundwater						Summary (Results Only)							
		DW - drinking water						NY ASP B Package							
		SW - surface water						NJ Reduced							
		WW - wastewater						NJ DKQP							
		O - Oil						NJ Full							
		Other						CT RCP							
Samples Collected by: (print AND sign your name)								Grab or Comp. G/C							
Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO ₃ (nitric acid)	H ₂ SO ₄ (sulfuric acid)	NaOH (sodium hydroxide)	Na ₂ S ₂ O ₃ (sodium thio.)	Trizma	Ammonium Acetate	Other:	EDD Type (circle)	
30H Fountain by RM244 Bottle	2/1	Am	DW											EQUIS (standard)	
31H Kitchen Handwash Sink #1														NYSDEC EQUIS	
32H " " Sink #2														NJDEP SRP Haz Site	
33H " " Sink #3														Standard Excel	
34H " " Sink #4														CMDP	
35H " " Sink #5														Other:	
36H " " Serving side Sink #6														Regulatory Comparative	
37H Kitchen Ice machine														Compared to the following Regulation(s): (please fill in)	
38H District Office Lounge Sink															
39H " " Area Fountain Bottle															
40H " " " Bubbler															
41H " " Lounge Coffee Spout															
42H Garage Sink															
43H " " Bottle Filler														Field Filtered	
												Lab Filtered			
Comments:				Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N											
				Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N											
				COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N											
				Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N											
Samples iced/chilled at time of lab pickup? Circle YES or NO															
1. Samples Relinquished by / Company		Date/Time		1. Samples Received by / Company		Date/Time		2. Samples Relinquished by / Company		Date/Time		2. Samples Received by / Company		Date/Time	
						2-7-25 9:40								2-7-25 14:50	
2. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time		3. Samples Received by / Company		Date/Time		3. Samples Received by / Company		Date/Time	
4. Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company		Date/Time		Samples Received in LAB by		Date/Time		Temperature		Degrees C	
								NCL		2/7/25 20:50		20.0			



Field Chain-of-Custody Record

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.


YORK Project Number

25B0347

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

Page _____ of _____

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time					
Company: Reg Com	Company: Reg Com	Ardsley Middle School		NY	CT	Other: (please specify)		RUSH - Next Day					
Address: 245 Albany Ave Tarrytown NY 10594	Address: "	water		NJ	PA			RUSH - Two Day					
Phone: 914-434-6513	Phone: "	PO Number		Analyses Requested				RUSH - Three Day					
Contact: E. Com	Contact: "							RUSH - Four Day					
E-mail: Regcomp2@hotmail.com	E-mail: "	Preservative (please list number of containers)		G/C				RUSH - Five Day					
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		Matrix Codes						Standard (6-9 Day)					
Samples Collected by: (print AND sign your name)		S - soil/solid/sludge	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO ₃ (nitric acid)	H ₂ SO ₄ (sulfuric acid)	NaOH (sodium hydroxide)	Na ₂ S ₂ O ₃ (sodium thio.)	Trizma	Ammonium Acetate	Other:	PFAS Standard 7-10 Day
Sample Identification	Date	Time	Matrix										Report Type (circle)
1M Commons Area Fountain Bottle	2/1	AM	DW										QA Report
2M " " " Bubbler													Summary (Results Only)
3M " " Office Sink													NY ASP B Package
4M Fountain by RM 206 Bubbler													NJ Reduced
5M " " " Bottle													NJ DKQP
6M Fountain by RM 217 Bottle													NJ Full
7M " " " Bubbler													CT RCP
8M Faculty RM 217 Bottle Filler													EDD Type (circle)
9M " " " Bubbler													EquiS (standard)
10M " " " Sink													NYSDEC EquiS
11M Fountain by Nurses RM Bottle													NJDEP SRP Haz Site
12M " " " Bubbler													Standard Excel
13M Nurses Office sink #1													CMDP
14M " " " Sink #2													Other:
15M CA Nurses Ice machine													Regulatory Comparative
Comments:				Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N									
				Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N									
				COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N									
				Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N									
Samples iced/chilled at time of lab pickup? circle Yes or No													
1. Samples Relinquished by / Company		Date/Time		1. Samples Received by / Company		Date/Time		2. Samples Relinquished by / Company		Date/Time			
M. M. M.		2/1 12:00pm		J. S.		2-7-25 9:30		J. S.		2-7-25 14:50			
2. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time		3. Samples Received by / Company		Date/Time			
4. Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company		Date/Time		Samples Received in LAB by		Date/Time		Temperature	
								NCC		2/7/25 20:50		20.0 Degrees C	



Field Chain-of-Custody Record

YORK Project Number


25B0347

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

Page ____ of ____

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time																			
Company: <u>Reg Com</u>	Company: <u>Reg Com</u>	Address:		<u>Ardley Middle School</u> <u>Water</u>		NY ☒	CT ☒	Other: (please specify)		RUSH - Next Day																	
						NJ ☐	PA ☐		RUSH - Two Day																		
Phone: _____		Phone: _____		PO Number		Analyses Requested				RUSH - Three Day																	
Contact: _____		Contact: _____		Preservative (please list number of containers)						RUSH - Four Day																	
E-mail: _____		E-mail: _____								RUSH - Five Day																	
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		Matrix Codes S - soil/solid/sludge GW - groundwater DW - drinking water SW - surface water WW - wastewater O - Oil Other _____		Unpreserved		HCl (hydrochloric acid)		MeOH (methanol)		HNO ₃ (nitric acid)		H ₂ SO ₄ (sulfuric acid)		NaOH (sodium hydroxide)		Na ₂ S ₂ O ₃ (sodium thio.)		Trizma		Ammonium Acetate		Other: _____		Grab or Comp. G/C		Report Type (circle)	
																										QA Report	
Samples Collected by: (print AND sign your name)																						Summary (Results Only)					
Sample Identification		Date	Time	Matrix																			EDD Type (circle)				
15 M (B) Nurse Ice machine		2/1	AM	DW																			EQUIS (standard)				
16 M Gym Boys Side Fountain Bottle																							NYSDEC EQUIS				
17 M " " " " Bubblers																							NJDEP SRP Haz Site				
18 M Gym Girls Side Fountain Bottle																							Standard Excel				
19 M " " " " Bubblers																							CMDP				
20 M Hallway in Pool Area by Boys Bottle																							Other: _____				
21 M " " " " Bubblers																							Regulatory Comparative				
22 M Pool Area Fountain #1 Bottle																							Compared to the following Regulation(s): (please fill in)				
23 M " " " " #1 Bubblers																											
24 M " " " " #2 Bottle																											
25 M " " " " #2 Bubblers																											
26 M Fountain by Andrianna PLEI Bottle																											
27 M " " " " Bubblers																											
28 M Fountain by Music Suite Bubblers																							Field Filtered				
29 M Fountain by RM 306 Bubblers																							Lab Filtered				
Comments:					Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N Custody Seals: Y / ☒ Containers Intact: Y / ☒ COC/Labels Agree: Y / ☒ Preservation Confirmed: Y / ☒ COC Complete: Y / ☒ COC Received: Y / ☒ Appropriate Sample Volumes: Y / ☒ Appropriate Sample Containers: Y / ☒ Cooler Temperature Confirmed: Y / ☒ Samples Submitted within Holding Times: Y / ☒ Corrective Action Form Required: Y / ☒																						
Samples iced/chilled at time of lab pickup? circle Yes or No																											
1. Samples Relinquished by / Company		Date/Time		1. Samples Received by / Company		Date/Time		2. Samples Relinquished by / Company		Date/Time		2. Samples Received by / Company		Date/Time													
<u>M/K</u>		2/1 12:00pm		<u>[Signature]</u>		2-7-25 9:40		<u>[Signature]</u>		2-7-25 14:50																	
2. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time		3. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time													
4. Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company		Date/Time		4. Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company		Date/Time													



Field Chain-of-Custody Record

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.


120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number

25B0347

Page _____ of _____

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time									
Company: Reg Corn	Company: Reg Corn	Ardsley Middle School water		NY	CT	Other: (please specify)		RUSH - Next Day									
Address:	Address:			NJ	PA			RUSH - Two Day									
Phone.:	Phone.:			Analyses Requested				RUSH - Three Day									
Contact:	Contact:							RUSH - Four Day									
E-mail:	E-mail:							RUSH - Five Day									
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		Matrix Codes S - soil/solid/sludge GW - groundwater DW - drinking water SW - surface water WW - wastewater O - Oil Other		PO Number						Standard (6-9 Day)							
				Preservative (please list number of containers)						PFAS Standard 7-10 Day							
Samples Collected by: (print AND sign your name)				Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO ₃ (nitric acid)	H ₂ SO ₄ (sulfuric acid)	NaOH (sodium hydroxide)	Na ₂ S ₂ O ₃ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Grab or Comp: G/C	Report Type (circle) QA Report Summary (Results Only) NY ASP B Package NJ Reduced NJ DKQP NJ Full CT RCP		
Sample Identification		Date	Time	Matrix													EDD Type (circle)
30M Fountain by RM 405 Bubble		2/1	AM	DW													EquiS (standard)
31M RM 400 Sink #1																	NYSDEC EquiS
32M " " " #2																	NJDEP SRP Haz Site
33M " " " #3																	Standard Excel
34M " " " #4																	CMDP
35M " " " #5																	Other:
(A) 36M RM 404B Ice machine																	Regulatory Comparative
(B) 36M " " " " "																	Compared to the following Regulation(s): (please fill in)
37M Kitchen Sink #1																	Field Filtered
38M " " " #2																	Lab Filtered
39M " " " #3																	
40M " " Jug Filler																	
41M (A) Kitchen Ice machine																	
41M (B) " " " "																	
Comments:					Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N												
					Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N												
					COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N												
Samples iced/chilled at time of lab pickup? circle Yes or No					Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N												
1. Samples Relinquished by / Company		Date/Time		1. Samples Received by / Company		Date/Time		2. Samples Relinquished by / Company		Date/Time							
[Signature]		2/1 12:00 PM		[Signature]		2-7-25 9:40		[Signature]		2-7-25 14:50							
2. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time		3. Samples Received by / Company		Date/Time							
4. Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company		Date/Time		Sample Received in LAB by [Signature] FOR DANIEL CORAUS 2/7/25 20:50				Temperature 20.0 Degrees C					



Technical Report

prepared for:

Regulatory Compliance

245 Albany Ave.

Thornwood NY, 10594

Attention: Ernest Coon

Report Date: 02/28/2025

Client Project ID: Concord Ardsley School

York Project (SDG) No.: 25B1129

Stratford, CT Laboratory IDs:
NY:10854, NJ: CT005, PA: 68-0440, CT: PH-0723



Richmond Hill, NY Laboratory IDs:
NY:12058, NJ: NY037, CT: PH-0721, NH: 2097,
EPA: NY01600

120 RESEARCH DRIVE
www.YORKLAB.com

STRATFORD, CT 06615
(203) 325-1371



132-02 89th AVENUE
FAX (203) 357-0166

RICHMOND HILL, NY 11418
ClientServices@yorklab.com

Regulatory Compliance

245 Albany Ave.
Thornwood NY, 10594
Attention: Ernest Coon

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on February 20, 2025 and listed below. The project was identified as your project: **Concord Ardsley School**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
25B1129-01	1 Bubbler Next to RM S4	Drinking Water	02/15/2025	02/20/2025
25B1129-02	2 Bottle filler to RM S4	Drinking Water	02/15/2025	02/20/2025
25B1129-03	3 Bubbler Next to RM 50C	Drinking Water	02/15/2025	02/20/2025
25B1129-04	4 Bottle Filter Next to RM 50c	Drinking Water	02/15/2025	02/20/2025
25B1129-05	5 Bubbler by RM 3	Drinking Water	02/15/2025	02/20/2025
25B1129-06	6 Bottle filler RM 3	Drinking Water	02/15/2025	02/20/2025
25B1129-07	7 Porcelian Faintain bg Rm11	Drinking Water	02/15/2025	02/20/2025
25B1129-08	8 Bubbler by RM 31	Drinking Water	02/15/2025	02/20/2025
25B1129-09	9 Bottle filler by RM 31	Drinking Water	02/15/2025	02/20/2025
25B1129-10	10 Bubbler by Room 35	Drinking Water	02/15/2025	02/20/2025
25B1129-11	11 Bottle Filler by room 35	Drinking Water	02/15/2025	02/20/2025
25B1129-12	12 Bubbler by RM #25	Drinking Water	02/15/2025	02/20/2025
25B1129-13	13 Bottle filler by RM #25	Drinking Water	02/15/2025	02/20/2025
25B1129-14	14 Bubbler by RM 41 & 43	Drinking Water	02/15/2025	02/20/2025
25B1129-15	15 Bottle filler by RM 41 & 43	Drinking Water	02/15/2025	02/20/2025
25B1129-16	16 Staff Lounge sink	Drinking Water	02/15/2025	02/20/2025
25B1129-17	17 Staff Lounge water fountain Bubbler	Drinking Water	02/15/2025	02/20/2025
25B1129-18	18 Staff lounge Bottle filler	Drinking Water	02/15/2025	02/20/2025
25B1129-19	19 Bubbler outside Gym	Drinking Water	02/15/2025	02/20/2025
25B1129-20	20 Bottle filler outside Gym	Drinking Water	02/15/2025	02/20/2025
25B1129-21	21 Bubbler in upper cafeteria	Drinking Water	02/15/2025	02/20/2025
25B1129-22	22 Handwash sink #1 in Kitchen	Drinking Water	02/15/2025	02/20/2025

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
25B1129-23	23 Kitchen sink #2	Drinking Water	02/15/2025	02/20/2025
25B1129-24	24 Kitchen sink #3	Drinking Water	02/15/2025	02/20/2025
25B1129-25	25 Kitchen Island sink #4	Drinking Water	02/15/2025	02/20/2025
25B1129-26	26 Kitchen Island sink #5	Drinking Water	02/15/2025	02/20/2025
25B1129-27	27A Kitchen free machine	Drinking Water	02/15/2025	02/20/2025
25B1129-28	27B Kitchen free machine	Drinking Water	02/15/2025	02/20/2025
25B1129-29	28 Primary cafe Bubbler	Drinking Water	02/15/2025	02/20/2025
25B1129-30	29 Primary cafe Bottle filler	Drinking Water	02/15/2025	02/20/2025
25B1129-31	30 Bubbler by Library Lobby	Drinking Water	02/15/2025	02/20/2025
25B1129-32	31 Bottle filler by Libarary Lobby	Drinking Water	02/15/2025	02/20/2025
25B1129-33	32 Bottle filler by Primary Entrance	Drinking Water	02/15/2025	02/20/2025
25B1129-34	33 Bubbler by Primary entrance	Drinking Water	02/15/2025	02/20/2025
25B1129-35	34 Bubbler by Rear entrance	Drinking Water	02/15/2025	02/20/2025
25B1129-36	35 Bottle filler by rear entrance	Drinking Water	02/15/2025	02/20/2025
25B1129-37	36 Nurses sink #1	Drinking Water	02/15/2025	02/20/2025
25B1129-38	37 Nurses sink #2 Bathroom	Drinking Water	02/15/2025	02/20/2025
25B1129-39	38 main office sink	Drinking Water	02/15/2025	02/20/2025
25B1129-40	39A Main office ice machine	Drinking Water	02/15/2025	02/20/2025
25B1129-41	39B Main office ice machine	Drinking Water	02/15/2025	02/20/2025

General Notes for York Project (SDG) No.: 25B1129

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854, NJ Cert No. CT005, PA Cert No. 68-04440, CT Cert No. PH-0723; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058, NJ Cert No. NY037, CT Cert No. PH-0721, NH Cert No. 2097, EPA Cert No. NY01600.


Approved By:



Cassie L. Mosher
Laboratory Manager

Date: 02/28/2025





Sample Information

Client Sample ID: 1 Bubbler Next to RM S4

York Sample ID: 25B1129-01

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix

Drinking Water

Collection Date/Time

February 15, 2025 10:00 am

Date Received

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:33	cw

Sample Information

Client Sample ID: 2 Bottle filler to RM S4

York Sample ID: 25B1129-02

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix

Drinking Water

Collection Date/Time

February 15, 2025 10:00 am

Date Received

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:34	cw

Sample Information

Client Sample ID: 3 Bubbler Next to RM 50C

York Sample ID: 25B1129-03

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix

Drinking Water

Collection Date/Time

February 15, 2025 10:00 am

Date Received

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:36	cw

Sample Information

Client Sample ID: 4 Bottle Filter Next to RM 50c

York Sample ID: 25B1129-04

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix


Drinking Water

Collection Date/Time

February 15, 2025 10:00 am

Date Received

02/20/2025



Sample Information

Client Sample ID: 4 Bottle Filter Next to RM 50c

York Sample ID: 25B1129-04

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:37	cw

Sample Information

Client Sample ID: 5 Bubbler by RM 3

York Sample ID: 25B1129-05

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:41	cw

Sample Information

Client Sample ID: 6 Bottle filler RM 3

York Sample ID: 25B1129-06

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:42	cw

Sample Information

Client Sample ID: 7 Porcelian Faintain bg Rm11

York Sample ID: 25B1129-07

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water


February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 7 Porcelian Faintain bg Rm11

York Sample ID: 25B1129-07

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	5.47	M-PbE X	ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/24/2025 10:55	02/24/2025 13:44	cw

Sample Information

Client Sample ID: 8 Bubbler by RM 31

York Sample ID: 25B1129-08

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/24/2025 10:55	02/24/2025 13:45	cw

Sample Information

Client Sample ID: 9 Bottle filler by RM 31

York Sample ID: 25B1129-09

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/24/2025 10:55	02/24/2025 13:46	cw

Sample Information

Client Sample ID: 10 Bubbler by Room 35

York Sample ID: 25B1129-10

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
---------	-----------	--------	------	-------	--------------------	----------	------------------	-----------------------	-----------------------	---------



Sample Information

Client Sample ID: 10 Bubbler by Room 35

York Sample ID: 25B1129-10

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix

Drinking Water

Collection Date/Time

February 15, 2025 10:00 am

Date Received

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:48	cw

Sample Information

Client Sample ID: 11 Bottle Filler by room 35

York Sample ID: 25B1129-11

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix

Drinking Water

Collection Date/Time

February 15, 2025 10:00 am

Date Received

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:49	cw

Sample Information

Client Sample ID: 12 Bubbler by RM #25

York Sample ID: 25B1129-12

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix

Drinking Water

Collection Date/Time

February 15, 2025 10:00 am

Date Received

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:50	cw

Sample Information

Client Sample ID: 13 Bottle filler by RM #25

York Sample ID: 25B1129-13

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix

Drinking Water

Collection Date/Time

February 15, 2025 10:00 am


Date Received

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 13 Bottle filler by RM #25

York Sample ID: 25B1129-13

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:52	cw

Sample Information

Client Sample ID: 14 Bubbler by RM 41 & 43

York Sample ID: 25B1129-14

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:53	cw

Sample Information

Client Sample ID: 15 Bottle filler by RM 41 & 43

York Sample ID: 25B1129-15

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:55	02/24/2025 13:57	cw

Sample Information

Client Sample ID: 16 Staff Lounge sink

York Sample ID: 25B1129-16

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
120 RESEARCH DRIVE		STRATFORD, CT 06615				132-02 89th AVENUE		RICHMOND HILL, NY 11418		
www.YORKLAB.com		(203) 325-1371				FAX (203) 357-0166		ClientServices@		



Sample Information

Client Sample ID: 16 Staff Lounge sink

York Sample ID: 25B1129-16

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

7439-92-1	Lead	ND	ug/L	1.00	1	EPA 200.8	02/24/2025 10:55	02/24/2025 13:59	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044									

Sample Information

Client Sample ID: 17 Staff Lounge water fountain Bubbler

York Sample ID: 25B1129-17

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/24/2025 10:55	02/24/2025 14:00	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044										

Sample Information

Client Sample ID: 18 Staff lounge Bottle filler

York Sample ID: 25B1129-18

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/24/2025 10:57	02/24/2025 14:07	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044										

Sample Information

Client Sample ID: 19 Bubbler outside Gym

York Sample ID: 25B1129-19

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/24/2025 10:57	02/24/2025 14:09	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044										



Sample Information

Client Sample ID: 19 Bubbler outside Gym

York Sample ID: 25B1129-19

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Sample Information

Client Sample ID: 20 Bottle filler outside Gym

York Sample ID: 25B1129-20

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:13	cw

Sample Information

Client Sample ID: 21 Bubbler in upper cafeteria

York Sample ID: 25B1129-21

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:15	cw

Sample Information

Client Sample ID: 22 Handwash sink #1 in Kitchen

York Sample ID: 25B1129-22

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:16	cw



Sample Information

Client Sample ID: 23 Kitchen sink #2

York Sample ID: 25B1129-23

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix

Drinking Water

Collection Date/Time

February 15, 2025 10:00 am

Date Received

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:17	cw

Sample Information

Client Sample ID: 24 Kitchen sink #3

York Sample ID: 25B1129-24

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix

Drinking Water

Collection Date/Time

February 15, 2025 10:00 am

Date Received

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:19	cw

Sample Information

Client Sample ID: 25 Kitchen Island sink #4

York Sample ID: 25B1129-25

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix

Drinking Water

Collection Date/Time

February 15, 2025 10:00 am

Date Received

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:20	cw

Sample Information

Client Sample ID: 26 Kitchen Island sink #5

York Sample ID: 25B1129-26

York Project (SDG) No.

25B1129

Client Project ID

Concord Ardsley School

Matrix

Drinking Water

Collection Date/Time

February 15, 2025 10:00 am


Date Received

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 26 Kitchen Island sink #5

York Sample ID: 25B1129-26

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	2.27		ug/L	1.00	1	EPA 200.8	02/24/2025 10:57	02/24/2025 14:21	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 27A Kitchen free machine

York Sample ID: 25B1129-27

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/24/2025 10:57	02/24/2025 14:23	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 27B Kitchen free machine

York Sample ID: 25B1129-28

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/24/2025 10:57	02/24/2025 14:24	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 28 Primary cafe Bubbler

York Sample ID: 25B1129-29

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
---------	-----------	--------	------	-------	--------------------	----------	------------------	-----------------------	-----------------------	---------



Sample Information

Client Sample ID: 28 Primary cafe Bubbler

York Sample ID: 25B1129-29

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:25	cw

Sample Information

Client Sample ID: 29 Primary cafe Bottle filler

York Sample ID: 25B1129-30

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:29	cw

Sample Information

Client Sample ID: 30 Bubbler by Library Lobby

York Sample ID: 25B1129-31

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water

February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:31	cw

Sample Information

Client Sample ID: 31 Bottle filler by Library Lobby

York Sample ID: 25B1129-32

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B1129

Concord Ardsley School

Drinking Water


February 15, 2025 10:00 am

02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 31 Bottle filler by Libarary Lobby

York Sample ID: 25B1129-32

<u>York Project (SDG) No.</u> 25B1129	<u>Client Project ID</u> Concord Ardsley School	<u>Matrix</u> Drinking Water	<u>Collection Date/Time</u> February 15, 2025 10:00 am	<u>Date Received</u> 02/20/2025
--	--	---------------------------------	---	------------------------------------

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:32	cw

Sample Information

Client Sample ID: 32 Bottle filler by Primary Entrance

York Sample ID: 25B1129-33

<u>York Project (SDG) No.</u> 25B1129	<u>Client Project ID</u> Concord Ardsley School	<u>Matrix</u> Drinking Water	<u>Collection Date/Time</u> February 15, 2025 10:00 am	<u>Date Received</u> 02/20/2025
--	--	---------------------------------	---	------------------------------------

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:34	cw

Sample Information

Client Sample ID: 33 Bubbler by Primary entrance

York Sample ID: 25B1129-34

<u>York Project (SDG) No.</u> 25B1129	<u>Client Project ID</u> Concord Ardsley School	<u>Matrix</u> Drinking Water	<u>Collection Date/Time</u> February 15, 2025 10:00 am	<u>Date Received</u> 02/20/2025
--	--	---------------------------------	---	------------------------------------

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/24/2025 10:57	02/24/2025 14:35	cw

Sample Information

Client Sample ID: 34 Bubbler by Rear entrance

York Sample ID: 25B1129-35

<u>York Project (SDG) No.</u> 25B1129	<u>Client Project ID</u> Concord Ardsley School	<u>Matrix</u> Drinking Water	<u>Collection Date/Time</u> February 15, 2025 10:00 am	<u>Date Received</u> 02/20/2025
--	--	---------------------------------	---	------------------------------------


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
120 RESEARCH DRIVE www.YORKLAB.com		STRATFORD, CT 06615 (203) 325-1371				132-02 89th AVENUE FAX (203) 357-0166		RICHMOND HILL, NY 11418 ClientServices@		



Sample Information

Client Sample ID: 34 Bubbler by Rear entrance

York Sample ID: 25B1129-35

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

7439-92-1	Lead	ND	ug/L	1.00	1	EPA 200.8	02/24/2025 10:57	02/24/2025 14:36	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044									

Sample Information

Client Sample ID: 35 Bottle filler by rear entrance

York Sample ID: 25B1129-36

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/24/2025 10:57	02/24/2025 14:38	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044										

Sample Information

Client Sample ID: 36 Nurses sink #1

York Sample ID: 25B1129-37

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	2.19		ug/L	1.00	1	EPA 200.8	02/24/2025 10:57	02/24/2025 14:39	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044										

Sample Information

Client Sample ID: 37 Nurses sink #2 Bathroom

York Sample ID: 25B1129-38

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	3.78		ug/L	1.00	1	EPA 200.8	02/24/2025 15:24	02/25/2025 12:56	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044										



Sample Information

Client Sample ID: 37 Nurses sink #2 Bathroom

York Sample ID: 25B1129-38

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Sample Information

Client Sample ID: 38 main office sink

York Sample ID: 25B1129-39

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/24/2025 15:24	02/25/2025 12:59	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 39A Main office ice machine

York Sample ID: 25B1129-40

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	9.56	M-PbE	ug/L	1.00	1	EPA 200.8	02/24/2025 15:24	02/25/2025 13:00	cw
				X						
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 39B Main office ice machine

York Sample ID: 25B1129-41

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B1129	Concord Ardsley School	Drinking Water	February 15, 2025 10:00 am	02/20/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	7.27	M-CCV	ug/L	1.00	1	EPA 200.8	02/24/2025 07:49	02/24/2025 16:19	cw
				1						
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		



Sample and Data Qualifiers Relating to This Work Order

M-PbEX	Lead result exceeds regulatory limit
M-CCV1	The recovery for this element in the Continuing Calibration Verification (CCV) was outside the 90-110% recovery criteria.

Definitions and Other Explanations

*	Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
ND	NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
RL	REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
LOQ	LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon current NELAC/TNI Standards and applies to all analyses.
LOD	LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW-846.
MDL	METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
Reported to	This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
NR	Not reported
RPD	Relative Percent Difference
Wet	The data has been reported on an as-received (wet weight) basis
Low Bias	Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
High Bias	High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
Non-Dir.	Non-dir. flag (Non-Directional Bias) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.

If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.

For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.



Field Chain-of-Custody Record

YORK Project Number


25 B1129


York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

Page of

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time							
Company: Reg Com	Company: Reg Com	Concord Aidsley School		NY	☒	CT		RUSH - Next Day							
Address: 245 Albany Ave Teterboro, NJ 07644	Address: 245 Albany Ave Teterboro, NJ 07644			NJ		PA		RUSH - Two Day							
Phone: 201-439-6513	Phone: 201-439-6513	PO Number		Analyses Requested				RUSH - Three Day							
Contact: E. Can	Contact: E. Can							RUSH - Four Day							
E-mail: Regcomp2@hotmail.com	E-mail: Regcomp2@hotmail.com	Preservative (please list number of containers)						RUSH - Five Day							
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		Matrix Codes						Standard (6-9 Day) ☒							
		S - soil/solid/sludge GW - groundwater DW - drinking water SW - surface water WW - wastewater O - Oil Other						PFAS Standard 7-10 Day							
Samples Collected by: (print AND sign your name)		Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO ₃ (nitric acid)	H ₂ SO ₄ (sulfuric acid)	NaOH (sodium hydroxide)	Na ₂ S ₂ O ₃ (sodium thio)	Trizma	Ammonium Acetate	Other:	Report Type (circle) QA Report Summary (Results Only) ☒ NY ASP B Package NJ Reduced NJ DKQP NJ Full CT RCP			
Sample Identification	Date	Time	Matrix									Grab or Comp. G/C	EDD Type (circle) EQUIS (standard) ☒ NYSDEC EQUIS NJDEP SRP Haz Site Standard Excel CMDP Other:		
1 Bubbler Next to RM 54	2/15	Am	DW										Regulatory Comparative Compared to the following Regulation(s): (please fill in)		
2 Bottle Filler " " "													Field Filtered		
3 Bubbler Next to RM 50C													Lab Filtered		
4 Bottle Filler " " "															
5 Bubbler by RM 3															
6 Bottle Filler " " "															
7 Porcelain Fountain by RM 11															
8 Bubbler by RM 31															
9 Bottle Filler " " "															
10 Bubbler by room 35															
11 Bottle Filler " " "															
12 Bubbler by RM #25															
13 Bottle Filler " " "															
14 Bubbler by RM 41 P43															
15 Bottle Filler by " " "															
Comments:				Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N Custody Seals: Y / ☒ Containers Intact: ☒ / N COC/Labels Agree: ☒ / N Preservation Confirmed: ☒ / N COC Complete: ☒ / N COC Received: ☒ / N Appropriate Sample Volumes: ☒ / N Appropriate Sample Containers: ☒ / N Cooler Temperature Confirmed: ☒ / N Samples Submitted within Holding Times: ☒ / N Corrective Action Form Required: Y / ☒											
Samples Relinquished by / Company Thomson		Date/Time 2/15/25		1. Samples Received by / Company [Signature]				Date/Time 2-20-25 10:00				2. Samples Relinquished by / Company [Signature]		Date/Time 2-20-25 14:10	
Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company				Date/Time				3. Samples Received by / Company		Date/Time	
Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company				Date/Time				Samples Received in LAB by [Signature]		Date/Time 2/20/25 14:10	
														Temperature 19.8 Degrees C	





Technical Report

prepared for:

Regulatory Compliance

245 Albany Ave.

Thornwood NY, 10594

Attention: Ernest Coon

Report Date: 02/28/2025

Client Project ID: Ardsley Middle/Highschool Water

York Project (SDG) No.: 25B0347

Stratford, CT Laboratory IDs:
NY:10854, NJ: CT005, PA: 68-0440, CT: PH-0723



Richmond Hill, NY Laboratory IDs:
NY:12058, NJ: NY037, CT: PH-0721, NH: 2097,
EPA: NY01600

120 RESEARCH DRIVE
www.YORKLAB.com

STRATFORD, CT 06615
(203) 325-1371

132-02 89th AVENUE
FAX (203) 357-0166

RICHMOND HILL, NY 11418
ClientServices@yorklab.com

Report Date: 02/28/2025
Client Project ID: Ardsley Middle/Highschool Water
York Project (SDG) No.: 25B0347

Regulatory Compliance
245 Albany Ave.
Thornwood NY, 10594
Attention: Ernest Coon

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on February 07, 2025 and listed below. The project was identified as your project: **Ardsley Middle/Highschool Water**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
25B0347-44	43H Garage Bottle Filler	Drinking Water	02/01/2025	02/07/2025
25B0347-45	1M Commons Area Fountain Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-46	2M Commons Area Fountain Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-47	3M Commons Area Office Sink	Drinking Water	02/01/2025	02/07/2025
25B0347-48	4M Fountain by Rm 206 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-49	5M Fountain by Rm 206 Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-50	6M Fountain by Rm 217 Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-51	7M Fountain by Rm 217 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-52	8M Faculty Rm 217 Bottle Filler	Drinking Water	02/01/2025	02/07/2025
25B0347-53	9M Faculty Rm 217 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-54	10M Faculty Rm 217 Sink	Drinking Water	02/01/2025	02/07/2025
25B0347-55	11M Fountain by Nurses Rm Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-56	12M Fountain by Nurses Rm Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-57	13M Nurses Office Sink #1	Drinking Water	02/01/2025	02/07/2025
25B0347-58	14M Nurses Office Sink #2	Drinking Water	02/01/2025	02/07/2025
25B0347-59	15M (A) Nurses Ice Machine	Drinking Water	02/01/2025	02/07/2025
25B0347-60	15M (B) Nurses Ice Machine	Drinking Water	02/01/2025	02/07/2025
25B0347-61	16M Gym Boys Side Fountain Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-62	17M Gym Boys Side Fountain Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-63	18M Gym Girls Side Fountain Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-64	19M Gym Girls Side Fountain Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-65	20M Hallway in Pool Area by Boys Bottle	Drinking Water	02/01/2025	02/07/2025

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
25B0347-66	21M Hallway in Pool Area by Boys Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-67	22M Pool Area Fountain #1 Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-68	23M Pool Area Fountain #1 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-69	24M Pool Area Fountain #2 Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-70	25M Pool Area Fountain #2 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-71	26M Fountain by Auditorium & LGI Bottle	Drinking Water	02/01/2025	02/07/2025
25B0347-72	27M Fountain by Auditorium & LGI Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-73	28M Fountain by Music Suite Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-74	29M Fountain by Rm 306 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-75	30M Fountain by Rm 405 Bubbler	Drinking Water	02/01/2025	02/07/2025
25B0347-76	31M Rm 400 Sink #1	Drinking Water	02/01/2025	02/07/2025
25B0347-77	32M Rm 400 Sink #2	Drinking Water	02/01/2025	02/07/2025
25B0347-78	33M Rm 400 Sink #3	Drinking Water	02/01/2025	02/07/2025
25B0347-79	34M Rm 400 Sink #4	Drinking Water	02/01/2025	02/07/2025
25B0347-80	35M Rm 400 Sink #5	Drinking Water	02/01/2025	02/07/2025
25B0347-81	36M (A) Rm 404B Ice Machine	Drinking Water	02/01/2025	02/07/2025
25B0347-82	36M (B) Rm 404B Ice Machine	Drinking Water	02/01/2025	02/07/2025
25B0347-83	37M Kitchen Sink #1	Drinking Water	02/01/2025	02/07/2025
25B0347-84	38M Kitchen Sink #2	Drinking Water	02/01/2025	02/07/2025
25B0347-85	39M Kitchen Sink #3	Drinking Water	02/01/2025	02/07/2025
25B0347-86	40M Kitchen Jug Filler	Drinking Water	02/01/2025	02/07/2025
25B0347-87	41M (A) Kitchen Ice Machine	Drinking Water	02/01/2025	02/07/2025
25B0347-88	41M (B) Kitchen Ice Machine	Drinking Water	02/01/2025	02/07/2025

General Notes for York Project (SDG) No.: 25B0347

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854, NJ Cert No. CT005, PA Cert No. 68-04440, CT Cert No. PH-0723; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058, NJ Cert No. NY037, CT Cert No. PH-0721, NH Cert No. 2097, EPA Cert No. NY01600.


Approved By:



Cassie L. Mosher
Laboratory Manager

Date: 02/28/2025





Sample Information

Client Sample ID: 43H Garage Bottle Filler

York Sample ID: 25B0347-44

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	6.85		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 08:00	02/13/2025 15:13	cw

Sample Information

Client Sample ID: 1M Commons Area Fountain Bottle

York Sample ID: 25B0347-45

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:36	02/13/2025 13:17	cw

Sample Information

Client Sample ID: 2M Commons Area Fountain Bubbler

York Sample ID: 25B0347-46

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:36	02/13/2025 13:18	cw

Sample Information

Client Sample ID: 3M Commons Area Office Sink

York Sample ID: 25B0347-47

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received


25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025



Sample Information

Client Sample ID: 3M Commons Area Office Sink

York Sample ID: 25B0347-47

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	8.27	M-PbE X	ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:36	02/13/2025 13:19	cw

Sample Information

Client Sample ID: 4M Fountain by Rm 206 Bubbler

York Sample ID: 25B0347-48

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.37		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:36	02/13/2025 13:21	cw

Sample Information

Client Sample ID: 5M Fountain by Rm 206 Bottle

York Sample ID: 25B0347-49

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.06		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:36	02/13/2025 13:25	cw

Sample Information

Client Sample ID: 6M Fountain by Rm 217 Bottle

York Sample ID: 25B0347-50

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water


February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 6M Fountain by Rm 217 Bottle

York Sample ID: 25B0347-50

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.23		ug/L	1.00	1	EPA 200.8	02/13/2025 09:36	02/13/2025 13:26	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 7M Fountain by Rm 217 Bubbler

York Sample ID: 25B0347-51

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.06		ug/L	1.00	1	EPA 200.8	02/13/2025 08:00	02/13/2025 15:15	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 8M Faculty Rm 217 Bottle Filler

York Sample ID: 25B0347-52

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:36	02/13/2025 13:27	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 9M Faculty Rm 217 Bubbler

York Sample ID: 25B0347-53

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
---------	-----------	--------	------	-------	-----------------	----------	------------------	--------------------	--------------------	---------



Sample Information

Client Sample ID: 9M Faculty Rm 217 Bubbler

York Sample ID: 25B0347-53

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:36	02/13/2025 13:29	cw

Sample Information

Client Sample ID: 10M Faculty Rm 217 Sink

York Sample ID: 25B0347-54

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	2.42		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:36	02/13/2025 13:30	cw

Sample Information

Client Sample ID: 11M Fountain by Nurses Rm Bottle

York Sample ID: 25B0347-55

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:36	02/13/2025 13:31	cw

Sample Information

Client Sample ID: 12M Fountain by Nurses Rm Bubbler

York Sample ID: 25B0347-56

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water


February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 12M Fountain by Nurses Rm Bubbler

York Sample ID: 25B0347-56

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:36	02/13/2025 13:33	cw

Sample Information

Client Sample ID: 13M Nurses Office Sink #1

York Sample ID: 25B0347-57

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:36	02/13/2025 13:34	cw

Sample Information

Client Sample ID: 14M Nurses Office Sink #2

York Sample ID: 25B0347-58

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.32		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:36	02/13/2025 13:35	cw

Sample Information

Client Sample ID: 15M (A) Nurses Ice Machine

York Sample ID: 25B0347-59

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
120 RESEARCH DRIVE	STRATFORD, CT 06615						132-02 89th AVENUE	RICHMOND HILL, NY 11418		
www.YORKLAB.com	(203) 325-1371						FAX (203) 357-0166	ClientServices@		



Sample Information

Client Sample ID: 15M (A) Nurses Ice Machine

York Sample ID: 25B0347-59

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:36	02/13/2025 13:37	cw

Sample Information

Client Sample ID: 15M (B) Nurses Ice Machine

York Sample ID: 25B0347-60

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:36	02/13/2025 13:41	cw

Sample Information

Client Sample ID: 16M Gym Boys Side Fountain Bottle

York Sample ID: 25B0347-61

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:36	02/13/2025 13:42	cw

Sample Information

Client Sample ID: 17M Gym Boys Side Fountain Bubbler

York Sample ID: 25B0347-62

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water


February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 17M Gym Boys Side Fountain Bubbler			York Sample ID: 25B0347-62		
<u>York Project (SDG) No.</u>	<u>Client Project ID</u>		<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water		Drinking Water	February 1, 2025 9:40 am	02/07/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:36	02/13/2025 13:43	cw

Sample Information

Client Sample ID: 18M Gym Girls Side Fountain Bottle			York Sample ID: 25B0347-63		
<u>York Project (SDG) No.</u>	<u>Client Project ID</u>		<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water		Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:38	02/13/2025 13:50	cw

Sample Information

Client Sample ID: 19M Gym Girls Side Fountain Bubbler			York Sample ID: 25B0347-64		
<u>York Project (SDG) No.</u>	<u>Client Project ID</u>		<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water		Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:38	02/13/2025 13:53	cw

Sample Information

Client Sample ID: 20M Hallway in Pool Area by Boys Bottle			York Sample ID: 25B0347-65		
<u>York Project (SDG) No.</u>	<u>Client Project ID</u>		<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water		Drinking Water	February 1, 2025 9:40 am	02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
120 RESEARCH DRIVE		STRATFORD, CT 06615				132-02 89th AVENUE		RICHMOND HILL, NY 11418		
www.YORKLAB.com		(203) 325-1371				FAX (203) 357-0166		ClientServices@		



Sample Information

Client Sample ID: 20M Hallway in Pool Area by Boys Bottle

York Sample ID: 25B0347-65

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

7439-92-1	Lead	ND	ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 13:57	cw	
						Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044			

Sample Information

Client Sample ID: 21M Hallway in Pool Area by Boys Bubbler

York Sample ID: 25B0347-66

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 13:58	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 22M Pool Area Fountain #1 Bottle

York Sample ID: 25B0347-67

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 14:00	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 23M Pool Area Fountain #1 Bubbler

York Sample ID: 25B0347-68

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 14:01	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		



Sample Information

Client Sample ID: 23M Pool Area Fountain #1 Bubbler

York Sample ID: 25B0347-68

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Sample Information

Client Sample ID: 24M Pool Area Fountain #2 Bottle

York Sample ID: 25B0347-69

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:38	02/13/2025 14:02	cw

Sample Information

Client Sample ID: 25M Pool Area Fountain #2 Bubbler

York Sample ID: 25B0347-70

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:38	02/13/2025 14:04	cw

Sample Information

Client Sample ID: 26M Fountain by Auditorium & LGI Bottle

York Sample ID: 25B0347-71

<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.23		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04	02/13/2025 09:38	02/13/2025 14:05	cw



Sample Information

Client Sample ID: 27M Fountain by Auditorium & LGI Bubbler

York Sample ID: 25B0347-72

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.68		ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 14:06	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 28M Fountain by Music Suite Bubbler

York Sample ID: 25B0347-73

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	2.32		ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 14:08	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 29M Fountain by Rm 306 Bubbler

York Sample ID: 25B0347-74

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 14:09	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044		

Sample Information

Client Sample ID: 30M Fountain by Rm 405 Bubbler

York Sample ID: 25B0347-75

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water


February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 30M Fountain by Rm 405 Bubbler

York Sample ID: 25B0347-75

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	4.70		ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 14:13	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 31M Rm 400 Sink #1

York Sample ID: 25B0347-76

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	1.16		ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 14:14	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 32M Rm 400 Sink #2

York Sample ID: 25B0347-77

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	7.50	M-PbE X	ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 14:16	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 33M Rm 400 Sink #3

York Sample ID: 25B0347-78

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
---------	-----------	--------	------	-------	--------------------	----------	------------------	-----------------------	-----------------------	---------



Sample Information

Client Sample ID: 33M Rm 400 Sink #3

York Sample ID: 25B0347-78

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	3.06		ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 14:17	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 34M Rm 400 Sink #4

York Sample ID: 25B0347-79

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	3.87		ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 14:18	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 35M Rm 400 Sink #5

York Sample ID: 25B0347-80

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	3.72		ug/L	1.00	1	EPA 200.8	02/13/2025 09:38	02/13/2025 14:20	cw
							Certifications:	CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04		

Sample Information

Client Sample ID: 36M (A) Rm 404B Ice Machine

York Sample ID: 25B0347-81

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water


February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:



Sample Information

Client Sample ID: 36M (A) Rm 404B Ice Machine

York Sample ID: 25B0347-81

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:38	02/13/2025 14:21	cw

Sample Information

Client Sample ID: 36M (B) Rm 404B Ice Machine

York Sample ID: 25B0347-82

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:38	02/13/2025 14:22	cw

Sample Information

Client Sample ID: 37M Kitchen Sink #1

York Sample ID: 25B0347-83

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044	02/13/2025 09:39	02/13/2025 14:32	cw

Sample Information

Client Sample ID: 38M Kitchen Sink #2

York Sample ID: 25B0347-84

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025


Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
120 RESEARCH DRIVE		STRATFORD, CT 06615					132-02 89th AVENUE		RICHMOND HILL, NY 11418	
www.YORKLAB.com		(203) 325-1371					FAX (203) 357-0166		ClientServices@	



Sample Information

Client Sample ID: 38M Kitchen Sink #2

York Sample ID: 25B0347-84

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

7439-92-1	Lead	1.31	ug/L	1.00	1	EPA 200.8	02/13/2025 09:39	02/13/2025 14:35	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04									

Sample Information

Client Sample ID: 39M Kitchen Sink #3

York Sample ID: 25B0347-85

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	3.25		ug/L	1.00	1	EPA 200.8	02/13/2025 09:39	02/13/2025 14:36	cw
Certifications:							CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04			

Sample Information

Client Sample ID: 40M Kitchen Jug Filler

York Sample ID: 25B0347-86

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	2.46		ug/L	1.00	1	EPA 200.8	02/13/2025 09:39	02/13/2025 14:37	cw
Certifications:							CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04			

Sample Information

Client Sample ID: 41M (A) Kitchen Ice Machine

York Sample ID: 25B0347-87

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25B0347	Ardsley Middle/Highschool Water	Drinking Water	February 1, 2025 9:40 am	02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.		Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead		ND		ug/L	1.00	1	EPA 200.8	02/13/2025 09:39	02/13/2025 14:39	cw
Certifications: CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-04											



Sample Information

Client Sample ID: 41M (B) Kitchen Ice Machine

York Sample ID: 25B0347-88

York Project (SDG) No.

Client Project ID

Matrix

Collection Date/Time

Date Received

25B0347

Ardsley Middle/Highschool Water

Drinking Water

February 1, 2025 9:40 am

02/07/2025

Lead by EPA 200.8

Log-in Notes:

Sample Notes:

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8 Certifications:	02/13/2025 09:39	02/13/2025 14:40	cw
CTDOH-PH-0723,NELAC-NY10854,NJDEP-CT005,PADEP-68-044										



Sample and Data Qualifiers Relating to This Work Order

M-PbEX Lead result exceeds regulatory limit

Definitions and Other Explanations

*	Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
ND	NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
RL	REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
LOQ	LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon current NELAC/TNI Standards and applies to all analyses.
LOD	LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW-846.
MDL	METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
Reported to	This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
NR	Not reported
RPD	Relative Percent Difference
Wet	The data has been reported on an as-received (wet weight) basis
Low Bias	Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
High Bias	High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
Non-Dir.	Non-dir. flag (Non-Directional Bias) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.


If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.

For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.



Field Chain-of-Custody Record

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

YORK Project Number

2530347

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

Page _____ of _____

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time			
Company: Reg Com	Company: Reg Com	Ardsley High School water		NY ☒	CT ☐	Other: (please specify)		RUSH - Next Day			
Address: 245 Albany Ave Thermonia NY 10594	Address: " "			NJ ☐	PA ☐			RUSH - Two Day			
Phone: 914-434-6513	Phone: " "	PO Number		Analyses Requested				RUSH - Three Day			
Contact: E. Caon	Contact: " "							RUSH - Four Day			
E-mail: Reg Comp 2@hotmail.com	E-mail: " "							RUSH - Five Day			
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		Matrix Codes		(please list number of containers)				Standard (6-9 Day) ☒			
		S - soil/solid/sludge GW - groundwater DW - drinking water SW - surface water WW - wastewater O - Oil Other						RUSH - Five Day			
Samples Collected by: (print AND sign your name)		Unpreserved		Grab or Comp. G/C				Report Type (circle) QA Report			
		HCl (hydrochloric acid) MeOH (methanol) HNO ₃ (nitric acid) H ₂ SO ₄ (sulfuric acid) NaOH (sodium hydroxide) Na ₂ S ₂ O ₃ (sodium thio.) Trizma Ammonium Acetate Other:						Summary (Results Only) ☒			
Sample Identification		Date	Time	Matrix					NY ASP B Package		
1 H Maint. Lunch Room Bottle		2/1	AM	DW					NJ Reduced		
2 H Maint. Lunch Bubbler									NJ Full		
3 H by Room 104E bottle									NJ DKQP		
4 H by Room 104E Bubbler									CT RCP		
5 H Fountain #1 by Room 108 Bottle									EDD Type (circle)		
6 H Fountain #1 by Room 108 Bubbler									EquiS (standard) ☒		
7 H Fountain #2 by Room 108 Bottle									NYSDEC EquiS		
8 H Fountain #2 by Room 108 Bubbler									NJDEP SRP Haz Site		
9 H Fitness Room Bottle									Standard Excel		
10 H " " Bubbler									CMDP		
11 H (A) Fitness Room Ice machine									Other:		
11 H (B) " " " "									Regulatory Comparative		
12 H Porcelain Fountain btwn 113 & 114									Compared to the following Regulation(s): (please fill in)		
13 H Fountain by RM 114 Bottle									Field Filtered		
14 H " " " Bubbler									Lab Filtered		
Comments:					Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N						
					Custody Seals: Y / ☒ Containers Intact: Y / ☒ COC/Labels Agree: Y / ☒ Preservation Confirmed: Y / ☒						
					COC Complete: Y / ☒ COC Received: Y / ☒ Appropriate Sample Volumes: Y / ☒ Appropriate Sample Containers: Y / ☒						
					Cooler Temperature Confirmed: Y / ☒ Samples Submitted within Holding Times: Y / ☒ Corrective Action Form Required: Y / ☒						
1. Samples Relinquished by / Company		Date/Time		1. Samples Received by / Company		Date/Time		2. Samples Relinquished by / Company		Date/Time	
Nicholas Caon		2/1/25 12:20pm		[Signature]		2-7-25 9:40		[Signature]		2-7-25 14:50	
2. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time		3. Samples Received by / Company		Date/Time	
4. Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company		Date/Time		Samples Received in LAB by		Date/Time Temperature	
								NICHOLAS FOR CORALES		2/7/25 20:50 20.0 Degrees C	



Field Chain-of-Custody Record

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.


YORK Project Number

25B0347

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

Page _____ of _____

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time				
Company: RegCom	Company: RegCom			NY	CT	Other: (please specify)		RUSH - Next Day				
Address:	Address:			NJ	PA			RUSH - Two Day				
Phone.:	Phone.:			Analyses Requested				RUSH - Three Day				
Contact:	Contact:							RUSH - Four Day				
E-mail:	E-mail:							RUSH - Five Day				
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		Matrix Codes		Preservative (please list number of containers)				Standard (6-9 Day)				
		S - soil/solid/sludge							PFAS Standard 7-10 Day			
		GW - groundwater										
DW - drinking water												
SW - surface water												
WW - wastewater												
O - Oil												
Other:												
Samples Collected by: (print AND sign your name)		Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO ₃ (nitric acid)	H ₂ SO ₄ (sulfuric acid)	NaOH (sodium hydroxide)	Na ₂ S ₂ O ₃ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Grab or Comp. G/C
Sample Identification	Date	Time	Matrix									Report Type (circle)
15 H - Nurses Office Fountain Bottle	2/1	AM	DW									QA Report
16 H " " " Bubbler												Summary (Results Only)
17 H Nurses Office Sink												NY ASP B Package
18 H Teachers Lounge Fountain Bottle												NJ Reduced
19 H " " " Bubbler												NJ DKQP
20 H By RM 130 Fountain Bottle												NJ Full
21 H " " " Bubbler												CT RCP
22 H Fountain by RM 142 #1 Bubbler												EDD Type (circle)
23 H " " " #2 Bubbler												EquiS (standard)
24 H Fountain by RM 200 Bottle												NYSDEC EquiS
25 H " " " Bubbler												NJDEP SRP Haz Site
26 H Fountain by RM 215 Bottle												Standard Excel
27 H " " " Bubbler												CMDP
28 H Fountain by RM 233 Bottle												Other:
29 H " " " Bubbler												Regulatory Comparative
Comments:												Compared to the following Regulation(s): (please fill in)
Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N												
Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N												
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N												
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N												
Samples iced/chilled at time of lab pickup? circle YES or NO												
1. Samples Relinquished by / Company		Date/Time		1. Samples Received by / Company		Date/Time		2. Samples Relinquished by / Company		Date/Time		
						2-7-25 9:40				2-7-25 14:50		
2. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time		3. Samples Received by / Company		Date/Time		
4. Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company		Date/Time		Samples Received in LAB by DANIEL FOR CORALES		Date/Time		Temperature
								2/4/25 20:50				20.0 Degrees C



Field Chain-of-Custody Record

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.


YORK Project Number

25B0347

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

Page _____ of _____

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time			
Company: Reg Com	Company: Reg Com	Ardsley Middle School		water		NY	CT	Other: (please specify)			
Address: 245 Albany Ave Tarrytown NY 10594	Address: "					NJ	PA				
Phone: 914-434-6513	Phone: "					Analyses Requested					
Contact: E. Com	Contact: "										
E-mail: Regcomp2@hotmail.com	E-mail: "										
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		Matrix Codes		Preservative (please list number of containers)							
		S - soil/solid/sludge GW - groundwater DW - drinking water SW - surface water WW - wastewater O - Oil Other		Unpreserved HCl (hydrochloric acid) MeOH (methanol) HNO ₃ (nitric acid) H ₂ SO ₄ (sulfuric acid) NaOH (sodium hydroxide) Na ₂ S ₂ O ₃ (sodium thio.) Trizma Ammonium Acetate Other:							
Samples Collected by: (print AND sign your name)											
Sample Identification		Date	Time	Matrix					Grab or Comp. G/C		
1M Commons Area Fountain Bottle		2/1	AM	DW					EDD Type (circle) EQUIS (standard)		
2M " " " Bubbler									NYSDEC EQuIS		
3M " " Office Sink									NJDEP SRP Haz Site		
4M Fountain by RM 206 Bubbler									Standard Excel		
5M " " " Bottle									CMDP		
6M Fountain by RM 217 Bottle									Other:		
7M " " " " Bubbler									Regulatory Comparative		
8M Faculty RM 217 Bottle Filler									Compared to the following Regulation(s): (please fill in)		
9M " " " " Bubbler											
10M " " " " Sink											
11M Fountain by Nurses RM Bottle											
12M " " " " Bubbler											
13M Nurses Office sink #1											
14M " " " " Sink #2											
15M CA Nurses Ice machine											
Comments:					Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N						
					Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N						
					COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N						
					Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N						
Samples iced/chilled at time of lab pickup? circle Yes or No											
1. Samples Relinquished by / Company		Date/Time		1. Samples Received by / Company		Date/Time		2. Samples Relinquished by / Company		Date/Time	
M. M. M.		2/1 12:00pm		J. S.		2-7-25 9:30		J. S.		2-7-25 14:50	
2. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time		3. Samples Received by / Company		Date/Time	
4. Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company		Date/Time		Samples Received in LAB by		Date/Time Temperature	
								NCC FOR DANIEL CORALES		2/7/25 20:50 20.0 Degrees C	



Field Chain-of-Custody Record

YORK Project Number


25B0347

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

Page ____ of ____

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time							
Company: <u>Reg Com</u>	Company: <u>Reg Com</u>	Address:		<u>Ardley Middle School</u> <u>Water</u>		NY ☒	CT ☒	Other: (please specify)							
						NJ ☐	PA ☐								
Phone.:		Phone.:		PO Number		Analyses Requested									
Contact:		Contact:		Preservative (please list number of containers)											
E-mail:		E-mail:													
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		Matrix Codes		Unpreserved											
		S - soil/solid/sludge GW - groundwater DW - drinking water SW - surface water WW - wastewater O - Oil Other													
Samples Collected by: (print AND sign your name)															
Sample Identification	Date	Time	Matrix	HCl (hydrochloric acid)	MeOH (methanol)	HNO ₃ (nitric acid)	H ₂ SO ₄ (sulfuric acid)	NaOH (sodium hydroxide)	Na ₂ S ₂ O ₃ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Grab or Comp. G/C	Report Type (circle) QA Report Summary (Results Only) NY ASP B Package NJ Reduced NJ DKQP NJ Full CT RCP	
15 M (B) Nurse Ice machine	2/1	AM	DW											EDD Type (circle) EQUIS (standard)	
16 M 6ym Boys Side Fountain Bottle														NYSDEC EQUIS	
17 M " " " " Bubblers														NJDEP SRP Haz Site	
18 M 6ym 6yrs Side Fountain Bottle														Standard Excel	
19 M " " " " Bubblers														CMDP	
20 M Hallway in Pool Area by Boys Bottle														Other:	
21 M " " " " Bubblers														Regulatory Comparative	
22 M Pool Area Fountain #1 Bottle														Compared to the following Regulation(s): (please fill in)	
23 M " " " " #1 Bubblers															
24 M " " " " #2 Bottle															
25 M " " " " #2 Bubblers															
26 M Fountain by Andrianna PLEI Bottle															
27 M " " " " Bubblers															
28 M Fountain by Music Suite Bubblers														Field Filtered	
29 M Fountain by RM 306 Bubblers														Lab Filtered	
Comments:				Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N Custody Seals: Y / ☒ Containers Intact: Y / ☒ COC/Labels Agree: Y / ☒ Preservation Confirmed: Y / ☒ COC Complete: Y / ☒ COC Received: Y / ☒ Appropriate Sample Volumes: Y / ☒ Appropriate Sample Containers: Y / ☒ Cooler Temperature Confirmed: Y / ☒ Samples Submitted within Holding Times: Y / ☒ Corrective Action Form Required: Y / ☒											
Samples iced/chilled at time of lab pickup? circle Yes or No															
1. Samples Relinquished by / Company		Date/Time		1. Samples Received by / Company		Date/Time		2. Samples Relinquished by / Company		Date/Time		3. Samples Received by / Company		Date/Time	
<u>M/K</u>		2/1 12:00pm		<u>[Signature]</u>		2-7-25 9:40		<u>[Signature]</u>		2-7-25 14:50					
2. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time		3. Samples Received by / Company		Date/Time		4. Samples Relinquished by / Company		Date/Time	
4. Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company		Date/Time		5. Samples Received in LAB by		Date/Time		Temperature		Degrees C	
								<u>[Signature]</u>		2/7/25 20:50		20.0			



Field Chain-of-Custody Record

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number

25B0347

Page _____ of _____

Report To:		Invoice To:		YOUR Project Name / Number		Samples Collected From		Turn-Around Time				
Company: Reg Corn	Company: Reg Corn	Ardsley Middle School water		NY	CT	Other: (please specify)		RUSH - Next Day				
Address:	Address:			NJ	PA			RUSH - Two Day				
Phone.:	Phone.:	PO Number		Analyses Requested				RUSH - Three Day				
Contact:	Contact:							RUSH - Four Day				
E-mail:	E-mail:							RUSH - Five Day				
Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.		Matrix Codes		Preservative (please list number of containers)				Standard (6-9 Day)				
		S - soil/solid/sludge GW - groundwater DW - drinking water SW - surface water WW - wastewater O - Oil Other	Unpreserved HCl (hydrochloric acid) MeOH (methanol) HNO ₃ (nitric acid) H ₂ SO ₄ (sulfuric acid) NaOH (sodium hydroxide) Na ₂ S ₂ O ₃ (sodium thio.) Trizma Ammonium Acetate Other:					PFAS Standard 7-10 Day				
Samples Collected by: (print AND sign your name)								Report Type (circle) QA Report Summary (Results Only)				
Sample Identification	Date	Time	Matrix					NY ASP B Package				
30M Fountain by RM 405 Bubble	2/1	AM	DW					NJ Reduced				
31M RM 400 Sink #1								NJ DKQP				
32M " " " #2								NJ Full				
33M " " " #3								CT RCP				
34M " " " #4								EDD Type (circle) EQUIS (standard)				
35M " " " #5								NYSDEC EQUIS				
(A) 36M RM 404B Ice machine								NJDEP SRP Haz Site				
(B) 36M " " " " "								Standard Excel				
37M Kitchen Sink #1								CMDP				
38M " " " #2								Other:				
39M " " " #3								Regulatory Comparative				
40M " " Jug Filler								Compared to the following Regulation(s): (please fill in)				
41M (A) Kitchen Ice machine								Field Filtered				
41M (B) " " " "								Lab Filtered				
Comments:				Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N								
				Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N								
				COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N								
				Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N								
Samples iced/chilled at time of lab pickup? circle Yes or No												
1. Samples Relinquished by / Company		Date/Time		1. Samples Received by / Company		Date/Time		2. Samples Relinquished by / Company		Date/Time		
[Signature]		2/1 12:00 PM		[Signature]		2-7-25 9:40		[Signature]		2-7-25 14:50		
2. Samples Received by / Company		Date/Time		3. Samples Relinquished by / Company		Date/Time		3. Samples Received by / Company		Date/Time		
4. Samples Relinquished by / Company		Date/Time		4. Samples Received by / Company		Date/Time		Sample Received in LAB by [Signature] FOR DANIEL CORAUS 2/7/25 20:50				Temperature 20.0 Degrees C