



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Wyoming County Health Department

Project Name: Letchworth Central School

Andy Meyer  
5362 Mungers Mill RD  
Silver Springs, NY 14550

Project / PO Number: N/A  
Received: 04/11/2025  
Reported: 04/28/2025

Analytical Testing Parameters

Client Sample ID:	EGLGLSR	Collected By:	Todd Brant
Sample Matrix:	Drinking Water	Collection Date:	04/08/2025 4:43
Lab Sample ID:	S5D0417-01		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0079	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2051	DLO

Client Sample ID:	EGLGLSRC	Collected By:	Todd Brant
Sample Matrix:	Drinking Water	Collection Date:	04/08/2025 4:43
Lab Sample ID:	S5D0417-02		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0523	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2056	DLO

Client Sample ID:	EGLGLSRL	Collected By:	Todd Brant
Sample Matrix:	Drinking Water	Collection Date:	04/08/2025 4:44
Lab Sample ID:	S5D0417-03		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.692	0.005 AL	0.0010	mg/L	M6	04/18/25 1613	04/21/25 1242	DLO

Client Sample ID:	EGLBLSFR	Collected By:	Todd Brant
Sample Matrix:	Drinking Water	Collection Date:	04/08/2025 4:45
Lab Sample ID:	S5D0417-04		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0151	0.005 AL	0.0010	mg/L		04/18/25 1613	04/21/25 1248	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: [EGLBLRS](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-05](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 4:46](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0120	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2058	DLO

Client Sample ID: [EGLBLSC](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-06](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 4:46](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0082	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2059	DLO

Client Sample ID: [EGLBLSL](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-07](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 4:47](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0133	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2101	DLO

Client Sample ID: [EGLDF1](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-08](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 4:48](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2102	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: EGLDF2  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-09

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2107	DLO

Client Sample ID: EGLBF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-10

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2109	DLO

Client Sample ID: ER1F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-11

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2110	DLO

Client Sample ID: ER2F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-12

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2112	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: ER3F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-13

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2113	DLO

Client Sample ID: ER4F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-14

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2116	DLO

Client Sample ID: ECLGR1  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-15

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2118	DLO

Client Sample ID: ECLGR2  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-16

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2119	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: ECLB1  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-17

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2121	DLO

Client Sample ID: ECLB2  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-18

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2126	DLO

Client Sample ID: ECDF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-19

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:57

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2127	DLO

Client Sample ID: ER5F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-20

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0061	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2129	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: EOSL  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-21

Collected By: Todd Brant  
Collection Date: 04/08/2025 4:59

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2130	DLO

Client Sample ID: ER10F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-22

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1602	04/17/25 2132	DLO

Client Sample ID: ER15F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-23

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2140	DLO

Client Sample ID: EROF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-24

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:04

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2144	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: ER16F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-25

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2146	DLO

Client Sample ID: ERSLF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-26

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2147	DLO

Client Sample ID: ER17F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-27

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0099	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2149	DLO

Client Sample ID: ER17LS  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-28

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0043	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2150	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: ER18F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-29

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:09

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2155	DLO

Client Sample ID: ER19F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-30

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:10

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2157	DLO

Client Sample ID: ER20F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-31

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:11

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2158	DLO

Client Sample ID: ER21F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-32

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2200	DLO





Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: ER23FR  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-33

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2201	DLO

Client Sample ID: ER23FC  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-34

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2204	DLO

Client Sample ID: ER23FL  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-35

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2206	DLO

Client Sample ID: ER23F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-36

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2207	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: [EHBL](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-37](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 5:16](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2209	DLO

Client Sample ID: [EHBLM](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-38](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 5:16](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2213	DLO

Client Sample ID: [EHBLR](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-39](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 5:17](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2215	DLO

Client Sample ID: [EHGRL](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-40](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 5:18](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2217	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: EHGLM  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-41

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0086	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2218	DLO

Client Sample ID: EHGLR  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-42

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0072	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2220	DLO

Client Sample ID: EHDF1  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-43

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2227	DLO

Client Sample ID: EHDFR  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-44

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2232	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: [ESLR](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-45](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 5:21](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0842	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2234	DLO

Client Sample ID: [ESLL](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-46](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 5:21](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0094	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2235	DLO

Client Sample ID: [ER36F](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-47](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 5:23](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2237	DLO

Client Sample ID: [ER36DF](#)  
Sample Matrix: [Drinking Water](#)  
Lab Sample ID: [S5D0417-48](#)

Collected By: [Todd Brant](#)  
Collection Date: [04/08/2025 5:23](#)

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2238	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: ER36L  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-49

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:24

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2243	DLO

Client Sample ID: ER37F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-50

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:24

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0017	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2245	DLO

Client Sample ID: ER37DF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-51

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2246	DLO

Client Sample ID: ER37L  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-52

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2248	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: ER39F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-53

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:26

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2249	DLO

Client Sample ID: ER39DF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-54

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:26

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2252	DLO

Client Sample ID: ER39L  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-55

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:27

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2254	DLO

Client Sample ID: ER41F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-56

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2255	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: ER41DF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-57

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2257	DLO

Client Sample ID: ER41FL  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-58

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:29

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2301	DLO

Client Sample ID: ER43F  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-59

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2303	DLO

Client Sample ID: ER43DF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-60

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2305	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: ER43FL  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-61

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:30

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2306	DLO

Client Sample ID: EOBF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-62

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1603	04/17/25 2308	DLO

Client Sample ID: EODF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-63

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1604	04/17/25 2315	DLO

Client Sample ID: EO  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-64

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.005 AL	0.0010	mg/L		04/17/25 1604	04/17/25 2334	DLO





Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: EOLGL  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-65

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.005 AL	0.0010	mg/L		04/17/25 1604	04/17/25 2336	DLO

Client Sample ID: EOLGM  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-66

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0052	0.005 AL	0.0010	mg/L		04/17/25 1604	04/17/25 2340	DLO

Client Sample ID: EOLGR  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-67

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.005 AL	0.0010	mg/L		04/17/25 1604	04/17/25 2342	DLO

Client Sample ID: EOLBL  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-68

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.005 AL	0.0010	mg/L		04/17/25 1604	04/17/25 2343	DLO



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

Client Sample ID: EOLBR  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-69

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.005 AL	0.0010	mg/L		04/17/25 1604	04/17/25 2345	DLO

Client Sample ID: MBRF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-70

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:27

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1604	04/17/25 2350	DLO

Client Sample ID: MLF  
Sample Matrix: Drinking Water  
Lab Sample ID: S5D0417-71

Collected By: Todd Brant  
Collection Date: 04/08/2025 5:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/17/25 1604	04/17/25 2337	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

AL:	US EPA Action Level
M6:	Matrix spike recovery is outside of acceptance limits. The analyte concentration is greater than 4X the spiking level.
MDL:	Minimum Detection Limit
mg/L:	Milligrams per Liter
RL:	Reporting Limit
RPD:	Relative Percent Difference

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville  
11549

New York State Department of Health



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S5D0417

**Report Comments**

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

**Reviewed and Approved By:**

A handwritten signature in black ink that reads "Renee Lantz". The signature is fluid and cursive, with the first name "Renee" being more prominent than the last name "Lantz".

Renee Lantz

Customer Relationship Specialist

Reported: 04/28/2025 10:29



250 West 84th Dr., Merrillville, IN 46410 | 219.769.8378 p | 219.769.1664 f

# CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 4.6

Therm ID 10

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

## Lab Report Address

Client Name: Wyoming CounHealth Department

Address: 5362A Mungers Mill Road

City, State, Zip: Silver Springs, NY 14550

Contact: Andy Meyer

Telephone No.: (585) 786-8894

## Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

## Turnaround Time

☐ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Send Invoice via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Letchworth Central School

Location: 5550 School Road, Gainesville, PO No.:

Compliance Monitoring? ☒ Yes ☐ No

☐ Agency/Program

Sampled by (PRINT): Todd Brant

Sampler Signature: Todd Brant

Sampler Phone No.: 585-493-3550

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **	Additional Note
	EGLGLSR	04/08/25	4:43 AM	1	DW	U	
	EGLGLSRC	04/08/25	4:43 AM	1	G	U	
	EGLGLSRL	04/08/25	4:44 AM	1		U	
	EGLBLSFR	04/08/25	4:45 AM	1		U	
	EGLBLSR	04/08/25	4:46 AM	1		U	
	EGLBLSC	04/08/25	4:46 AM	1		U	
	EGLBLSL	04/08/25	4:47 AM	1		U	
	EGLDF1	04/08/25	4:48 AM	1		U	
	EGLDF2	04/08/25	4:48 AM	1		U	
	EGLBF	04/08/25	4:49 AM	1		U	

Possible Hazard Identification  
Comments

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

C. J. [Signature]

Relinquished By (signature)

R. [Signature]

Relinquished By (signature)

Date/Time

4/10/25 10:30 AM

Date/Time

4-10-25 330p

Date/Time

Received By (signature)

R. [Signature]

Received By (signature)

Received By (signature)

Date/Time

4-10-25

Date/Time

Date/Time

4/11/25

Page 1

of 8



Wyoming County Health Department  
PM: Joseph Palanza



250 West 84th Dr., Merrillville, IN 46410 | 219.769.8378 p | 219.769.1664 f

## CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 4.6°

Therm ID 10

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Turnaround Time

☐ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Lab Report Address

Client Name: Wyoming CounHealth Department

Address: 5362A Mungers Mill Road

City, State, Zip: Silver Springs, NY 14550

Contact: Andy Meyer

Telephone No.: (585) 786-8894

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Invoice via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Letchworth Central School

Location: 5550 School Road, Gainesville, PO No.:

Compliance Monitoring? ☒ Yes ☐ No

☐ Agency/Program

Sampled by (PRINT): TODD Brant

Sampler Signature: Todd Brant

Sampler Phone No.: 585-493-3550

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

### REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **	Additional N
	ER1F	04/08/25	4:50 AM	1	DW	U	
	ER2F	04/08/25	4:52 AM	1		U	
	ER3F	04/08/25	4:52 AM	1		U	
	ER4F	04/08/25	4:52 AM	1		U	
	ECLGR1	04/08/25	4:54 AM	1		U	
	ECLGR2	04/08/25	4:54 AM	1		U	
	ECLB1	04/08/25	4:56 AM	1		U	
	ECLB2	04/08/25	4:56 AM	1		U	
	ECDF	04/08/25	4:57 AM	1		U	
	ER5F	04/08/25	4:58 AM	1		U	

Possible Hazard Identification  
Comments

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

*C. Van G...*

Relinquished By (signature)

*Rimm*

Relinquished By (signature)

Date/Time

4/10/25 10:30 AM

Date/Time

4-10-25 330p

Date/Time

Received By (signature)

*Rimm*

Received By (signature)

*M. C...*

Received By (signature)

Date/Time

4-10-25

Date/Time

4/11/25 6:35

Date/Time

Wyoming County Health Department  
P.M.: Joseph Palanza





250 West 84th Dr., Merrillville, IN 46410 | 219.769.8378 p | 219.769.1664 f

## CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 4.6

Therm ID 10

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Turnaround Time

☐ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Lab Report Address

Client Name: Wyoming CounHealth Department

Address: 5362A Mungers Mill Road

City, State, Zip: Silver Springs, NY 14550

Contact: Andy Meyer

Telephone No.: (585) 786-8894

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Invoice via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Letchworth Central School

Location: 5550 School Road, Gainesville, PO No.:

Compliance Monitoring? ☒ Yes ☐ No

☐ Agency/Program

Sampled by (PRINT): TODD Brant

Sampler Signature: Todd Brant

Sampler Phone No.: 585-493-3550

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO<sub>3</sub>, (2) H<sub>2</sub>SO<sub>4</sub>, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

### REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **	Additional Notes
	EOSL	04/08/25	4:59 AM	1	DW	U	
	ER10F	04/08/25	5:00 AM	1		U	
	ER15F	04/08/25	5:03 AM	1		U	
	EROF	04/08/25	5:04 AM	1		U	
	ER16F	04/08/25	5:05 AM	1		U	
	ERLSF	04/08/25	5:06 AM	1		U	
	ER17F	04/08/25	5:08 PM	1		U	
	ER17LS	04/08/25	5:08 AM	1		U	
	ER18F	04/08/25	5:09 AM	1		U	
	ER19F	04/08/25	5:10 AM	1		U	

Possible Hazard Identification  
Comments

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time

4/10/25 10:30 AM

Date/Time

4-10-25

Date/Time

330p

Received By (signature)

Received By (signature)

Received By (signature)

Received By (signature)

Date/Time

4-10-25

Date/Time

Date/Time

4/11/25

Page 3

of 8

Wyoming County Health Department  
PM: Joseph Palanza





250 West 84th Dr., Merrillville, IN 46410 | 219.769.8378 p | 219.769.1664 f

# CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 4.6

Therm ID 10

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Turnaround Time

☐ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Lab Report Address

Client Name: Wyoming CounHealth Department

Address: 5362A Mungers Mill Road

City, State, Zip: Silver Springs, NY 14550

Contact: Andy Meyer

Telephone No.: (585) 786-8894

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Send Invoice via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Letchworth Central School

Location: 5550 School Road, Gainesville, PO No.:

Compliance Monitoring? ☒ Yes ☐ No

☐ Agency/Program

Sampled by (PRINT):

Sampler Signature:

Sampler Phone No.:

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **	Additional N.
	ER20F	04/08/25	5:11 AM	1	DW	U	
	ER21F	04/08/25	5:12 AM	1		U	
	ER23FR	04/08/25	5:13 AM	1		U	
	ER23FC	04/08/25	5:13 AM	1		U	
	ER23FL	04/08/25	5:14 AM	1		U	
	ER23F	04/08/25	5:14 AM	1		U	
	EHBL	04/08/25	5:16 AM	1		U	
	EHBLM	04/08/25	5:16 AM	1		U	
	EHBLR	04/08/25	5:17 AM	1		U	
	EHGRL	04/08/25	5:18 AM	1		U	

Possible Hazard Identification  
Comments

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time

4/10/25 10:30 AM

Date/Time

4-10-25 330p

Date/Time

Received By (signature)

Received By (signature)

Received By (signature)

Received By (signature)

Received By (signature)

Date/Time

4-10-25

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Date/Time

Additional N.

Wyoming County Health Department  
PM: Joseph Palanza





250 West 84th Dr., Merrillville, IN 46410 | 219.769.8378 p | 219.769.1664 f

# CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 4.6

Therm ID 10

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Turnaround Time

☐ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Lab Report Address

Client Name: Wyoming CounHealth Department

Address: 5362A Mungers Mill Road

City, State, Zip: Silver Springs, NY 14550

Contact: Andy Meyer

Telephone No.: (585) 786-8894

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Send Invoice via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Letchworth Central School

Location: 5550 School Road, Gainesville, PO No.:

Compliance Monitoring? ☒ Yes ☐ No

☐ Agency/Program

Sampled by (PRINT): Todd Brant

Sampler Signature: Todd Brant

Sampler Phone No.: 585-443-3550

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **	Additional No
	EHGLM	04/08/25	5:18 AM	1	DW	U	
	EHGLR	04/08/25	5:19 AM	1		U	
	EHDF1	04/08/25	5:19 AM	1		U	
	EHDFR	04/08/25	5:20 AM	1		U	
	ESLR	04/08/25	5:21 AM	1		U	
	ESLL	04/08/25	5:21 AM	1		U	
	ER36F	04/08/25	5:23 AM	1		U	
	ER36DF	04/08/25	5:23 AM	1		U	
	ER36L	04/08/25	5:24 AM	1		U	
	ER37F	04/08/25	5:24 AM	1		U	

Lead

Possible Hazard Identification  
Comments

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time

4/10/25 10:30 AM

Date/Time

4-10-25 330p

Date/Time

Received By (signature)

Received By (signature)

Received By (signature)

Date/Time

4-10-25

Date/Time

Date/Time

4/11/25 6:35

Page 5 of 8

Wyoming County Health Department  
PM: Joseph Palanza







250 West 84th Dr., Merrillville, IN 46410 | 219.769.8378 p | 219.769.1664 f

# CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) **4.6°**

Therm ID **10**

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Lab Report Address

Client Name: Wyoming CounHealth Department

Address: 5362A Mungers Mill Road

City, State, Zip: Silver Springs, NY 14550

Contact: Andy Meyer

Telephone No.: (585) 786-8894

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Turnaround Time

☐ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Send Invoice via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Letchworth Central School

Location: 5550 School Road, Gainesville, PO No.:

Compliance Monitoring? ☒ Yes ☐ No

☐ Agency/Program

Sampled by (PRINT): **Todd Brant**

Sampler Signature: **Todd Brant**

Sampler Phone No.: **585-493-3550**

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

## REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **	Additional Note
	ER37DF	04/08/25	5:25 AM	1	DW	U	
	ER37L	04/08/25	5:25 AM	1		U	
	ER39F	04/08/25	5:26 AM	1		U	
	ER39DF	04/08/25	5:26 AM	1		U	
	ER39L	04/08/25	5:27 AM	1		U	
	ER41F	04/08/25	5:28 AM	1		U	
	ER41DF	04/08/25	5:28 AM	1		U	
	ER41FL	04/08/25	5:29 AM	1		U	
	ER43F	04/08/25	5:30 AM	1		U	
	ER43DF	04/08/25	5:30 AM	1		U	

Lead

Possible Hazard Identification  
Comments

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

**C. G. [Signature]**

Relinquished By (signature)

**R. Timm**

Relinquished By (signature)

Date/Time

**4/10/25 10:30 AM**

Date/Time

**4-10-25 330p**

Date/Time

Received By (signature)

**R. Timm**

Received By (signature)

**R. Timm**

Received By (signature)

Date/Time

**4-10-25**

Date/Time

**4-10-25**

Date/Time

**4/11/25 6:35**

Page 6 of 8





250 West 84th Dr., Merrillville, IN 46410 | 219.769.8378 p | 219.769.1664 f

## CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 4.6°

Therm ID 10

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Turnaround Time

☐ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☐ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Lab Report Address

Client Name: Wyoming CounHealth Department

Address: 5362A Mungers Mill Road

City, State, Zip: Silver Springs, NY 14550

Contact: Andy Meyer

Telephone No.: (585) 786-8894

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Invoice via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Letchworth Central School

Location: 5550 School Road, Gainesville, FL PO No.:

Compliance Monitoring? ☒ Yes ☐ No

☐ Agency/Program

Sampled by (PRINT): Todd Brant

Sampler Signature: Todd Brant

Sampler Phone No.: 585-493-3550

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

### REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **
	ER43FL	04/08/25	5:30 AM	1	DW	U
	EOBF	04/08/25	5:32 AM	1		U
	EODF	04/08/25	5:33 AM	1		U
	EO	04/08/25	5:33 AM	1		U
	EOLGL	04/08/25	5:34 AM	1		U
	EOLGM	04/08/25	5:34 AM	1		U
	EOLGR	04/08/25	5:35 AM	1		U
	EOLBL	04/08/25	5:36 AM	1		U
	EOLBR	04/08/25	5:36 AM	1		U
	MBRF	04/08/25	5:37 AM	1		U

Possible Hazard Identification  
Comments

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition

☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time

Date/Time

Date/Time

Received By (signature)

Received By (signature)

Received By (signature)

Date/Time

Date/Time

Date/Time

Received By (signature)

Received By (signature)

Received By (signature)

Date/Time

Date/Time

Date/Time

Yamington County Health Department  
P.M. Joseph Palanza





250 West 84th Dr., Merrillville, IN 46410 | 219.769.8378 p | 219.769.1664 f

## CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 46°

Therm ID 10

Holding Time

Samples Received on Ice? ☐ Yes ☐ No ☐ N/A

Custody Seals Intact? ☐ Yes ☐ No ☐ N/A

Turnaround Time

☐ Routine (5 to 7 business days)

☐ RUSH\* (notify lab)

(needed by)

Report Type

☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Lab Report Address

Client Name: Wyoming CounHealth Department

Address: 5362A Mungers Mill Road

City, State, Zip: Silver Springs, NY 14550

Contact: Andy Meyer

Telephone No.: (585) 786-8894

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Report via: ☐ Mail ☐ Fax ☒ e-mail (address)

Send Invoice via: ☐ Mail ☐ Fax ☒ e-mail (address)

Project: Letchworth Central School

Location: 5550 School Road, Gainesville, PO No.:

Compliance Monitoring? ☒ Yes ☐ No

☐ Agency/Program

Sampled by (PRINT): TODD BRANT

Sampler Signature: Todd Brant

Sampler Phone No.: 585-493-3550

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO<sub>3</sub>, (2) H<sub>2</sub>SO<sub>4</sub>, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

### REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **	Additional Notes
	MLF	04/08/25	5:35 AM	1	Soil	U	

Possible Hazard Identification  
Comments

☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition ☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

C. J. [Signature]

Relinquished By (signature)

R. Timm

Relinquished By (signature)

Date/Time

4/10/25 10:30 AM

Date/Time

4-10-25 330P

Date/Time

Received By (signature)

R. Timm

Received By (signature)

[Signature]

Received By (signature)

Date/Time

4-10-25

Date/Time

4/11/25 6:35

Date/Time

