Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

May 07, 2025

Maureen Doherty
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

RE: Project: Greenwood Lake MS
Pace Project No.: 70350886

Dear Maureen Doherty:

Enclosed are the analytical results for sample(s) received by the laboratory on April 25, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Newburgh

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Felicia Morgan-Nichols
felicia.morgan-nichols@pacelabs.com
(845)562-0890
Project Manager

Enclosures

cc: Mikayla Higgins, Orange-Ulster BOCES
Ashley Kimiecik, Orange-Ulster BOCES
Juliana Lennon, Orange-Ulster BOCES
Halina Redner, Orange-Ulster BOCES

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

CERTIFICATIONS

Project: Greenwood Lake MS
Pace Project No.: 70350886

Pace Analytical Services, LLC- Newburgh, NY
315 Fullerton Avenue, Newburgh, NY 12550
New York Certification #: 10142 Primary Accrediting Body
New Jersey Certification #: NY015
Connecticut Certification #: PH-0823

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

PROJECT NARRATIVE

Project: Greenwood Lake MS
Pace Project No.: 70350886

Method: **EPA 200.8, Rev. 5.4**
Description: NB 200.8 ICPMS DW No Prep
Client: Orange-Ulster BOCES
Date: May 07, 2025

General Information:
28 samples were analyzed for EPA 200.8, Rev. 5.4 by Pace Analytical Services Newburgh. All samples were received in acceptable condition with any exceptions noted below or on the chain-of custody and/or the sample condition upon receipt form (SCUR) attached at the end of this report.

Hold Time:
The samples were analyzed within the method required hold times with any exceptions noted below.

Initial Calibrations (including MS Tune as applicable):
All criteria were within method requirements with any exceptions noted below.

Continuing Calibration:
All criteria were within method requirements with any exceptions noted below.

Internal Standards:
All internal standards were within QC limits with any exceptions noted below.

Surrogates:
All surrogates were within QC limits with any exceptions noted below.

Method Blank:
All analytes were below the report limit in the method blank, where applicable, with any exceptions noted below.

Laboratory Control Spike:
All laboratory control spike compounds were within QC limits with any exceptions noted below.

Matrix Spikes:
All percent recoveries and relative percent differences (RPDs) were within acceptance criteria with any exceptions noted below.

Duplicate Sample:
All duplicate sample results were within method acceptance criteria with any exceptions noted below.

Additional Comments:

This data package has been reviewed for quality and completeness and is approved for release.

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

ANALYTICAL RESULTS

Project: Greenwood Lake MS
Pace Project No.: 70350886

Sample: O/S Guidance CU/BF **Lab ID: 70350886001** Collected: 04/25/25 04:14 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 12:57	7439-92-1	

Sample: O/S Guidance CU/DF **Lab ID: 70350886002** Collected: 04/25/25 04:14 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 12:59	7439-92-1	

Sample: O/S Cafe CU/BF **Lab ID: 70350886003** Collected: 04/25/25 04:02 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:02	7439-92-1	

Sample: O/S Cafe CU/DF **Lab ID: 70350886004** Collected: 04/25/25 04:03 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:04	7439-92-1	

Sample: Second Floor South Wing by Ele **Lab ID: 70350886005** Collected: 04/25/25 04:44 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

ANALYTICAL RESULTS

Project: Greenwood Lake MS
Pace Project No.: 70350886

Sample: Second Floor South Wing by Ele **Lab ID: 70350886006** Collected: 04/25/25 04:44 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:13	7439-92-1	

Sample: Business Office KS **Lab ID: 70350886007** Collected: 04/25/25 04:22 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:27	7439-92-1	

Sample: Main Office KS **Lab ID: 70350886008** Collected: 04/25/25 04:08 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:29	7439-92-1	

Sample: Nurse NS **Lab ID: 70350886009** Collected: 04/25/25 04:10 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:32	7439-92-1	

Sample: Nurse Well Room NS **Lab ID: 70350886010** Collected: 04/25/25 04:12 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

ANALYTICAL RESULTS

Project: Greenwood Lake MS
Pace Project No.: 70350886

Sample: O/S 109 CU/BF **Lab ID: 70350886011** Collected: 04/25/25 04:20 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:36	7439-92-1	

Sample: O/S 109 CU/DF **Lab ID: 70350886012** Collected: 04/25/25 04:21 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:39	7439-92-1	

Sample: O/S 202 CU/BF **Lab ID: 70350886013** Collected: 04/25/25 04:33 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:41	7439-92-1	

Sample: O/S 202 CU/DF **Lab ID: 70350886014** Collected: 04/25/25 04:33 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:48	7439-92-1	

Sample: O/S 209 CU/BF **Lab ID: 70350886015** Collected: 04/25/25 04:30 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

ANALYTICAL RESULTS

Project: Greenwood Lake MS
Pace Project No.: 70350886

Sample: O/S 209 CU/DF **Lab ID: 70350886016** Collected: 04/25/25 04:30 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:52	7439-92-1	

Sample: Boys Locker Room CU/BF **Lab ID: 70350886017** Collected: 04/25/25 04:04 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:57	7439-92-1	

Sample: Boys Locker Room CU/DF **Lab ID: 70350886018** Collected: 04/25/25 04:05 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 13:59	7439-92-1	

Sample: First Floor South Wing by Elev **Lab ID: 70350886019** Collected: 04/25/25 04:37 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 14:02	7439-92-1	

Sample: First Floor South Wing by Elev **Lab ID: 70350886020** Collected: 04/25/25 04:39 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 14:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

ANALYTICAL RESULTS

Project: Greenwood Lake MS
Pace Project No.: 70350886

Sample: Girls Locker Room CU/BF **Lab ID: 70350886021** Collected: 04/25/25 04:18 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 14:06	7439-92-1	

Sample: Girls Locker Room CU/DF **Lab ID: 70350886022** Collected: 04/25/25 04:18 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 14:09	7439-92-1	

Sample: Kitchen KS (Left) **Lab ID: 70350886023** Collected: 04/25/25 03:56 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	**1.1**	ug/L	1.0	1		05/06/25 14:15	7439-92-1	

Sample: Kitchen KS (Right) **Lab ID: 70350886024** Collected: 04/25/25 03:57 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	**1.1**	ug/L	1.0	1		05/06/25 14:18	7439-92-1	

Sample: Kitchen KF - Kettle **Lab ID: 70350886025** Collected: 04/25/25 03:54 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	**1.2**	ug/L	1.0	1		05/06/25 14:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

ANALYTICAL RESULTS

Project: Greenwood Lake MS
Pace Project No.: 70350886

Sample: Kitchen Ice Machine **Lab ID: 70350886026** Collected: 04/25/25 03:47 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 14:27	7439-92-1	

Sample: O/S 102 CU/DF **Lab ID: 70350886027** Collected: 04/25/25 04:27 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 14:36	7439-92-1	

Sample: O/S 102 CU/BF **Lab ID: 70350886028** Collected: 04/25/25 04:26 Received: 04/25/25 12:49 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep	Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	ND	ug/L	1.0	1		05/06/25 14:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

QUALITY CONTROL DATA

Project: Greenwood Lake MS
Pace Project No.: 70350886

QC Batch: 396799
QC Batch Method: EPA 200.8, Rev. 5.4
Analysis Method: EPA 200.8, Rev. 5.4
Analysis Description: NB 200.8 ICPMS DW No Prep
Laboratory: Pace Analytical Services - Newburgh
Associated Lab Samples: 70350886001, 70350886002, 70350886003, 70350886004, 70350886005

METHOD BLANK: 2091442 Matrix: Water
Associated Lab Samples: 70350886001, 70350886002, 70350886003, 70350886004, 70350886005

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	1.0	05/06/25 12:00	

LABORATORY CONTROL SAMPLE: 2091443

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.6	97	85-115	

MATRIX SPIKE SAMPLE: 2091445

Parameter	Units	70350663001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	53.3	105	70-130	

MATRIX SPIKE SAMPLE: 2094536

Parameter	Units	70350882001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.7	50	55.0	105	70-130	

SAMPLE DUPLICATE: 2091444

Parameter	Units	70350663001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	.66J		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

QUALITY CONTROL DATA

Project: Greenwood Lake MS
Pace Project No.: 70350886

QC Batch: 397280
QC Batch Method: EPA 200.8, Rev. 5.4
Analysis Method: EPA 200.8, Rev. 5.4
Analysis Description: NB 200.8 ICPMS DW No Prep
Laboratory: Pace Analytical Services - Newburgh
Associated Lab Samples: 70350886006, 70350886007, 70350886008, 70350886009, 70350886010, 70350886011, 70350886012, 70350886013, 70350886014, 70350886015, 70350886016, 70350886017, 70350886018, 70350886019, 70350886020, 70350886021, 70350886022, 70350886023, 70350886024, 70350886025

METHOD BLANK: 2094537 Matrix: Water
Associated Lab Samples: 70350886006, 70350886007, 70350886008, 70350886009, 70350886010, 70350886011, 70350886012, 70350886013, 70350886014, 70350886015, 70350886016, 70350886017, 70350886018, 70350886019, 70350886020, 70350886021, 70350886022, 70350886023, 70350886024, 70350886025

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	1.0	05/06/25 13:09	

LABORATORY CONTROL SAMPLE: 2094538

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	45.4	91	85-115	

MATRIX SPIKE SAMPLE: 2094540

Parameter	Units	70350886006 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	ND	50	50.0	100	70-130	

MATRIX SPIKE SAMPLE: 2094542

Parameter	Units	70350886016 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	ND	50	50.4	101	70-130	

SAMPLE DUPLICATE: 2094539

Parameter	Units	70350886006 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	ND	ND		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

QUALITY CONTROL DATA

Project: Greenwood Lake MS
Pace Project No.: 70350886

QC Batch: 397285
QC Batch Method: EPA 200.8, Rev. 5.4
Analysis Method: EPA 200.8, Rev. 5.4
Analysis Description: NB 200.8 ICPMS DW No Prep
Laboratory: Pace Analytical Services - Newburgh
Associated Lab Samples: 70350886026, 70350886027, 70350886028

METHOD BLANK: 2094667 Matrix: Water
Associated Lab Samples: 70350886026, 70350886027, 70350886028

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	1.0	05/06/25 14:22	

LABORATORY CONTROL SAMPLE: 2094668

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	45.2	90	85-115	

MATRIX SPIKE SAMPLE: 2094670

Parameter	Units	70350886026 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	ND	50	50.4	101	70-130	

SAMPLE DUPLICATE: 2094669

Parameter	Units	70350886026 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	ND	ND		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

QUALIFIERS

Project: Greenwood Lake MS
Pace Project No.: 70350886

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace Analytical Services, LLC
315 Fullerton Avenue
Newburgh, NY 12550
(845)562-0890

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Greenwood Lake MS
Pace Project No.: 70350886

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70350886001	**O/S Guidance CU/BF**	EPA 200.8, Rev. 5.4	396799		
70350886002	**O/S Guidance CU/DF**	EPA 200.8, Rev. 5.4	396799		
70350886003	**O/S Cafe CU/BF**	EPA 200.8, Rev. 5.4	396799		
70350886004	**O/S Cafe CU/DF**	EPA 200.8, Rev. 5.4	396799		
70350886005	**Second Floor South Wing by Ele**	EPA 200.8, Rev. 5.4	396799		
70350886006	**Second Floor South Wing by Ele**	EPA 200.8, Rev. 5.4	397280		
70350886007	**Business Office KS**	EPA 200.8, Rev. 5.4	397280		
70350886008	**Main Office KS**	EPA 200.8, Rev. 5.4	397280		
70350886009	**Nurse NS**	EPA 200.8, Rev. 5.4	397280		
70350886010	**Nurse Well Room NS**	EPA 200.8, Rev. 5.4	397280		
70350886011	**O/S 109 CU/BF**	EPA 200.8, Rev. 5.4	397280		
70350886012	**O/S 109 CU/DF**	EPA 200.8, Rev. 5.4	397280		
70350886013	**O/S 202 CU/BF**	EPA 200.8, Rev. 5.4	397280		
70350886014	**O/S 202 CU/DF**	EPA 200.8, Rev. 5.4	397280		
70350886015	**O/S 209 CU/BF**	EPA 200.8, Rev. 5.4	397280		
70350886016	**O/S 209 CU/DF**	EPA 200.8, Rev. 5.4	397280		
70350886017	**Boys Locker Room CU/BF**	EPA 200.8, Rev. 5.4	397280		
70350886018	**Boys Locker Room CU/DF**	EPA 200.8, Rev. 5.4	397280		
70350886019	**First Floor South Wing by Elev**	EPA 200.8, Rev. 5.4	397280		
70350886020	**First Floor South Wing by Elev**	EPA 200.8, Rev. 5.4	397280		
70350886021	**Girls Locker Room CU/BF**	EPA 200.8, Rev. 5.4	397280		
70350886022	**Girls Locker Room CU/DF**	EPA 200.8, Rev. 5.4	397280		
70350886023	**Kitchen KS (Left)**	EPA 200.8, Rev. 5.4	397280		
70350886024	**Kitchen KS (Right)**	EPA 200.8, Rev. 5.4	397280		
70350886025	**Kitchen KF - Kettle**	EPA 200.8, Rev. 5.4	397280		
70350886026	**Kitchen Ice Machine**	EPA 200.8, Rev. 5.4	397285		
70350886027	**O/S 102 CU/DF**	EPA 200.8, Rev. 5.4	397285		
70350886028	**O/S 102 CU/BF**	EPA 200.8, Rev. 5.4	397285		

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

WO# : 70350886

70350886

Company Name: Orange-Ulster BOCES	Contact/Report To: Maureen Doherty
Street Address: 53 Gibson Road, Goshen, NY 10924	Phone #: 845-781-4887
	E-Mail: Maureen.Doherty@ouboces.org
	Cc E-Mail: Halina.redner@ouboces.org
Customer Project #:	Invoice to: Halina Redner
Project Name:	Invoice E-mail: halina.redner@ouboces.org
Site Collection Info/Facility ID (as applicable): Greenwood Lake MS	Purchase Order # (if applicable): A24-00300
	Quote #:
Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [X] ET	County / State origin of sample(s): Orange County / New York
Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other	Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No
	Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other ____ Date Results Requested:
	DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): [ ] Yes [ ] No Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Lead	Sample Comment
O/S Guidance CU/BF	DW	G			4/25/25	4:14	1			X	
O/S Guidance CU/DF	DW	G			4/25/25	4:14	1			X	
O/S cafe CU/BF	DW	G			4/25/25	4:02	1			X	
O/S cafe CU/DF	DW	G			4/25/25	4:03	1			X	
Second Floor South Wing by Elevator CU/BF	DW	G			4/25/25	4:44	1			X	
Second Floor South Wing by Elevator CU/DF	DW	G			4/25/25	4:44	1			X	
Business Office KS	DW	G			4/25/25	4:22	1			X	
Main Office KS	DW	G			4/25/25	4:08	1			X	
Nurse NS	DW	G			4/25/25	4:10	1			X	
Nurse Well Room NS	DW	G			4/25/25	4:12	1			X	

Specify Container Size **: 3

Identify Container Preservative Type***: 2

Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: | AcctNum / Client ID: | Table #: | Profile / Template: 11266 | Prelog / Bottle Ord. ID:

Preservation non-conformance identified for sample.

Additional Instructions from Pace®:

Collected By: Printed Name: Ashley Kimiecik Signature:

Customer Remarks / Special Conditions / Possible Hazards:

Coolers: | Thermometer ID: | Correction Factor (°C): | Obs. Temp. (°C): | Corrected Temp. (°C): 01.4 | [ ] On Ice

Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
	4/25/25 12:44	Pace	4/25/25 12:44
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:

Tracking Number:

Delivered by: [ ] In-Person [ ] Courier [ ] FedEx [ ] UPS [ ] Other

Page: 1 of 3

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

WO# : 70350886

PM: FMN Due Date: 05/09/25

CLIENT: NB-OU BOCES

Company Name: Orange-Ulster BOCES

Street Address: 53 Gibson Road, Goshen, NY 10924

Customer Project #:

Project Name:

Site Collection Info/Facility ID (as applicable): Greenwood Lake MS

Contact/Report To: Maureen Doherty

Phone #: 845-781-4887

E-Mail: Maureen.Doherty@ouboces.org

Cc E-Mail: Halina.redner@ouboces.org

Invoice to: Halina Redner

Invoice E-mail: halina.redner@ouboces.org

Purchase Order # (if applicable): A24-00300

Quote #:

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [X] ET

County / State origin of sample(s): Orange County / New York

Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other

Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No

Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other

Date Results Requested:

DW PWSID # or WW Permit # as applicable:

Field Filtered (if applicable): [ ] Yes [ ] No

Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

Specify Container Size **

Identify Container Preservative Type***

Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: | AcctNum / Client ID: | Table #: | Profile / Template: 11266 | Prelog / Bottle Ord. ID:

Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Lead	Sample Comment	Preservation non-conformance identified for sample.
O/S 109 CU/BF	DW	G			4/25/25	4:20	1			X		
O/S 109 CU/DF	DW	G			4/25/25	4:21	1			X		
O/S 202 CU/BF	DW	G			4/25/25	4:33	1			X		
O/S 202 CU/DF	DW	G			4/25/25	4:33	1			X		
O/S 209 CU/BF	DW	G			4/25/25	4:30	1			X		
O/S 209 CU/DF	DW	G			4/25/25	4:30	1			X		
Boys Locker Room CU/BF	DW	G			4/25/25	4:04	1			X		
Boys Locker Room CU/DF	DW	G			4/25/25	4:05	1			X		
First Floor South Wing by Elevator CU/BF	DW	G			4/25/25	4:37	1			X		
First Floor South Wing by Elevator CU/DF	DW	G			4/25/25	4:39	1			X		

Additional Instructions from Pace® :

Collected By: Printed Name: Ashley Kinicick

Signature:

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers:	Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp. (°C):	[ ] On Ice
				2.4	✓

Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
	4/25/25 12:44	pace	4/25/25 12:49
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:

Tracking Number:

Delivered by: [ ] In-Person [ ] Courier [ ] FedEx [ ] UPS [ ] Other

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Pace® Location Requested (City/State): **Newburgh, NY**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

WO# : 70350886

PM: FMN Due Date: 05/09/25

CLIENT: NB-OU BOCES

Company Name: Orange-Ulster BOCES

Street Address: 53 Gibson Road, Goshen, NY 10924

Customer Project #:

Project Name:

Site Collection Info/Facility ID (as applicable): Greenwood Lake MS

Contact/Report To: Maureen Doherty

Phone #: 845-781-4887

E-Mail: Maureen.Doherty@ouboces.org

Cc E-Mail: Halina.redner@ouboces.org

Invoice to: Halina Redner

Invoice E-mail: halina.redner@ouboces.org

Purchase Order # (if applicable): A24-00300

Quote #:

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [X] ET

County / State origin of sample(s): Orange County / New York

Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV [ ] EQUIS [ ] Other

Regulatory Program (DW, RCRA, etc.) as applicable:

Reportable [ ] Yes [ ] No

Rush (Pre-approval required): [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day Other

Date Results Requested:

DW PWSID # or WW Permit # as applicable:

Field Filtered (if applicable): [ ] Yes [ ] No

Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

Specify Container Size **

Identify Container Preservative Type***

Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only: Proj. Mgr: | AcctNum / Client ID: | Table #: | Profile / Template: 112660 | Prelog / Bottle Ord. ID:

Preservation non-conformance identified for sample.

	Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Composite Start Time	Collected or Composite End Date	Collected or Composite End Time	# Cont.	Residual Chlorine Result	Residual Chlorine Units	Lead	Sample Comment
1	Girls Locker Room CU/BF	DW	G			4/25/25	4:18	1			X	
2	Girls Locker Room CU/DF	DW	G			4/25/25	4:18	1			X	
3	Kitchen KS (Left)	DW	G			4/25/25	3:56	1			X	
4	Kitchen KS (Right)	DW	G			4/25/25	3:57	1			X	
5	Kitchen KF - Kettle	DW	G			4/25/25	3:54	1			X	
6	Kitchen Ice Machine	DW	G			4/25/25	3:47	1			X	
7	OIS 102 CU DF	DW	G			4/25/25	4:27	1			X	
8	OIS 102 CU BF	DW	G			4/25/25	4:26	1			X	
		DW	G			4/25/25		1			X	
		DW	G			4/25/25		1			X	

Additional Instructions from Pace®:

Collected By: Printed Name: Ashley Kiniecik

Signature:

Customer Remarks / Special Conditions / Possible Hazards:

Coolers: | Thermometer ID: | Correction Factor (°C): | Obs. Temp. (°C): | Corrected Temp. (°C): 21.4 | [ ] On Ice

Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
	4/25/25; 12:49	Pace	4/4/25 12:49
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:
Relinquished by/Company: (Signature)	Date/Time:	Received by/Company: (Signature)	Date/Time:

Tracking Number:

Delivered by: [ ] In- Person [ ] Courier [ ] FedEX [ ] UPS [ ] Other

Page: 3 of 3

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Sample Condition Upon Receipt Form (SCUR)

WO# : 70350886

PM: FMN Due Date: 05/09/25
CLIENT: NB-OU BOCES

Project #
Client:

Date and Initials of person:
Examining contents:
Label:
Deliver to location:
pH:

Thermometer Used: IRG4 Date: 4/25 Time: 1249 Initials:

State of Origin: NY

Cooler #1 Temp.°C 21.4 (Visual) 0.2 @ 0.0°C, -0.5 @20.0°C (Correction Factor) (Actual) ~~Samples on ice, cooling process has begun~~

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☒ Client ☐ Commercial ☐ Pace ☐ Other

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground ☐ Other

Tracking #

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ No Ice: ~~Wet~~ Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

		Comments:
Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☒ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☒ N/A	Preservation Information: Preservative:
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☒ N/A	Lot #/Trace #: Date: Time: Initials:
Exceptions: Vials, Microbiology, O&G, Metals		
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☒ N/A	
Trip Blank Present:	☐ Yes ☐ No ☒ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: Date/Time:

Comments/Resolution: