

ADDENDUM #2

To BID #25029

Blacktop Surfacing Repairs Project

May 8, 2025

TO: ALL PROSPECTIVE BIDDERS
FROM: Travis Unified School District

RE: Addendum #2

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents as noted below.

Questions and responses:

1. Please provide a bid form or clarify if the contractor's should issue a proposal.

Answer – The Bid form is on the Districts website at [RFPs/Bids/CUPCCAA - Travis Unified School District](#) under the forms tab.

2. Please clarify which striping is to be re-done on the play court areas

Answer – The District will provide an updated list of items to be striped on the play courts, with colors, no later than 1:00 pm on 13 May.

3. Please clarify that the "Apply two (4") inches of 1/2" Type A AC" for the Center Elementary Work refers to two equal lifts of AC at 2" thick each, for a total of 4".

Answer – The work refers to two equal lifts, totaling 4”.

4. Please clarify that a 2' deep AC curb would be acceptable for the hillside area on Center Elementary.

Answer – A 2’ deep AC curb is acceptable.