

**ADDENDUM #1**  
**To BID #25032**  
**Carpet Replacement Project**

May 8, 2025

TO: ALL PROSPECTIVE BIDDERS  
FROM: Travis Unified School District

**RE: Addendum #1**

*This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents as noted below.*

**Questions and responses:**

1. Who is moving the furniture and is that scheduled or tentatively scheduled?

**Answer – The District will have staff that will move out as much furniture as possible and move items to one side of the classroom. The District will move furniture to the other side to complete the work.**

2. Has the VCT under the walk off carpet, where it occurs, been tested for asbestos?

**Answer – The District will have the areas tested for asbestos and will have the carpet abated if needed.**

3. Does the district have any contingency money to cover subfloor repair due to demo, or replacement of subfloor where dry rot occurs?

**Answer – The Contractor will be responsible for repairs on a T&M basis. District approval required prior to repair.**

4. Are any certifications applicable for this project?

**Answer – A (General Engineering), B (General Contractor), or C-15 - Flooring and Floor Covering Contractors**

5. Where can I get the BID of a form?

**Answer – The Bid form is on the Districts website at [RFPs/Bids/CUPCCAA - Travis Unified School District](#) under the forms tab.**