

ENVIRONMENTAL LABWORKS, INC.

April 25, 2025

Rondout Valley CSD
P.O. Box 9
122 Kyserike Rd.
Accord, NY 12404

Dear James,

The following are results of the analyses performed on water samples from **Rondout Valley High School and District Office** received at the laboratory on 04/03/25.

Date/Time Collected: 04/02/25 4:53pm - 04/03/25 7:09am First Draw
Collected By: RVSD
Project ID: 04032518
Secondary ID: RH251163-88
PWS ID: 5502495

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
400 Wing Fountain 04032518-1	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
600 Wing Fountain 04032518-2	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
200 Wing Fountain 04032518-3	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
300 Wing Fountain 04032518-4	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Girls Gym Fountain 04032518-5	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
500 Wing Fountain 04032518-6	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Boys Gym Fountain 04032518-7	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Outside Boiler Drain 04032518-8	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
200 Wing Bottle Filler 04032518-9	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
300 Wing Bottle Filler 04032518-10	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25

ENVIRONMENTAL LABWORKS, INC.

Rondout Valley High School and District Office - 04032518

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Sink 2 Kitchen 04032518-11	EPA 200.8 Lead	0.0021 mg/L		0.005 mg/L	04/15/25
Pot 1 Kitchen 04032518-12	EPA 200.8 Lead	0.0035 mg/L		0.005 mg/L	04/15/25
Boys Gym Bottle Filler 04032518-13	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Pot 2 Kitchen 04032518-14	EPA 200.8 Lead	0.0146 mg/L	X	0.005 mg/L	04/15/25
Sink 3 Kitchen 04032518-15	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Kitchen Mixer 04032518-16	EPA 200.8 Lead	0.0629 mg/L	X	0.005 mg/L	04/17/25
Girls Gym Bottle Filler 04032518-17	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Pot 3 Kitchen 04032518-18	EPA 200.8 Lead	0.0022 mg/L		0.005 mg/L	04/15/25
400 Wing Bottle Filler 04032518-19	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Sink 1 Kitchen 04032518-20	EPA 200.8 Lead	0.0017 mg/L		0.005 mg/L	04/15/25
600 Wing Bottle Filler 04032518-21	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Concession Stand Sink 04032518-22	EPA 200.8 Lead	0.153 mg/L	X	0.005 mg/L	04/15/25
Life Skills Sink 04032518-23	EPA 200.8 Lead	0.0219 mg/L	X	0.005 mg/L	04/21/25
500 Wing Bottle Filler 04032518-24	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
District Office Bottle Filler 04032518-25	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
District Office Kitchen Sink 04032518-26	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.


Rondout Valley High School and District Office - 04032518

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director

ENVIRONMENTAL LABWORKS, INC.

April 25, 2025

Rondout Valley CSD
P.O. Box 9
122 Kyserike Rd.
Accord, NY 12404

Dear James,

The following are results of the analyses performed on water samples from **Rondout Valley Middle School** received at the laboratory on 04/03/25.

Date/Time Collected: 04/02/25 3:45pm - 04/03/25 9:05am First Draw
Collected By: RVSD
Project ID: 04032515
Secondary ID: RM251115-45
PWS ID: 5502494

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
A Wing Fountain 04032515-1	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Girls Gym Fountain 04032515-2	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Tech Hall Fountain 04032515-3	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Main 1 st Fl Fountain 04032515-4	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
A Wing 2 nd Fl Fountain 04032515-5	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Main 2 nd Fl Fountain 04032515-6	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Boys Gym Fountain 04032515-7	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
C Wing 2 nd Fl Fountain 04032515-8	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
C Wing 1 st Fl Fountain 04032515-9	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Cafeteria Fountain 04032515-10	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25

ENVIRONMENTAL LABWORKS, INC.

NYSDOH #10824

Rondout Valley Middle School - 04032515

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
C Wing 1 st Fl Bottle Filler 04032515-11	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
M 202 Sink 2 04032515-12	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
C Wing 2 nd Fl Bottle Filler 04032515-13	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
M 202 Sink 3 04032515-14	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
M Wing 2 nd Fl Bottle Filler 04032515-15	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
M 202 Sink 1 04032515-16	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
A Wing 1 st Fl Bottle Filler 04032515-17	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
A Wing 2 nd Fl Bottle Filler 04032515-18	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Girls Gym Bottle Filler 04032515-19	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Boys Gym Bottle Filler 04032515-20	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Kitchen Sink 1 04032515-21	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
M 202 Sink 4 04032515-22	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Tech Hall Bottle Filler 04032515-23	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Cafeteria Bottle Filler 04032515-24	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Main Hall Bottle Filler 2 nd Fl 04032515-25	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25


ENVIRONMENTAL LABWORKS, INC.

Rondout Valley Middle School - 04032515

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Kitchen Sink 3 04032515-26	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
M 202 Sink 5 04032515-27	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
M 202 Sink 6 04032515-28	EPA 200.8 Lead	0.0011 mg/L	0.005 mg/L	04/17/25
M 202 Sink 7 04032515-29	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Kitchen Sink 2 04032515-30	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25
Kitchen Sink 4 04032515-31	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	04/17/25

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director

ENVIRONMENTAL LABWORKS, INC.

April 25, 2025

Rondout Valley CSD
P.O. Box 9
122 Kyserike Rd.
Accord, NY 12404

Dear James,

The following are results of the analyses performed on water samples from **Kerhonkson Elementary School** received at the laboratory on 04/03/25.

Date/Time Collected: 04/02/25 2:31pm - 04/03/25 9:03am First Draw
Collected By: RVSD
Project ID: 04032517
Secondary ID: KE251155-62

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Kitchen Sink 3 04032517-1	EPA 200.8 Lead	0.0106 mg/L	X	0.005 mg/L	04/15/25
2 nd Fl Bottle Filler 04032517-2	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Kitchen Sink 1 04032517-3	EPA 200.8 Lead	0.0053 mg/L	X	0.005 mg/L	04/15/25
Kitchen Sink 2 04032517-4	EPA 200.8 Lead	0.0205 mg/L	X	0.005 mg/L	04/15/25
Gym Hall Bottle Filler 04032517-5	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Cafeteria Bottle Filler 04032517-6	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Main Hall Bottle Filler 04032517-7	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25
Cafeteria Fountain 04032517-8	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/15/25

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.


PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Kerhonkson Elementary School - 04032517

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director

ENVIRONMENTAL LABWORKS, INC.

April 25, 2025

Rondout Valley CSD
P.O. Box 9
122 Kyserike Rd.
Accord, NY 12404

Dear James,

The following are results of the analyses performed on water samples from **Marbletown Elementary School** received at the laboratory on 04/03/25.

Date/Time Collected: 04/02/25 3:18pm - 4/03/25 9:35am First Draw
Collected By: Ulster BOCES
Project ID: 04032516
Secondary ID: ME251146-54
PWS ID: 5502484

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Kitchen Sink 2 04032516-1	EPA 200.8 Lead	0.0092 mg/L	X	0.005 mg/L	04/17/25
3 rd Grade Hall Fountain 04032516-2	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/17/25
Kitchen Sink 1 04032516-3	EPA 200.8 Lead	0.314 mg/L	X	0.005 mg/L	04/21/25
Main Hall Bottle Filler 04032516-4	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/17/25
3 rd Grade Hall Bottle Filler 04032516-5	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/17/25
Kitchen Sink 3 04032516-6	EPA 200.8 Lead	0.0073 mg/L	X	0.005 mg/L	04/17/25
Cafeteria Bottle Filler 04032516-7	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/17/25
Cafeteria Sink 04032516-8	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/17/25
Main Hall Fountain 04032516-9	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	04/17/25

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.


Marbletown Elementary School - 04032516

Qualifier(Q) :

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director