

ENVIRONMENTAL LABWORKS, INC.

May 8, 2025

Rondout Valley CSD
P.O. Box 9
122 Kyserike Rd.
Accord, NY 12404

Dear James,

The following are results of the analyses performed on water samples from **Rondout Valley CSD** received at the laboratory on 05/02/25.

Date/Time Collected: 05/02/25 5:37-8:03am First Draw
Collected By: RVCSD
Project ID: 05022503
Secondary ID: RV251630-39
PWS ID: ---

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Marbletown ES Kitchen Sink 1 05022503-1	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	05/07/25
Marbletown ES Kitchen Sink 2 05022503-2	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	05/07/25
Marbletown ES Kitchen Sink 3 05022503-3	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	05/07/25
Kerhonkson ES Kitchen Sink 1 05022503-4	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	05/07/25
Kerhonkson ES Kitchen Sink 3 05022503-5	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	05/07/25
HS Life Skills 05022503-6	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	05/07/25
Concession Stand Sink 05022503-7	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	05/07/25
Concession Stand Fountain 1 05022503-8	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	05/07/25
Concession Stand Fountain 2 05022503-9	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	05/07/25
Concession Stand Bottle Filler 05022503-10	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	05/07/25


PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Rondout Valley CSD - 05022503

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #10854. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director