



CFS Oaklyn
33 W. Haddon Avenue
Oaklyn, NJ 08107

2/14/2025 12:03
SAMPLE NUMBER: Y731
DATE SAMPLED: 1/30/25
DATE/TIME RECEIVED: 1/30/25 16:30
COLLECTED BY: Client

CERTIFICATE OF ANALYSIS

N.J.D.E.P. CERTIFICATION # 06003

Results in mg/l(ppm) unless otherwise noted

Sample #	Sample Location	Date Sampled	Time Sampled	DF	Lead	RL	Date/Time Analyzed
Y731-1	Pantry Sink F.D.	1/30/2025	6:00	1	<0.002	0.002	2/3/2025 12:36
Y731-2	Kitchen Sink F.D.	1/30/2025	6:01	1	<0.002	0.002	2/3/2025 12:41
Y731-3	Kitchen 3 Bay F.D.	1/30/2025	6:02	1	<0.002	0.002	2/3/2025 12:46
Y731-4	1st Fl. Children Bath 1 F.D.	1/30/2025	6:04	1	<0.002	0.002	2/3/2025 12:51
Y731-5	1st Fl. Children Bath 2 F.D.	1/30/2025	6:05	1	<0.002	0.002	2/3/2025 12:56
Y731-6	1st Fl. Water cooler	1/30/2025	6:07	1	<0.002	0.002	2/3/2025 13:01
Y731-7	1st Fl. Womans Bath F.D.	1/30/2025	6:08	1	<0.002	0.002	2/3/2025 13:06
Y731-8	1st Floor Mens Bath F.D.	1/30/2025	6:09	1	<0.002	0.002	2/3/2025 13:22
Y731-9	2nd Fl. Child Bath 1 F.D.	1/30/2025	6:12	1	<0.002	0.002	2/3/2025 13:37
Y731-10	2nd Fl. Child Bath 2 F.D.	1/30/2025	6:13	1	<0.002	0.002	2/3/2025 13:42
Y731-11	Staff Bath 2nd Fl. F.D.	1/30/2025	6:15	1	<0.002	0.002	2/4/2025 10:30
Y731-12	Water cooler 2nd Floor	1/30/2025	6:16	1	<0.002	0.002	2/4/2025 10:35
Y731-13	Classroom 1	1/30/2025	6:18	1	<0.002	0.002	2/4/2025 10:40
Y731-14	Classroom 2	1/30/2025	6:20	1	<0.002	0.002	2/4/2025 11:05
Y731-15	Classroom 3	1/30/2025	6:22	1	<0.002	0.002	2/4/2025 11:10
Y731-16	Classroom 4	1/30/2025	6:23	1	<0.002	0.002	2/4/2025 11:15
Y731-17	Classroom 5	1/30/2025	6:26	1	<0.002	0.002	2/4/2025 11:20
Y731-18	Classroom 6	1/30/2025	6:28	1	<0.002	0.002	2/4/2025 11:25

Latish Menghani
Lab Director



CFS Oaklyn
33 W. Haddon Avenue
Oaklyn, NJ 08107

2/14/2025 12:03
SAMPLE NUMBER: Y731
DATE SAMPLED: 1/30/25
DATE/TIME RECEIVED: 1/30/25 16:30
COLLECTED BY: Client

CERTIFICATE OF ANALYSIS

N.J.D.E.P. CERTIFICATION # 06003

Results in mg/l(ppm) unless otherwise noted

Sample #	Sample Location	Date Sampled	Time Sampled	DF	Copper	RL	Date/Time Analyzed
Y731-1	Pantry Sink F.D.	1/30/2025	6:00	1	0.428	0.05	2/4/2025 10:28
Y731-2	Kitchen Sink F.D.	1/30/2025	6:01	1	0.349	0.05	2/4/2025 10:28
Y731-3	Kitchen 3 Bay F.D.	1/30/2025	6:02	1	0.289	0.05	2/4/2025 10:29
Y731-4	1st Fl. Children Bath 1 F.D.	1/30/2025	6:04	1	0.292	0.05	2/4/2025 10:29
Y731-5	1st Fl. Children Bath 2 F.D.	1/30/2025	6:05	1	0.358	0.05	2/4/2025 10:30
Y731-6	1st Fl. Water cooler	1/30/2025	6:07	1	<0.05	0.05	2/4/2025 10:31
Y731-7	1st Fl. Womans Bath F.D.	1/30/2025	6:08	1	0.251	0.05	2/4/2025 10:33
Y731-8	1st Floor Mens Bath F.D.	1/30/2025	6:09	1	0.277	0.05	2/4/2025 10:35
Y731-9	2nd Fl. Child Bath 1 F.D.	1/30/2025	6:12	1	0.211	0.05	2/4/2025 10:36
Y731-10	2nd Fl. Child Bath 2 F.D.	1/30/2025	6:13	1	0.165	0.05	2/4/2025 10:36
Y731-11	Staff Bath 2nd Fl. F.D.	1/30/2025	6:15	1	0.1614	0.05	2/4/2025 10:37
Y731-12	Water cooler 2nd Floor	1/30/2025	6:16	1	<0.05	0.05	2/4/2025 10:37
Y731-13	Classroom 1	1/30/2025	6:18	1	0.241	0.05	2/4/2025 10:38
Y731-14	Classroom 2	1/30/2025	6:20	1	0.207	0.05	2/4/2025 10:38
Y731-15	Classroom 3	1/30/2025	6:22	1	0.358	0.05	2/4/2025 10:39
Y731-16	Classroom 4	1/30/2025	6:23	1	0.155	0.05	2/4/2025 10:39
Y731-17	Classroom 5	1/30/2025	6:26	1	0.18	0.05	2/4/2025 10:43
Y731-18	Classroom 6	1/30/2025	6:28	1	0.188	0.05	2/4/2025 10:43

Latish Menghani
Lab Director



VINELAND ENVIRONMENTAL LABORATORIES

Water and Wastewater Testing

782 S. Brewster Rd., Ste. B1, Vineland, NJ 08361
Office: (856) 692-6800 • Cell: (856) 297-3063 • Fax: (856) 692-3700

CHAIN OF CUSTODY

Page 1 of 1

Bill to/Report to: (if different)

Sampling Site Address: (if different)

Client/Account No. CFS ST ALEIS

Address Head STREET

City/State/Zip DAKOTA, MS

Phone/Fax

P.O. No.

Client Contact Joe Flood

VEL Contact:

Lab LIMS No: 17731

LAB USE ONLY:

Ascorbic/HCl Vials # HCl Vials

Na₂S₂O₃ # HCl Vials

Na OH/Zn acetate pH

10 HNO₃ pH Present in 105

H₂SO₄ pH

NaOH pH

Unpreserved

HCl pH

10 Temp control 20 ID #

MATRIX CODES

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

OIL: OIL

SOL: NON SOLID

MI: MISCELLANEOUS

X: OTHER

ANALYSIS REQUESTED

Field pH, Temp (C or F), DO, Cl₂ S. Cond. etc.

PROJECT	FIELD ID	Date	Collection	Military Time	Matrix	Code	Total	Number of Containers	H ₂	O ₂	C	I	S	P	H	N	O	A	P	B
A	Pantry Sink	11/30/05	06:00		DO	1														
B	Kitchen Sink	11/30/05	06:01																	
C	Kitchen 3 Bay Sink	11/30/05	06:02																	
D	Childcare Bath Sink 1	11/30/05	06:04																	
E	Childcare Bath Sink 2	11/30/05	06:05																	
F	Water Cooler 1st Floor	11/30/05	06:07																	
G	1st Fl Womens Bath Sink	11/30/05	06:08																	
H	1st Fl Mens Bath Side	11/30/05	06:09																	
I	2nd Fl Child Sick 1	11/30/05	06:12																	
J	2nd Fl Child Sick 2	11/30/05	06:13																	

SAMPLED BY: (Name/Company)

Verbal/fax data due: 1 1 1

Hardcopy due: 1 1 1

Please call for pricing and availability on rush (<14-21 day) turnaround and on all but standard format.

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK). IE 8AM IS 0800, 4 PM IS 1600

RELINQUISHED BY SAMPLER	DATE	TIME	RECEIVED BY	DATE	TIME	DELIVERY METHOD	Custody Seal Number
1 <u>Agro 12/00/04</u>	<u>11/30/05</u>	<u>21:00</u>	<u>1 2800</u>	<u>11/30/05</u>	<u>10:00</u>	☐ UPS ☐ FEDEX ☐ OTHER <u> </u>	
2 RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME		
3 RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME		
4 RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME		
5 RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME		

Hazardous: ☐ Yes ☐ No

