



181 US Hwy 46
Mine Hill, NJ 07803
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:

Maywood Public Schools

Performed For:

Maywood Public Schools

John Montany

452 Maywood Avenue, Maywood, NJ, 07607

Prepared By:

LEW Environmental Services, LLC.

181 US Hwy 46

Mine Hill, NJ 07803

Phone (908) 654-8068

Fax (908) 654-8069

Website <http://www.LEWCorp.com>

Inspection Date: 12/23/2024

Project Number: 2743

Table of Contents

Contact Information	3
Introduction	4
Sampling Methodology	4
Drinking Water Results	5
Recommendations	5
Additional Recommendations	6

Appendices

Appendix A	Exceedances
Appendix B	Recommendations
Appendix C	All results
Appendix D	Floor Plan(S)
Appendix E	Water Outlet Inventory(ies)
Appendix F	Laboratory Data

Contact Information

Education Agency

Client Contact:	John Montany
Client Name:	Maywood Public Schools
Street Address	452 Maywood Avenue, Maywood, NJ, 07607
Phone Number:	(201) 843-4598

Sampler(s)

Site Assessor(s):	Pablo Viera
Signature:	
Date:	1/21/25

Firm

Organization:	LEW Environmental Services, LLC.
Certification #:	NJDCA 00015 E
Street:	181 US Hwy 46
City, State & Zip:	Mine Hill, NJ 07803
Phone Number:	908-654-8068
Web Address:	http://www.lewcorp.com

Laboratory

Organization:	Environmental Hazard Services, LLC
Street:	7469 Whitepine Road
City, State & Zip:	Richmond, VA 23237
NJDEP Certification #	VA008
Phone Number:	800-347-4010

Introduction

LEW Environmental Services, LLC. was contracted by Maywood Public Schools to test for the presence of lead in drinking water in two facilities in the district.

Sampling Methodology

LEW Environmental Services, LLC. followed NJAC 6A:26. Full details on sampling practices can be found in Districts Sampling Plan.

All samples were collected in 250mL wide mouth plastic containers that was prepackaged by the analytical laboratory. The sample containers may contain nitric acid, if expedited analysis is required. If not, nitric acid will be added to each sample upon arrival at the laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than forty-eight hours. If second draw samples were collected, they were collecting following a flushing protocol outlined in the District's Sampling Plan.

Drinking Water Results

On December 23, 2024, LEW Environmental Services, LLC. collected the following number of water samples:

Maywood Avenue School

- 19 first draw samples collected plus 1 QAQC blank sample
- 1 sample above the 15ppb action level

Memorial School

- 14 first draw samples collected plus 1 QAQC blank sample
- 0 samples above the 15ppb action level

The complete list of samples that exceeded the 15ppb limit can be found in Appendix A. The complete list of all sample results can be found in Appendix C. The laboratory results can be found in Appendix F.

Certain outlets could not or were not tested due to various reasons. The following table lists those locations and the reason why samples were not collected.

School	Sample Location	Reason for not testing.
Maywood Avenue	HW-Elevator Water Fountain	Not functional
Maywood	O/S 2 nd Floor Elevator Water Fountain	Not functional
Memorial School	A-10 Water Fountain	Not functional
Memorial School	HW Outside C5 Water Fountain	Not functional
Memorial School	Gym HW Water Fountain	Not functional
Memorial School	Rm C2 Bubbler	Not functional

Recommendations

On December 23, 2024, LEW Environmental Services, LLC. collected the first draw samples. We recommend the following actions.

Those outlets where the first draw sample tested below 15ppb are not considered to be elevated and no remediation is necessary.

For those outlets where the first draw sample exceeds 15ppb the following steps are recommended:

- 1) Immediately discontinue use of the outlets.
- 2) Conduct second draw (flush) samples on these outlets to further delineate source of contamination.

A complete list of recommendations per outlet can be found in Appendix B.

Additional Recommendations

- 1) Follow-up samples should be collected after any remediation efforts in order to determine the efficacy of the work.
- 2) Any of the inoperable/non-functioning outlets listed above that are brought back into service should be sampled.
- 3) Comply with all requirements set forth in NJAC 6A:26.

Appendix A Exceedances

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Maywood Avenue School	12/23/2024	1/3/2025	MAS-S-16	KITCHEN	25

Appendix B Recommendations

Building	Location	Remediation Recommendation
Maywood Avenue School	KITCHEN	Discontinue use and perform second draw sampling


Appendix C All Results

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Maywood Avenue School	12/23/2024	1/3/2025	MAS-BF-1	HW O/S 104	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-WC-1A	HW O/S 104	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-BF-3	HW 116	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-WC-3A	HW 116	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-BF-4	HW BIG GYM	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-WC-4A	HW BIG GYM	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-2FL-5	O/S 200	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-2FL-5A	O/S 200	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-2FL-7	O/S 207	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-2FL-7A	O/S 207	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-WC-8	BOYS LR	<1.00
Maywood Avenue School	12/23/2024	1/8/2025	MAS-WC-9	GIRLS LR	3.51
Maywood Avenue School	12/23/2024	1/3/2025	MAS-WC-10	BASEMTN O/S CAFE	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-S-11	KITCHEN	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-S-12	KITCHEN	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-S-13	KITCHEN	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-S-14	KITCHEN	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-S-15	KITCHEN	<1.00
Maywood Avenue School	12/23/2024	1/3/2025	MAS-S-16	KITCHEN	25
Maywood Avenue School	12/23/2024	1/3/2025	MAS-DW-17	DETENTION	<1.00

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Memorial School	12/23/2024	1/3/2025	MS-WC-2	HW OUTSIDE A-10	<1.00
Memorial School	12/23/2024	1/3/2025	MS-BF-3	HW OUTSIDE NURSE	<1.00
Memorial School	12/23/2024	1/3/2025	MS-WC-3A	HW OUTSIDE NURSE	<1.00
Memorial School	12/23/2024	1/3/2025	MS-WC-4	HW OUTSIDE NURSE	<1.00
Memorial School	12/23/2024	1/3/2025	MS-S-5	KITCHEN	<1.00
Memorial School	12/23/2024	1/3/2025	MS-WC-6	HW/LIBRARY	<1.00
Memorial School	12/23/2024	1/3/2025	MS-BF-8	GYM HW	<1.00
Memorial School	12/23/2024	1/3/2025	MS-BF-8A	GYM HW	<1.00
Memorial School	12/23/2024	1/3/2025	MS-WC-9	GYM HW	1.22
Memorial School	12/23/2024	1/3/2025	MS-DW-10	RM D5	<1.00
Memorial School	12/23/2024	1/3/2025	MS-DW-11	ROOM D4	<1.00
Memorial School	12/23/2024	1/3/2025	MS-DW-12	ROOM D2	<1.00
Memorial School	12/23/2024	1/3/2025	MS-DW-13	ROOM C6	<1.00
Memorial School	12/23/2024	1/3/2025	MS-DW-14	ROOM C4	<1.00
Memorial School	12/23/2024	1/3/2025	MS-DW-15	DETENTION	<1.00

Appendix D Floor Plan(s)

Maywood Avenue School





Appendix E Water Outlet Inventory(ies)

Attachment C - Drinking Water Outlet Inventory

(To be completed for each school)

Name of School: Maywood Avenue School

Address: 452 Maywood Avenue, Maywood

Grade Levels: 4-8

Year School Constructed:

Renovations/Additions:

Individual school project officer Name/Signature: _____

Date completed: 10/12/16

[illegible]

Attachment C - Drinking Water Outlet Inventory

(To be completed for each school)

Name of School: Memorial School

Address: 764 Grant Ave, Maywood, NJ 07607

Grade Levels: K-3

Year School Constructed: 1954

Renovations/Additions: 2007

Individual school project officer Name/Signature: _____

Date completed: 10/12/16

#[1]	Type	Location	Code	Operational [2] (Y/N)	Signs of Corrosion [3] (Y/N)	Filter [4] (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
1	Water Fountain	A-10	MS-DW-1	N	N	N	Y		N		Standard		Not Working
2	Water Fountain	HW Outside A-10	MS-DW-2	Y	N	N	Y	N	N	Y	Oasis		
3	Water Fountain	HW Outside Nurse	MS-DW-3	Y	N	N	Y	N	N	Y	Oasis		
4	Water Fountain	HW Outside Nurse	MS-DW-4	N	N	N	Y	N	N	Y	Oasis		
5	Faucet	Kitchen	MS-S-5	Y	N	N	Y	N	N	N			3 Faucets
6	Water Fountain	HW/Librafy	MS-DW-6	Y	N	N	Y	N	N	Y	Elkay	EBFSA4G-1Y	
7	Bottle Filler	HW/ C5	MS-BF-7	N	N	Y	Y	N	Y	Y	Elkay	EZFS8-1A	
7A	Water Fountain	HW Outside C5	MS-WC-7A	N	N	N	Y	N	N	Y			Not Working
8	Water Fountain	Gym HW	MS-DW-8	Y	N	N	Y	N	N	Y	Elkay	EZFS8-1A	Not Working
9	Water Fountain	Gym HW	MS-DW-9	Y	N	N	Y	N	N	Y	Elkay	EZFS8-1A	
10	Bubbler	RM D5	MS-DW-10	Y	N	N	Y	N	N	Y			
11	Bubbler	RM D4	MS-DW-11	Y	N	N	Y	N	N	Y			
12	Bubbler	RM D2	MS-DW-12	Y	N	N	Y	N	N	Y			
13	Bubbler	RM C6	MS-DW-13	Y	N	N	Y	N	N	Y			
14	Bubbler	RM C4	MS-DW-14	Y	N	N	Y	N	N	Y			
15	Bubbler	RM C2	MS-DW-15	N	N	N	Y	N	N	Y			Not Working

Appendix F Laboratory Data



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 24-12-05265

Received Date: 12/30/2024
Reported Date: 01/08/2025
Sampled By: Pablo Viera
Tech Certification #:

Project/Test Address: 2743; Maywood Avenue School; 452 Maywood Ave; Maywood, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-12-05265-001	MAS-BF-1	12/23/2024	HW O/S 104	<1.00	01/03/2025	
24-12-05265-002	MAS-WC-1A	12/23/2024	HW O/S 104	<1.00	01/03/2025	
24-12-05265-003	MAS-BF-3	12/23/2024	HW 116	<1.00	01/03/2025	
24-12-05265-004	MAS-WC-3A	12/23/2024	HW 116	<1.00	01/03/2025	
24-12-05265-005	MAS-BF-4	12/23/2024	HW BIG GYM	<1.00	01/03/2025	
24-12-05265-006	MAS-WC-4A	12/23/2024	HW BIG GYM	<1.00	01/03/2025	
24-12-05265-007	MAS-2FL-5	12/23/2024	O/S 200	<1.00	01/03/2025	
24-12-05265-008	MAS-2FL-5A	12/23/2024	O/S 200	<1.00	01/03/2025	
24-12-05265-009	MAS-2FL-7	12/23/2024	O/S 207	<1.00	01/03/2025	
24-12-05265-010	MAS-2FL-7A	12/23/2024	O/S 207	<1.00	01/03/2025	
24-12-05265-011	MAS-WC-8	12/23/2024	BOYS LR	<1.00	01/03/2025	
24-12-05265-012	MAS-WC-9	12/23/2024	GIRLS LR	3.51	01/08/2025	
24-12-05265-013	MAS-WC-10	12/23/2024	BASEMTN O/S CAFE	<1.00	01/03/2025	

Environmental Hazards Services, L.L.C

Client Number: 201327
Project/Test Address: 2743; Maywood Avenue School; 452 Maywood Ave;
Maywood, NJ

Report Number: 24-12-05265

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-12-05265-014	MAS-S-11	12/23/2024	KITCHEN	<1.00	01/03/2025	
24-12-05265-015	MAS-S-12	12/23/2024	KITCHEN	<1.00	01/03/2025	
24-12-05265-016	MAS-S-13	12/23/2024	KITCHEN	<1.00	01/03/2025	
24-12-05265-017	MAS-S-14	12/23/2024	KITCHEN	<1.00	01/03/2025	
24-12-05265-018	MAS-S-15	12/23/2024	KITCHEN	<1.00	01/03/2025	
24-12-05265-019	MAS-S-16	12/23/2024	KITCHEN	25.0	01/03/2025	
24-12-05265-020	MAS-DW-17	12/23/2024	DETENTION	<1.00	01/03/2025	

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



EHS
Laboratories

ENVIRONMENTAL HAZARDS SERVICES, LLC


ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907

105

24-12-05265



Company Name: LEW Environmental Services LLC

Account #: 201327

Due Date:

01/07/2025

(Tuesday)

AE

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 654-8068

Email: labresults@lewenvironmental.com

Fax: 908-654-8069

18

Project Name / Collection Address: Maywood Avenue School

452 Maywood Ave

City/State/Zip: Maywood, NJ

(Required)

Project #: 2743

Sampled By: Pablo Viera

License # (if Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (if Applicable):

☒ 5 Day Turnaround

☐ 3 Day Turnaround

☐ 2 Day Turnaround

☐ 1 Day Turnaround * Call Ahead

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	Temp at time of Receipt:
1	MAS-BF-1	HW O/S 104	12-23-24	8:15 AM PM						
2	MAS-WC-1A	" " " "		AM / PM						
3	-BF-3	HW-116		AM / PM						
4	-WC-3A	" " " "		AM / PM						
5	-BF-4	HW Big Gym		AM / PM						
6	-WC-4A	" " " "		AM / PM						
7	-BF-2FL-5	O/S-200		AM / PM						
8	-WC-2FL-5A	" " " "		AM / PM						
9	-WC-2FL-7	O/S-207		AM / PM						
10	-BF-2FL-7A	" " " "		AM / PM						
Released by: <u>Pablo Viera</u>			Signature: <u>Pablo Viera</u>		Date/Time: <u>12-26-24 6:20 PM</u>					
Released by: <u>KT HARRIS</u>			Signature: <u>KT Harris</u>		Date/Time: <u>12-26-24 @ 12:44</u>					

gm

Client Name: Maywood Avenue SchoolPage 2 of 2Order # 2743

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
11	MAS-WC-8	Boys LR	12-23-24	8:15	AM/PM					
12	-WC-9	Girls LR			AM/PM					
13	-WC-10	Basement O/S cafe			AM/PM					
14	-S-11	Kitchen			AM/PM					
15	-S-12				AM/PM					
16	-S-13				AM/PM					
17	-S-14				AM/PM					
18	-S-15				AM/PM					
19	-SP-16				AM/PM					
20	-DW-17	Detention			AM/PM					
21					AM/PM					
22					AM/PM					
23					AM/PM					
24					AM/PM					
25					AM/PM					
26					AM/PM					
27					AM/PM					
28					AM/PM					
29					AM/PM					
30					AM/PM					

KTHALLIS M. Glauert

12/30/24 @ 12:44pm



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 24-12-05327

Received Date: 12/30/2024
Reported Date: 01/07/2025
Sampled By: Pablo Viera
Tech Certification #:

Project/Test Address: 2743; Memorial School; 764 Grant Ave; Maywood, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-12-05327-001	MS-WC-2	12/23/2024	HW OUTSIDE A-10	<1.00	01/03/2025	
24-12-05327-002	MS-BF-3	12/23/2024	HW OUTSIDE NURSE	<1.00	01/03/2025	
24-12-05327-003	MS-WC-3A	12/23/2024	HW OUTSIDE NURSE	<1.00	01/03/2025	
24-12-05327-004	MS-WC-4	12/23/2024	HW OUTSIDE NURSE	<1.00	01/03/2025	
24-12-05327-005	MS-S-5	12/23/2024	KITCHEN	<1.00	01/03/2025	
24-12-05327-006	MS-WC-6	12/23/2024	HW/LIBRARY	<1.00	01/03/2025	
24-12-05327-007	MS-BF-8	12/23/2024	GYM HW	<1.00	01/03/2025	
24-12-05327-008	MS-BF-8A	12/23/2024	GYM HW	<1.00	01/03/2025	
24-12-05327-009	MS-WC-9	12/23/2024	GYM HW	1.22	01/03/2025	
24-12-05327-010	MS-DW-10	12/23/2024	RM D5	<1.00	01/03/2025	
24-12-05327-011	MS-DW-11	12/23/2024	ROOM D4	<1.00	01/03/2025	
24-12-05327-012	MS-DW-12	12/23/2024	ROOM D2	<1.00	01/03/2025	
24-12-05327-013	MS-DW-13	12/23/2024	ROOM C6	<1.00	01/03/2025	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-12-05327

Project/Test Address: 2743; Memorial School; 764 Grant Ave; Maywood, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-12-05327-014	MS-DW-14	12/23/2024	ROOM C4	<1.00	01/03/2025	
24-12-05327-015	MS-DW-15	12/23/2024	DETENTION	<1.00	01/03/2025	

Method: EPA 200.8

Analyst: Nicole Holloway

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion




Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907

EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com



24-12-05327

Due Date:

01/07/2025

(Tuesday)

AE

Company Name: LEW Environmental Services LLC

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908) 654-8068

Email: labresults@lewenvironmental.com

Fax: 908-654-8069

Project Name / Collection Address: Memorial School 764 East Ave

City/State/Zip: Maywood, NJ

Project #: 2743

Sampled By: Pablo Viera

License # (if Required):

Water Source: (Check One) Public ☒ Well ☐

Well Tag # (if Applicable):

☒ 5 Day Turnaround

☐ 3 Day Turnaround

☐ 2 Day Turnaround

☐ 1 Day Turnaround * Call Ahead

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE Temp at time of Receipt:
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	
1	MS-WC-2	HW outside A-10	12-23-24	10:00	AM/PM					
2	-BF-3	HW outside nurse			AM/PM					
3	-WC-3A				AM/PM					
4	-WC-4				AM/PM					
5	-S-5	Kitchen			AM/PM					
6	-WC-6	HW/Library			AM/PM					
7	-BF-8	Gym HW			AM/PM					
8	-BF-8A				AM/PM					
9	-WC-9				AM/PM					
10	DW-10	RM BS			AM/PM					

Released by: Pablo Viera Signature: Pablo Viera Date/Time: 12-23-24 7:30pm

Released by: PTHARRIS Signature: PTHARRIS Date/Time: 12-30-24 2:35pm

Client Name: Memorial SchoolPage 2 of 2Order # 2743

5327

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters		LAB USE
					Lead	Copper	Other	Field pH at time of Collection:	Temp. at time of Collection:	Temp at Time of Receipt:
11	MS-DW-11	Room DY	12-23-24	10:00 AM/PM						
12	-DW-12	" " O2		AM/PM						
13	-DW-13	" " C6		AM/PM						
14	-DW-14	" " C4		AM/PM						
15	-DW-15	Detection		AM/PM						
16				AM/PM						
17				AM/PM						
18				AM/PM						
19				AM/PM						
20				AM/PM						
21				AM/PM						
22				AM/PM						
23				AM/PM						
24				AM/PM						
25				AM/PM						
26				AM/PM						
27				AM/PM						
28				AM/PM						
29				AM/PM						
30				AM/PM						

KITCHENS 22 flowers 12:30-24 2:38 pm