ADDENDUM TO THE BID DOCUMENTS	Page: 1	Total Pages: 1
Addendum No: **# 1**	Date this Addendum Issued: **May 14, 2025**	
Issuing Office: Matanuska-Susitna Borough School District (MSBSD) Purchasing Department 690 Cope Industrial Way Palmer, Alaska 99645 Phone: (907) 861-5120 Facsimile: (907) 861-5184	Previous Addenda Issued: None _____ _____ _____ _____ _____ _____ _____ _____ _____ _____	
Return Acknowledgment To: **Issuing Department** Bid Title: **Auto Shop Wastewater Improvements** Bid No: **B25-18**	Date and Hour of Bid Due Date: **May 23, 2025 at 2:00 P.M.** As Advertised (Frontiersman): **April 23 and 25, 2025** As Advertised (ADN): **April 23 and 27, 2025**	

The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the contract documents. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence. The bidder must acknowledge receipt of this addendum in the space provided on Appendix #1. Failure to do so may subject the bidder to disqualification.

Questions:

1. Q: Do you have an engineer's estimate or cost range for this project?

   A: No, the MSBSD does not have an estimate or price range for this project.

2. Q: Is HDL providing all the engineering or does the contractor have to get a certified engineer?

   A: HDL is providing engineering services for this project. The contractor does not need to hire a separate engineer.

3. Q: What is the existing PVC pipe diameter?

   A: The current pipe diameter is 4".

END OF ADDENDUM #1

APPROVED BY: Signature on File	DATE: May 14, 2025