

ANALYTICAL REPORT

PREPARED FOR

Attn: Matt Burton
Margate City School District
8103 Winchester Avenue
Margate City, New Jersey 08402

Generated 5/12/2025 5:08:13 PM

JOB DESCRIPTION

Margate City Schools - Lead - 7804 Amherst Ave

JOB NUMBER

630-109285-1

Eurofins Environment Testing Philadelphia, LLC

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Environment Testing Philadelphia, LLC Project Manager.

Authorization



Generated
5/12/2025 5:08:13 PM

Authorized for release by
Erin Dougherty, Project Administrator
Erin.Dougherty@et.eurofinsus.com
(215)355-3900

Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Coliform MCLs

· Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If you report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

Warranties, Terms, and Conditions

· Analyses for Field Parameters are performed by Eurofins Philadelphia field staff. Locations and certifications are identified on the Chain of Custody as follows:

ERF = field staff performs tests under NJ State certification # 02015.

VL = field staff performs tests under NJ State certification # 06005.

WG = field staff performs tests under NJ State certification # PA001, PA State certification # 48-01334.

H = field staff performs tests under NJ NELAP certification # PA093, PA NELAP certification # 46-05499.

· Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.

· The report shall not be reproduced, except in full, without the written consent of the laboratory

· All samples are collected as "grab" samples unless otherwise identified.

· Reported results related only to the samples as tested. Eurofins Philadelphia is not responsible for sample integrity unless sampling has been performed by a member of our staff.

· Eurofins Philadelphia is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.

· Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.

· The following personnel or their deputies have approved the results of the tests performed by Eurofins Philadelphia : Nicki Smith (Environmental Chemistry) and Jacqueline Gartner (Water Microbiology).



Case Narrative

Client: Margate City School District
Project: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Job ID: 630-109285-1

Eurofins Environment Testing Philadelphia,

Job Narrative 630-109285-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 4/28/2025 2:56 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Sample Summary

Client: Margate City School District

Job ID: 630-109285-1

Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
630-109285-1	TWF01	Drinking Water	04/15/25 05:09	04/28/25 14:56
630-109285-2	THWS01	Drinking Water	04/15/25 05:12	04/28/25 14:56
630-109285-3	THWS02	Drinking Water	04/15/25 05:14	04/28/25 14:56
630-109285-4	TWF02	Drinking Water	04/15/25 05:16	04/28/25 14:56
630-109285-5	TPS01	Drinking Water	04/15/25 05:18	04/28/25 14:56
630-109285-6	THWS03	Drinking Water	04/15/25 05:20	04/28/25 14:56
630-109285-7	THWS04	Drinking Water	04/15/25 05:22	04/28/25 14:56
630-109285-8	THB01	Drinking Water	04/15/25 05:26	04/28/25 14:56
630-109285-9	THWS05	Drinking Water	04/15/25 05:30	04/28/25 14:56
630-109285-10	THWS06	Drinking Water	04/15/25 05:32	04/28/25 14:56
630-109285-11	TWC01	Drinking Water	04/15/25 05:35	04/28/25 14:56
630-109285-12	TPS02	Drinking Water	04/15/25 05:38	04/28/25 14:56
630-109285-13	TPS03	Drinking Water	04/15/25 05:41	04/28/25 14:56
630-109285-14	TKS01	Drinking Water	04/15/25 05:45	04/28/25 14:56
630-109285-15	THWS07	Drinking Water	04/15/25 05:47	04/28/25 14:56
630-109285-16	THWS08	Drinking Water	04/15/25 05:49	04/28/25 14:56
630-109285-17	TKS02	Drinking Water	04/15/25 05:53	04/28/25 14:56
630-109285-18	TKS03	Drinking Water	04/15/25 05:54	04/28/25 14:56
630-109285-19	TKS04	Drinking Water	04/15/25 05:55	04/28/25 14:56
630-109285-20	TKS05	Drinking Water	04/15/25 05:56	04/28/25 14:56
630-109285-21	TWC02	Drinking Water	04/15/25 05:59	04/28/25 14:56
630-109285-22	THWS09	Drinking Water	04/15/25 06:05	04/28/25 14:56
630-109285-23	THWS10	Drinking Water	04/15/25 06:06	04/28/25 14:56
630-109285-24	THWS11	Drinking Water	04/15/25 06:06	04/28/25 14:56
630-109285-25	THWS12	Drinking Water	04/15/25 06:07	04/28/25 14:56
630-109285-26	THWS13	Drinking Water	04/15/25 06:07	04/28/25 14:56
630-109285-27	THWS14	Drinking Water	04/15/25 06:08	04/28/25 14:56
630-109285-28	THWS15	Drinking Water	04/15/25 06:18	04/28/25 14:56
630-109285-29	THWS16	Drinking Water	04/15/25 06:19	04/28/25 14:56
630-109285-30	THWS17	Drinking Water	04/15/25 06:20	04/28/25 14:56
630-109285-31	THWS18	Drinking Water	04/15/25 06:21	04/28/25 14:56
630-109285-32	THWS19	Drinking Water	04/15/25 06:23	04/28/25 14:56
630-109285-33	THWS250	Drinking Water	04/15/25 06:24	04/28/25 14:56
630-109285-34	TWC03	Drinking Water	04/15/25 06:27	04/28/25 14:56
630-109285-35	TWC04	Drinking Water	04/15/25 06:28	04/28/25 14:56
630-109285-36	TPS05	Drinking Water	04/15/25 06:36	04/28/25 14:56
630-109285-37	TPS06	Drinking Water	04/15/25 06:41	04/28/25 14:56
630-109285-38	TPS07	Drinking Water	04/15/25 06:43	04/28/25 14:56
630-109285-39	TPS08	Drinking Water	04/15/25 06:44	04/28/25 14:56
630-109285-40	TPS09	Drinking Water	04/15/25 06:53	04/28/25 14:56
630-109285-41	TPS10	Drinking Water	04/15/25 06:54	04/28/25 14:56
630-109285-42	TPS11	Drinking Water	04/15/25 06:55	04/28/25 14:56
630-109285-43	TPS12	Drinking Water	04/15/25 06:55	04/28/25 14:56
630-109285-44	TPS13	Drinking Water	04/15/25 06:56	04/28/25 14:56
630-109285-45	TPS14	Drinking Water	04/16/25 06:22	04/28/25 14:56
630-109285-46	TPS15	Drinking Water	04/16/25 06:23	04/28/25 14:56
630-109285-47	TPS16	Drinking Water	04/16/25 06:25	04/28/25 14:56
630-109285-48	TPS17	Drinking Water	04/16/25 06:26	04/28/25 14:56
630-109285-49	TPS18	Drinking Water	04/16/25 06:27	04/28/25 14:56
630-109285-50	TPS19	Drinking Water	04/16/25 06:27	04/28/25 14:56
630-109285-51	TPS20	Drinking Water	04/16/25 06:28	04/28/25 14:56
630-109285-52	THB03	Drinking Water	04/16/25 06:30	04/28/25 14:56
630-109285-53	THWS21	Drinking Water	04/16/25 06:40	04/28/25 14:56
630-109285-54	THWS22	Drinking Water	04/16/25 06:41	04/28/25 14:56

Sample Summary

Client: Margate City School District

Job ID: 630-109285-1

Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
630-109285-55	THWS23	Drinking Water	04/16/25 06:42	04/28/25 14:56
630-109285-56	TCS01	Drinking Water	04/16/25 06:44	04/28/25 14:56
630-109285-57	THWS24	Drinking Water	04/16/25 06:47	04/28/25 14:56
630-109285-58	TCS02	Drinking Water	04/16/25 06:49	04/28/25 14:56
630-109285-59	TWC05	Drinking Water	04/16/25 06:51	04/28/25 14:56
630-109285-60	THB04	Drinking Water	04/16/25 06:55	04/28/25 14:56
630-109285-61	TSL01	Drinking Water	04/16/25 06:57	04/28/25 14:56
630-109285-62	THWS26	Drinking Water	04/16/25 06:58	04/28/25 14:56
630-109285-63	TKS06	Drinking Water	04/16/25 06:59	04/28/25 14:56
630-109285-64	TKS07	Drinking Water	04/16/25 06:59	04/28/25 14:56
630-109285-65	TKS08	Drinking Water	04/16/25 07:00	04/28/25 14:56
630-109285-66	TIMK	Drinking Water	04/16/25 07:01	04/28/25 14:56
630-109285-67	THWS27	Drinking Water	04/16/25 07:02	04/28/25 14:56
630-109285-68	TWC06	Drinking Water	04/16/25 07:06	04/28/25 14:56
630-109285-69	TWC07	Drinking Water	04/16/25 07:07	04/28/25 14:56
630-109285-70	TWC08	Drinking Water	04/16/25 07:08	04/28/25 14:56
630-109285-71	THWS28	Drinking Water	04/16/25 07:18	04/28/25 14:56
630-109285-72	THWS29	Drinking Water	04/16/25 07:20	04/28/25 14:56
630-109285-73	TWF04	Drinking Water	04/16/25 07:22	04/28/25 14:56
630-109285-74	TWF05	Drinking Water	04/16/25 07:24	04/28/25 14:56
630-109285-75	TCS02	Drinking Water	04/16/25 07:25	04/28/25 14:56
630-109285-76	THB02	Drinking Water	04/16/25 07:30	04/28/25 14:56

Client Sample Results

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TWF01

Date Collected: 04/15/25 05:09

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-1

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/09/25 19:09	1	SAM2

Client Sample ID: THWS01

Date Collected: 04/15/25 05:12

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-2

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/07/25 10:52	1	SAM2

Client Sample ID: THWS02

Date Collected: 04/15/25 05:14

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-3

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/07/25 10:56	1	SAM2

Client Sample ID: TWF02

Date Collected: 04/15/25 05:16

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-4

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/07/25 10:59	1	SAM2

Client Sample ID: TPS01

Date Collected: 04/15/25 05:18

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-5

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/07/25 11:02	1	SAM2

Client Sample ID: THWS03

Date Collected: 04/15/25 05:20

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-6

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.2		1.0	0.69	ug/L		05/07/25 11:05	1	SAM2

Client Sample ID: THWS04

Date Collected: 04/15/25 05:22

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-7

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/07/25 11:08	1	SAM2

Client Sample Results

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: THB01

Date Collected: 04/15/25 05:26

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-8

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	5.5		1.0	0.69	ug/L		05/09/25 18:56	1	SAM2

Client Sample ID: THWS05

Date Collected: 04/15/25 05:30

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-9

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.79	J	1.0	0.69	ug/L		05/09/25 19:12	1	SAM2

Client Sample ID: THWS06

Date Collected: 04/15/25 05:32

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-10

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/09/25 19:03	1	SAM2

Client Sample ID: TWC01

Date Collected: 04/15/25 05:35

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-11

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/09/25 19:06	1	SAM2

Client Sample ID: TPS02

Date Collected: 04/15/25 05:38

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-12

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/09/25 19:00	1	SAM2

Client Sample ID: TPS03

Date Collected: 04/15/25 05:41

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-13

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	4.0		1.0	0.69	ug/L		05/09/25 18:53	1	SAM2

Client Sample ID: TKS01

Date Collected: 04/15/25 05:45

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-14

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.89	J	1.0	0.69	ug/L		05/09/25 18:44	1	SAM2

Client Sample Results

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: THWS07

Date Collected: 04/15/25 05:47

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-15

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.6		1.0	0.69	ug/L		05/09/25 18:41	1	SAM2

Client Sample ID: THWS08

Date Collected: 04/15/25 05:49

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-16

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.90	J	1.0	0.69	ug/L		05/09/25 18:38	1	SAM2

Client Sample ID: TKS02

Date Collected: 04/15/25 05:53

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-17

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	2.8		1.0	0.69	ug/L		05/09/25 18:00	1	SAM2

Client Sample ID: TKS03

Date Collected: 04/15/25 05:54

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-18

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	2.2		1.0	0.69	ug/L		05/09/25 18:19	1	SAM2

Client Sample ID: TKS04

Date Collected: 04/15/25 05:55

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-19

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	2.0		1.0	0.69	ug/L		05/09/25 18:25	1	SAM2

Client Sample ID: TKS05

Date Collected: 04/15/25 05:56

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-20

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	2.4		1.0	0.69	ug/L		05/09/25 18:22	1	SAM2

Client Sample ID: TWC02

Date Collected: 04/15/25 05:59

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-21

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	2.6		1.0	0.69	ug/L		05/09/25 18:31	1	SAM2

Client Sample Results

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: THWS09

Date Collected: 04/15/25 06:05

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-22

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	110		1.0	0.67	ug/L		05/07/25 12:58	1	SAM2

Client Sample ID: THWS10

Date Collected: 04/15/25 06:06

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-23

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	170		1.0	0.67	ug/L		05/07/25 13:01	1	SAM2

Client Sample ID: THWS11

Date Collected: 04/15/25 06:06

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-24

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	49		1.0	0.69	ug/L		05/09/25 18:35	1	SAM2

Client Sample ID: THWS12

Date Collected: 04/15/25 06:07

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-25

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	130		1.0	0.69	ug/L		05/12/25 12:09	1	SAM2

Client Sample ID: THWS13

Date Collected: 04/15/25 06:07

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-26

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	140		1.0	0.69	ug/L		05/12/25 11:53	1	SAM2

Client Sample ID: THWS14

Date Collected: 04/15/25 06:08

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-27

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	79		1.0	0.69	ug/L		05/12/25 12:12	1	SAM2

Client Sample ID: THWS15

Date Collected: 04/15/25 06:18

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-28

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	22		1.0	0.69	ug/L		05/09/25 18:28	1	SAM2

Client Sample Results

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: THWS16

Date Collected: 04/15/25 06:19

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-29

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	35		1.0	0.69	ug/L		05/12/25 11:34	1	SAM2

Client Sample ID: THWS17

Date Collected: 04/15/25 06:20

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-30

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	49		1.0	0.69	ug/L		05/12/25 11:40	1	SAM2

Client Sample ID: THWS18

Date Collected: 04/15/25 06:21

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-31

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	31		1.0	0.69	ug/L		05/12/25 11:44	1	SAM2

Client Sample ID: THWS19

Date Collected: 04/15/25 06:23

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-32

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	2.4		1.0	0.69	ug/L		05/12/25 14:01	1	SAM2

Client Sample ID: THWS250

Date Collected: 04/15/25 06:24

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-33

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.8		1.0	0.69	ug/L		05/12/25 11:47	1	SAM2

Client Sample ID: TWC03

Date Collected: 04/15/25 06:27

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-34

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/12/25 11:50	1	SAM2

Client Sample ID: TWC04

Date Collected: 04/15/25 06:28

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-35

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	42		1.0	0.69	ug/L		05/12/25 10:54	1	SAM2

Client Sample Results

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TPS05

Date Collected: 04/15/25 06:36

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-36

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.3		1.0	0.69	ug/L		05/12/25 11:06	1	SAM2

Client Sample ID: TPS06

Date Collected: 04/15/25 06:41

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-37

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.79	J	1.0	0.69	ug/L		05/12/25 11:09	1	SAM2

Client Sample ID: TPS07

Date Collected: 04/15/25 06:43

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-38

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.92	J	1.0	0.69	ug/L		05/12/25 11:12	1	SAM2

Client Sample ID: TPS08

Date Collected: 04/15/25 06:44

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-39

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.1		1.0	0.69	ug/L		05/12/25 11:15	1	SAM2

Client Sample ID: TPS09

Date Collected: 04/15/25 06:53

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-40

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/12/25 11:25	1	SAM2

Client Sample ID: TPS10

Date Collected: 04/15/25 06:54

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-41

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/12/25 11:28	1	SAM2

Client Sample ID: TPS11

Date Collected: 04/15/25 06:55

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-42

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.91	J	1.0	0.69	ug/L		05/12/25 11:31	1	SAM2

Client Sample Results

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TPS12

Date Collected: 04/15/25 06:55

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-43

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.78	J	1.0	0.69	ug/L		05/07/25 14:31	1	SAM2

Client Sample ID: TPS13

Date Collected: 04/15/25 06:56

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-44

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.2		1.0	0.69	ug/L		05/07/25 14:06	1	SAM2

Client Sample ID: TPS14

Date Collected: 04/16/25 06:22

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-45

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.0		1.0	0.69	ug/L		05/07/25 14:02	1	SAM2

Client Sample ID: TPS15

Date Collected: 04/16/25 06:23

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-46

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.83	J	1.0	0.69	ug/L		05/07/25 14:09	1	SAM2

Client Sample ID: TPS16

Date Collected: 04/16/25 06:25

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-47

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.1		1.0	0.69	ug/L		05/07/25 14:12	1	SAM2

Client Sample ID: TPS17

Date Collected: 04/16/25 06:26

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-48

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.1		1.0	0.69	ug/L		05/07/25 14:15	1	SAM2

Client Sample ID: TPS18

Date Collected: 04/16/25 06:27

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-49

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.3		1.0	0.69	ug/L		05/07/25 14:18	1	SAM2

Client Sample Results

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TPS19

Date Collected: 04/16/25 06:27

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-50

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/07/25 14:27	1	SAM2

Client Sample ID: TPS20

Date Collected: 04/16/25 06:28

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-51

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.4		1.0	0.69	ug/L		05/07/25 13:19	1	SAM2

Client Sample ID: THB03

Date Collected: 04/16/25 06:30

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-52

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.85	J	1.0	0.69	ug/L		05/07/25 13:31	1	SAM2

Client Sample ID: THWS21

Date Collected: 04/16/25 06:40

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-53

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.0		1.0	0.69	ug/L		05/07/25 13:56	1	SAM2

Client Sample ID: THWS22

Date Collected: 04/16/25 06:41

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-54

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.1		1.0	0.69	ug/L		05/07/25 13:59	1	SAM2

Client Sample ID: THWS23

Date Collected: 04/16/25 06:42

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-55

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.2		1.0	0.69	ug/L		05/07/25 13:37	1	SAM2

Client Sample ID: TCS01

Date Collected: 04/16/25 06:44

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-56

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/07/25 13:34	1	SAM2

Client Sample Results

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: THWS24

Date Collected: 04/16/25 06:47

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-57

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.71	J	1.0	0.69	ug/L		05/07/25 13:41	1	SAM2

Client Sample ID: TCS02

Date Collected: 04/16/25 06:49

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-58

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.77	J	1.0	0.69	ug/L		05/07/25 13:50	1	SAM2

Client Sample ID: TWC05

Date Collected: 04/16/25 06:51

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-59

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	5.8		1.0	0.69	ug/L		05/07/25 13:53	1	SAM2

Client Sample ID: THB04

Date Collected: 04/16/25 06:55

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-60

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	16		1.0	0.69	ug/L		05/07/25 16:55	1	LHF4

Client Sample ID: TSL01

Date Collected: 04/16/25 06:57

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-61

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.3		1.0	0.69	ug/L		05/07/25 16:33	1	LHF4

Client Sample ID: THWS26

Date Collected: 04/16/25 06:58

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-62

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	4.1		1.0	0.69	ug/L		05/07/25 16:42	1	LHF4

Client Sample ID: TKS06

Date Collected: 04/16/25 06:59

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-63

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.4		1.0	0.69	ug/L		05/07/25 16:39	1	LHF4

Client Sample Results

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TKS07

Date Collected: 04/16/25 06:59

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-64

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.97	J	1.0	0.69	ug/L		05/07/25 16:36	1	LHF4

Client Sample ID: TKS08

Date Collected: 04/16/25 07:00

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-65

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.4		1.0	0.69	ug/L		05/07/25 16:52	1	LHF4

Client Sample ID: TIMK

Date Collected: 04/16/25 07:01

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-66

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/07/25 16:02	1	LHF4

Client Sample ID: THWS27

Date Collected: 04/16/25 07:02

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-67

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	2.8		1.0	0.69	ug/L		05/07/25 15:59	1	LHF4

Client Sample ID: TWC06

Date Collected: 04/16/25 07:06

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-68

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	3.4		1.0	0.69	ug/L		05/07/25 15:43	1	LHF4

Client Sample ID: TWC07

Date Collected: 04/16/25 07:07

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-69

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.9		1.0	0.69	ug/L		05/07/25 15:55	1	LHF4

Client Sample ID: TWC08

Date Collected: 04/16/25 07:08

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-70

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	10		1.0	0.69	ug/L		05/07/25 16:14	1	LHF4

Client Sample Results

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: THWS28

Date Collected: 04/16/25 07:18

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-71

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/07/25 16:17	1	LHF4

Client Sample ID: THWS29

Date Collected: 04/16/25 07:20

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-72

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		05/07/25 16:05	1	LHF4

Client Sample ID: TWF04

Date Collected: 04/16/25 07:22

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-73

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.0		1.0	0.69	ug/L		05/07/25 16:20	1	LHF4

Client Sample ID: TWF05

Date Collected: 04/16/25 07:24

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-74

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.78	J	1.0	0.69	ug/L		05/07/25 16:24	1	LHF4

Client Sample ID: TCS02

Date Collected: 04/16/25 07:25

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-75

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	3.4		1.0	0.69	ug/L		05/07/25 16:27	1	LHF4

Client Sample ID: THB02

Date Collected: 04/16/25 07:30

Date Received: 04/28/25 14:56

Lab Sample ID: 630-109285-76

Matrix: Drinking Water

Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.8		1.0	0.69	ug/L		05/07/25 16:30	1	LHF4

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TWF01

Lab Sample ID: 630-109285-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS01

Lab Sample ID: 630-109285-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS02

Lab Sample ID: 630-109285-3

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TWF02

Lab Sample ID: 630-109285-4

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS01

Lab Sample ID: 630-109285-5

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS03

Lab Sample ID: 630-109285-6

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.2		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: THWS04

Lab Sample ID: 630-109285-7

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THB01

Lab Sample ID: 630-109285-8

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	5.5		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS05

Lab Sample ID: 630-109285-9

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.79	J	ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS06

Lab Sample ID: 630-109285-10

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TWC01

Lab Sample ID: 630-109285-11

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS02

Lab Sample ID: 630-109285-12

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TPS03

Lab Sample ID: 630-109285-13

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	4.0		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TKS01

Lab Sample ID: 630-109285-14

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.89	J	ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS07

Lab Sample ID: 630-109285-15

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.6		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS08

Lab Sample ID: 630-109285-16

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.90	J	ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TKS02

Lab Sample ID: 630-109285-17

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	2.8		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TKS03

Lab Sample ID: 630-109285-18

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	2.2		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TKS04

Lab Sample ID: 630-109285-19

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	2.0		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TKS05

Lab Sample ID: 630-109285-20

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	2.4		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TWC02

Lab Sample ID: 630-109285-21

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	2.6		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS09

Lab Sample ID: 630-109285-22

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	110		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS10

Lab Sample ID: 630-109285-23

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	170		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS11

Lab Sample ID: 630-109285-24

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	49		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: THWS12

Lab Sample ID: 630-109285-25

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	130		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS13

Lab Sample ID: 630-109285-26

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	140		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS14

Lab Sample ID: 630-109285-27

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	79		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS15

Lab Sample ID: 630-109285-28

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	22		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS16

Lab Sample ID: 630-109285-29

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	35		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS17

Lab Sample ID: 630-109285-30

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	49		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: THWS18

Lab Sample ID: 630-109285-31

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	31		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS19

Lab Sample ID: 630-109285-32

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	2.4		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS250

Lab Sample ID: 630-109285-33

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.8		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TWC03

Lab Sample ID: 630-109285-34

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TWC04

Lab Sample ID: 630-109285-35

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	42		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS05

Lab Sample ID: 630-109285-36

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.3		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TPS06

Lab Sample ID: 630-109285-37

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.79	J	ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS07

Lab Sample ID: 630-109285-38

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.92	J	ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS08

Lab Sample ID: 630-109285-39

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.1		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS09

Lab Sample ID: 630-109285-40

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS10

Lab Sample ID: 630-109285-41

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS11

Lab Sample ID: 630-109285-42

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.91	J	ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TPS12

Lab Sample ID: 630-109285-43

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.78	J	ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS13

Lab Sample ID: 630-109285-44

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	1.2		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS14

Lab Sample ID: 630-109285-45

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	1.0		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS15

Lab Sample ID: 630-109285-46

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.83	J	ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS16

Lab Sample ID: 630-109285-47

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	1.1		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS17

Lab Sample ID: 630-109285-48

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	1.1		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TPS18

Lab Sample ID: 630-109285-49

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.3		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS19

Lab Sample ID: 630-109285-50

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TPS20

Lab Sample ID: 630-109285-51

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.4		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THB03

Lab Sample ID: 630-109285-52

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.85	J	ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS21

Lab Sample ID: 630-109285-53

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.0		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS22

Lab Sample ID: 630-109285-54

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.1		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: THWS23

Lab Sample ID: 630-109285-55

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.2		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TCS01

Lab Sample ID: 630-109285-56

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS24

Lab Sample ID: 630-109285-57

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.71	J	ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TCS02

Lab Sample ID: 630-109285-58

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.77	J	ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TWC05

Lab Sample ID: 630-109285-59

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	5.8		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THB04

Lab Sample ID: 630-109285-60

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	16		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TSL01

Lab Sample ID: 630-109285-61

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.3		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS26

Lab Sample ID: 630-109285-62

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	4.1		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TKS06

Lab Sample ID: 630-109285-63

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.4		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TKS07

Lab Sample ID: 630-109285-64

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.97	J	ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TKS08

Lab Sample ID: 630-109285-65

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.4		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TIMK

Lab Sample ID: 630-109285-66

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: THWS27

Lab Sample ID: 630-109285-67

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	2.8		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TWC06

Lab Sample ID: 630-109285-68

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	3.4		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TWC07

Lab Sample ID: 630-109285-69

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.9		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TWC08

Lab Sample ID: 630-109285-70

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	10		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS28

Lab Sample ID: 630-109285-71

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THWS29

Lab Sample ID: 630-109285-72

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Action Limit Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Client Sample ID: TWF04

Lab Sample ID: 630-109285-73

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.0		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TWF05

Lab Sample ID: 630-109285-74

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.78	J	ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: TCS02

Lab Sample ID: 630-109285-75

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	3.4		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Client Sample ID: THB02

Lab Sample ID: 630-109285-76

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.8		ug/L	15.4	1.0	200.8 Rev 5.4	Total/NA

Accreditation/Certification and Definitions Summary

Client: Margate City School District
Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Job ID: 630-109285-1

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
New Jersey	NELAP	PA011	06-30-25

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
□	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
MRL	Method Reporting Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
SDL	Sample Detection Limit
SDL	Sample Detection Limit
SDL	Sample Detection Limit
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Method Summary

Client: Margate City School District

Job ID: 630-109285-1

Project/Site: Margate City Schools - Lead - 7804 Amherst Ave

Method	Method Description	Protocol	Laboratory
200.8 Rev 5.4	Metals (ICP/MS)	EPA	ELLE
200.8	Preparation, Total Metals	EPA	ELLE
Non-Digest Prep	Preparation, Non-Digested Aqueous Metals	EPA	ELLE

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300



Environment Testing
Philadelphia

CHAIN OF CUSTODY

Page 7 of 19

MATRIX CODES

795 Horsham Road
Horsham, PA 19044

Phone : 215-355-3900

Bill to/Report to (if different)



630-109285 Chain of Custody

Sampling Site Address (if different) Include State

Client/Acct. No.

Address

8103 Winchester Ave
Winchester, NJ

City/State/Zip

08402

Phone/Fax

609 822-1447 / 822-3399

Client Contact:

Math Burton

P.O. No.

24-055

PWSID#:

Quote#

63007311

e-mail:

mburton@margateschools.org

NaOH/Znacetate

HNO₃

H₂SO₄

NaOH

Unpreserved

HCl

NH₄Cl

MeOH

DI Water

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

OIL: OIL

SOL: NON SOIL SOLID

MI: MISCELLANEOUS

X: OTHER

PROJECT

Collection

Number of Containers

FIELD ID

Date

Military Time

Matrix Code

Total

H₂SO₄

HCl

Vials

HNO₃

NaOH

ZnAc

UNPRE

BACT

ANALYSIS REQUESTED

Field pH, Temp (°C),
DO, C12, Cond, etc.

TWFO1

4/15/25 0509

DW

Lead

THWSO1

4/15/25 0512

DW

Lead

THWSO2

4/15/25 0514

DW

Lead

TWFO2

4/15/25 0516

DW

Lead

TPSO1

4/15/25 0518

DW

Lead

THWSO3

4/15/25 0520

DW

Lead

THWSO4

4/15/25 0522

DW

Lead

THBSO1

4/15/25 0526

DW

Lead

THWSO5

4/15/25 0530

DW

Lead

THWSO6

4/15/25 0532

DW

Lead

SAMPLED BY: (Name/Company)

Margate School

TAT: ☐ STANDARD (10 DAY)

or DUE DATE ____/____/____

Report Format: ☐ Standard ☐ NJ-RDD ☐ SRP-RDD

☐ Standard + QC ☐ Forms ☐ EDD

Field Parameters Analyzed By:

Initials

Date/Time:

Please call for pricing and availability for rush (<10 day) turnaround and for all but standard reporting format.

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK, IE, 8AM IS 0800, 4 PM IS 1600)

RELINQUISHED BY SAMPLER

DATE

TIME

RECEIVED BY

DATE

TIME

DELIVERY: ☐ EETP COURIER ☐ CLIENT

Custody Seal Number

RELINQUISHED BY

DATE

TIME

RECEIVED BY

DATE

TIME

Rec'd Temp.: _____ Initials: _____ Ice Y / N Location: _____

RELINQUISHED BY

DATE

TIME

RECEIVED BY

DATE

TIME

COMMENTS:

RELINQUISHED BY

DATE

TIME

RECEIVED BY

DATE

TIME

RELINQUISHED BY

DATE

TIME

RECEIVED BY

DATE

TIME

Hazardous: yes / no

5/12/2025



Environment Testing
Philadelphia

CHAIN OF CUSTODY

Page 8 of 14

Lab LIMS No:

MATRIX CODES

795 Horsham Road
Horsham, PA 19044

Phone : 215-355-3900

Client/Acct. No.

Address

8103 Winchester Ave
Margate, NJ

7804 Amherst Ave
Margate, NJ 08402

City/State/Zip

08402

Phone/Fax

609 822-1447 / 822-3399

Client Contact:

Matt Burton

Bill to/Report to (if different)

Sampling Site Address (if different) Include State

P.O. No.

24-055

PWSID#:

Quote#

6300 7311

e-mail:

mburton@margateschools.org

LAB USE ONLY:

_____ Ascorbic/HCL Vials # _____ HCL Vials

_____ Na₂S₂O₃ _____

_____ NaOH/Znacetate _____

_____ HNO₃ _____

_____ H₂SO₄ _____

_____ NaOH _____

_____ Unpreserved

_____ HCL # _____ NH₄Cl # _____ MeOH

_____ DI Water

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

CIL: OIL

SOL: NON SOIL SOLID

MI: MISCELLANEOUS

X: OTHER

ANALYSIS REQUESTED

Field pH, Temp (°C),
DO, C12, Cond, etc.

LAB USE ONLY

FIELD ID

TWC01

TPS02

TPS03

TKS01

THWS07

THWS08

TKS02

TKS03

TKS04

TKS05

Collection

Date

Military
Time

G
R
A
B

C
O
M
P

Matrix
Code

Number of Containers

Total

H
2
S
O
4

H
C
l

V
i
a
l
s

H
N
O
3

N
a
O
H

Z
n
A
c

U
N
P
R
E

B
A
C
T

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

SAMPLED BY: (Name/Company)

Margate School

TAT: ☐ STANDARD (10 DAY)

or DUE DATE ____/____/____

Report Format: ☐ Standard ☐ NJ-RDD ☐ SRP-RDD

☐ Standard + QC ☐ Forms ☐ EDD

Field Parameters Analyzed By:

Initials

Date/Time:

Please call for pricing and availability for rush (<10 day) turnaround and for all but standard reporting format.

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK, IE, 8AM IS 0800, 4 PM IS 1600)

RELINQUISHED BY/SAMPLER 1. <i>Melanie S...</i>	DATE 4/28/25	TIME 14:19	RECEIVED BY 1. <i>John Chaw</i>	DATE 4/28/25	TIME 14:19	DELIVERY: ☐ EETP COURIER ☐ CLIENT ☐ UPS ☐ FEDEX ☐ OTHER _____	Custody Seal Number
RELINQUISHED BY 2.	DATE	TIME	RECEIVED BY 2.	DATE	TIME	Rec'd Temp.: _____ Initials: _____ Ice Y / N Location: _____ COMMENTS: Hazardous: yes / no	
RELINQUISHED BY 3.	DATE	TIME	RECEIVED BY 3.	DATE	TIME		
RELINQUISHED BY 4.	DATE	TIME	RECEIVED BY 4.	DATE	TIME		
RELINQUISHED BY 5.	DATE	TIME	RECEIVED BY 5.	DATE	TIME		



Environment Testing
Philadelphia

CHAIN OF CUSTODY

Page 9 of 14

Lab LIMS No:

MATRIX CODES

795 Horsham Road
Horsham, PA 19044

Phone : 215-355-3900

Client/Acct. No.

Address

City/State/Zip

Phone/Fax

Client Contact:

Bill to/Report to (if different)

Sampling Site Address (if different) Include State

P.O. No.

PWSID#:

Quote#

e-mail:

LAB USE ONLY:

____ Ascorbic/HCL Vials # ____ HCL Vials

____ Na₂S₂O₃

____ NaOH/Znacetate

____ HNO₃

____ H₂SO₄

____ NaOH

____ Unpreserved

____ HCL # ____ NH₄Cl # ____ MeOH

____ DI Water

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

OIL: OIL

SOL: NON SOIL SOLID

MI: MISCELLANEOUS

X: OTHER

ANALYSIS REQUESTED

Field pH, Temp (°C),
DO, C12, Cond, etc.

LAB USE ONLY

FIELD ID

Collection

Date

Military
Time

G
R
A
B

C
O
M
P

Matrix
Code

Total

H
2
S
O
4

H
C
l

V
i
a
l
s

H
N
O
3

N
a
O
H

Z
n
A
c

U
N
P
R
E

B
A
C
T

Number of Containers

SAMPLED BY: (Name/Company)

TAT : ☐ STANDARD (10 DAY)

or DUE DATE ____/____/____

Report Format: ☐ Standard ☐ NJ-RDD ☐ SRP-RDD

☐ Standard + QC ☐ Forms ☐ EDD

Field Parameters Analyzed By:

Initials

Date/Time:

Please call for pricing and availability for rush (<10 day) turnaround and for all but standard reporting format.

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK, IE, 8AM IS 0800, 4 PM IS 1600)

RELINQUISHED BY SAMPLER

1. *Melvin S. Clark*

DATE

4/15/25

TIME

11:20

RECEIVED BY

1. *John Graser*

DATE

4/15/25

TIME

14:20

DELIVERY: ☐ EETP COURIER ☐ CLIENT
☐ UPS ☐ FEDEX ☐ OTHER

Custody Seal Number

RELINQUISHED BY

2.

DATE

TIME

RECEIVED BY

2.

DATE

TIME

Rec'd Temp.: _____ Initials: _____ Ice Y / N Location: _____

RELINQUISHED BY

3.

DATE

TIME

RECEIVED BY

3.

DATE

TIME

COMMENTS:

RELINQUISHED BY

4.

DATE

TIME

RECEIVED BY

4.

DATE

TIME

RELINQUISHED BY

5.

DATE

TIME

RECEIVED BY

5.

DATE

TIME

Hazardous: yes / no

5/12/2025



Environment Testing
Philadelphia

CHAIN OF CUSTODY

Page 10 of 14

Lab LIMS No:

MATRIX CODES

795 Horsham Road
Horsham, PA 19044

Phone : 215-355-3900

Client/Acct. No.

Address

City/State/Zip

Phone/Fax

Client Contact:

Bill to/Report to (if different)

Sampling Site Address (if different) Include State

P.O. No.

PWSID#:

Quote#

e-mail:

LAB USE ONLY:

____ Ascorbic/HCL Vials # ____ HCL Vials

____ Na₂S₂O₃ ____

____ NaOH/Znacetate ____

____ HNO₃ ____

____ H₂SO₄ ____

____ NaOH ____

____ Unpreserved

____ HCL # ____ NH₄Cl # ____ MeOH

____ DI Water

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

CIL: OIL

SOL: NON SOIL SOLID

MI: MISCELLANEOUS

X: OTHER

ANALYSIS REQUESTED

Field pH, Temp (°C),
DO, C12, Cond, etc.

LAB USE ONLY

PROJECT

Collection

Number of Containers

FIELD ID

Date

Military Time

G
R
A
B

C
O
M
P

Matrix Code

Total

H
2
S
O
4

H
C
l

V
i
a
l
s

H
N
O
3

N
a
O
H

Z
n
A
c

U
N
P
R
E

B
A
C
T

THWS18

4/15/25 0621

DW

THWS19

4/15/25 0623

DW

THWS20

4/15/25 0624

DW

TWCO3

4/15/25 0627

DW

TWCO4

4/15/25 0628

DW

TPSO5

4/15/25 0636

DW

TPSO6

4/15/25 0641

DW

TPSO7

4/15/25 0643

DW

TPSO8

4/15/25 0644

DW

TPSO9

4/15/25 0653

DW

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

SAMPLED BY: (Name/Company)

TAT : ☐ STANDARD (10 DAY)

or DUE DATE ____/____/____

Report Format: ☐ Standard ☐ NJ-RDD ☐ SRP-RDD

☐ Standard + QC ☐ Forms ☐ EDD

Field Parameters Analyzed By:

Initials

Date/Time:

Please call for pricing and availability for rush (<10 day) turnaround and for all but standard reporting format.

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK, IE, 8AM IS 0800, 4 PM IS 1600)

RELINQUISHED BY SAMPLER

DATE

TIME

RECEIVED BY

DATE

TIME

DELIVERY: ☐ EETP COURIER ☐ CLIENT

Custody Seal Number

1. *Melvin Clark*

4/28/25

14:00

1. *Jake Glow*

4/28/25

14:50

☐ UPS ☐ FEDEX ☐ OTHER

RELINQUISHED BY

DATE

TIME

RECEIVED BY

DATE

TIME

Rec'd Temp.: _____ Initials: _____ Ice Y / N Location: _____

2.

DATE

TIME

RECEIVED BY

DATE

TIME

COMMENTS:

RELINQUISHED BY

DATE

TIME

RECEIVED BY

DATE

TIME

3.

DATE

TIME

RECEIVED BY

DATE

TIME

RELINQUISHED BY

DATE

TIME

RECEIVED BY

DATE

TIME

4.

DATE

TIME

RECEIVED BY

DATE

TIME

RELINQUISHED BY

DATE

TIME

RECEIVED BY

DATE

TIME

5.



Environment Testing
Philadelphia

CHAIN OF CUSTODY

Page 11 of 14

Lab LIMS No:

MATRIX CODES

795 Horsham Road
Horsham, PA 19044

Phone : 215-355-3900

Client/Acct. No.

Address

City/State/Zip

Phone/Fax

Client Contact:

Bill to/Report to (if different)

Sampling Site Address (if different) Include State

P.O. No.

PWSID#:

Quote#

e-mail:

LAB USE ONLY:

____ Ascorbic/HCL Vials # ____ HCL Vials

____ Na₂S₂O₃ ____

____ NaOH/Znacetate ____

____ HNO₃ ____

____ H₂SO₄ ____

____ NaOH ____

____ Unpreserved

____ HCL # ____ NH₄Cl # ____ MeOH

____ DI Water

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

OIL: OIL

SOL: NON SOIL SOLID

MI: MISCELLANEOUS

X: OTHER

ANALYSIS REQUESTED

Field pH, Temp (°C),
DO, C12, Cond, etc.

LAB USE ONLY

FIELD ID

Collection

Date

Military
Time

G
R
A
B

C
O
M
P

Matrix
Code

Total

H
2
S
O
4

H
C
l

V
i
a
l
s

H
N
O
3

N
a
O
H

Z
n
A
c

U
N
P
R
E

B
A
C
T

Number of Containers

TPS10

4/15/25 0654

DW

TPS11

4/15/25 0655

DW

TPS12

4/15/25 0655

DW

TPS13

4/15/25 0656

DW

TPS14

4/16/25 0622

DW

TPS15

4/16/25 0623

DW

TPS16

4/16/25 0625

DW

TPS17

4/16/25 0626

DW

TPS18

4/16/25 0627

DW

TPS19

4/16/25 0627

DW

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

SAMPLED BY: (Name/Company)

TAT : ☐ STANDARD (10 DAY)

or DUE DATE ____/____/____

Report Format: ☐ Standard ☐ NJ-RDD ☐ SRP-RDD

☐ Standard + QC ☐ Forms ☐ EDD

Field Parameters Analyzed By:

Initials

Date/Time:

Please call for pricing and availability for rush (<10 day) turnaround and for all but standard reporting format.

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK, IE, 8AM IS 0800, 4 PM IS 1600)

RELINQUISHED BY SAMPLER

1. *Melvin Slatt*

DATE

4/13/25

TIME

11:21

RECEIVED BY

1. *John C. Raser*

DATE

4/28/25

TIME

14:21

DELIVERY: ☐ EETP COURIER ☐ CLIENT

☐ UPS ☐ FEDEX ☐ OTHER

Custody Seal Number

RELINQUISHED BY

2.

DATE

TIME

RECEIVED BY

2.

DATE

TIME

Rec'd Temp.: _____ Initials: _____ Ice Y / N Location: _____

RELINQUISHED BY

3.

DATE

TIME

RECEIVED BY

3.

DATE

TIME

COMMENTS:

RELINQUISHED BY

4.

DATE

TIME

RECEIVED BY

4.

DATE

TIME

RELINQUISHED BY

5.

DATE

TIME

RECEIVED BY

5.

DATE

TIME

Hazardous: yes / no

5/12/2025



Environment Testing
Philadelphia

795 Horsham Road
Horsham, PA 19044

Phone : 215-355-3900

Client/Acct. No.

Address

City/State/Zip

Phone/Fax

Client Contact:

8103
Winchester Ave

Margate, NJ 08402

609 822-1447 / 822-3399

Matt Burton

CHAIN OF CUSTODY

Page 12 of 14

Bill to/Report to (if different)

Sampling Site Address (if different) Include State

7804 Amherst Ave
Margate, NJ 08402

P.O. No.

PWSID#:

Quote#

e-mail:

24-055

63007311

mburton@margateschools.org

Lab LIMS No:

LAB USE ONLY:

____ Ascorbic/HCL Vials # ____ HCL Vials

____ Na2S2O3

____ NaOH/Znacetate

____ HNO3

____ H2SO4

____ NaOH

____ Unpreserved

____ HCL # ____ NH4Cl # ____ MeOH

____ DI Water

MATRIX CODES

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

OIL: OIL

SOL: NON SOIL SOLID

MI: MISCELLANEOUS

X: OTHER

ANALYSIS REQUESTED

Field pH, Temp (°C),
DO, C12, Cond, etc.

LAB USE ONLY

PROJECT

Collection

Number of Containers

FIELD ID

Date

Military Time

G
R
A
B

C
O
M
P

Matrix Code

Total

H
2
S
O
4

H
C
l

V
i
a
l
s

H
N
O
3

N
a
O
H

Z
n
A
c

U
N
P
R
E

B
A
C
T

TPS20

4/16/25 0628

DW

THB03

4/16/25 0630

DW

THWS21

4/16/25 0640

DW

THWS22

4/16/25 0641

DW

THWS23

4/16/25 0642

DW

TCS01

4/16/25 0644

DW

THWS24

4/16/25 0647

DW

TCS02

4/16/25 0649

DW

TWC05

4/16/25 0651

DW

THB04

4/16/25 0655

DW

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

SAMPLED BY: (Name/Company)

TAT: ☐ STANDARD (10 DAY)

or DUE DATE ____ / ____ / ____

Report Format: ☐ Standard ☐ NJ-RDD ☐ SRP-RDD

☐ Standard + QC ☐ Forms ☐ EDD

Field Parameters Analyzed By:

Initials

Date/Time:

Please call for pricing and availability for rush (<10 day) turnaround and for all but standard reporting format.

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK, IE, 8AM IS 0800, 4 PM IS 1600)

RELINQUISHED BY SAMPLER	DATE	TIME	RECEIVED BY	DATE	TIME	DELIVERY: ☐ EETP COURIER ☐ CLIENT	Custody Seal Number
Melissa	4/28/25	14:20	Jake Glaser	4/28/25	14:21	☐ UPS ☐ FEDEX ☐ OTHER	
RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME	Rec'd Temp.: _____	Initials: _____
2.			2.			Ice Y / N	Location: _____
RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME	COMMENTS:	
3.			3.				
RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME		
4.			4.				
RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME		
5.			5.				



Environment Testing
Philadelphia

CHAIN OF CUSTODY

Page 13 of 14

Lab LIMS No:

MATRIX CODES

795 Horsham Road
Horsham, PA 19044

Phone : 215-355-3900

Client/Acct. No.

Address

City/State/Zip

Phone/Fax

Client Contact:

Bill to/Report to (if different)

Sampling Site Address (if different) Include State

P.O. No.

PWSID#:

Quote#

e-mail:

LAB USE ONLY:

____ Ascorbic/HCL Vials # ____ HCL Vials

____ Na2S2O3

____ NaOH/Znacetate

____ HNO3

____ H2SO4

____ NaOH

____ Unpreserved

____ HCL # ____ NH4Cl # ____ MeOH

____ DI Water

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

OIL: OIL

SOL: NON SOIL SOLID

MI: MISCELLANEOUS

X: OTHER

ANALYSIS REQUESTED

Field pH, Temp (°C),
DO, C12, Cond, etc.

LAB USE ONLY

FIELD ID

Collection

Date

Military
Time

G
R
A
B

C
O
M
P

Matrix
Code

Total

Number of Containers

H
2
S
O
4

H
C
l

V
i
a
l
s

H
N
O
3

N
a
O
H

Z
n
A
c

U
N
P
R
E

B
A
C
T

TSLO1

4/16/25 0657

DW

THWS26

4/16/25 0658

DW

TKS06

4/16/25 0659

DW

TKS07

4/16/25 0659

DW

TKS08

4/16/25 0700

DW

TIMK

4/16/25 0701

DW

THWS27

4/16/25 0702

DW

TWC06

4/16/25 0706

DW

TWC07

4/16/25 0707

DW

TWC08

4/16/25 0708

DW

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

Lead

SAMPLED BY: (Name/Company)

Margate School

TAT : ☐ STANDARD (10 DAY)

or DUE DATE ____/____/____

Report Format: ☐ Standard ☐ NJ-RDD ☐ SRP-RDD

☐ Standard + QC ☐ Forms ☐ EDD

Field Parameters Analyzed By:

Initials

Date/Time:

Please call for pricing and availability for rush (<10 day) turnaround and for all but standard reporting format.

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK, IE, 8AM IS 0800, 4 PM IS 1600)

RELINQUISHED BY SAMPLER	DATE	TIME	RECEIVED BY	DATE	TIME	DELIVERY: ☐ EETP COURIER ☐ CLIENT ☐ UPS ☐ FEDEX ☐ OTHER	Custody Seal Number
1. <i>[Signature]</i>	4/28/25	14:21	1. <i>[Signature]</i>	4/28/25	14:21		
RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME	Rec'd Temp.: _____ Initials: _____ Ice Y / N Location: _____	
2.			2.			COMMENTS:	
RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME		
3.			3.				
RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME		
4.			4.				
RELINQUISHED BY	DATE	TIME	RECEIVED BY	DATE	TIME		
5.			5.				



Environment Testing
Philadelphia

CHAIN OF CUSTODY

Page 14 of 14

Lab LIMS No:

MATRIX CODES

795 Horsham Road
Horsham, PA 19044

Phone : 215-355-3900

Client/Acct. No.

Address

City/State/Zip

Phone/Fax

Client Contact:

Bill to/Report to (if different)

Sampling Site Address (if different) Include State

P.O. No.

PWSID#:

Quote#

e-mail:

LAB USE ONLY:

____ Ascorbic/HCL Vials # ____ HCL Vials

____ Na₂S₂O₃ ____

____ NaOH/Znacetate ____

____ HNO₃ ____

____ H₂SO₄ ____

____ NaOH ____

____ Unpreserved

____ HCl # ____ NH₄Cl # ____ MeOH

____ DI Water

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

OIL: OIL

SOL: NON SOIL SOLID

MI: MISCELLANEOUS

X: OTHER

ANALYSIS REQUESTED

Field pH, Temp (°C),
DO, C12, Cond, etc.

LAB USE ONLY

PROJECT

Collection

Number of Containers

FIELD ID

Date

Military
Time

G
R
A
B

C
O
M
P

Matrix
Code

Total

H
2
S
O
4

H
C
l

V
i
a
l
s

H
N
O
3

N
a
O
H

Z
n
A
c

U
N
P
R
E

B
A
C
T

THWS28

4/16/25 0718

DW

THWS29

4/16/25 0720

DW

TNFO4

4/16/25 0722

DW

TNFO5

4/16/25 0724

DW

TCSO2

4/16/25 0725

DW

THBO2

4/16/25 0730

DW

Lead

Lead

Lead

Lead

Lead

Lead

SAMPLED BY: (Name/Company)

TAT : ☐ STANDARD (10 DAY)

or DUE DATE ____ / ____ / ____

Report Format: ☐ Standard ☐ NJ-RDD ☐ SRP-RDD

☐ Standard + QC ☐ Forms ☐ EDD

Field Parameters Analyzed By:

Initials

Date/Time:

Please call for pricing and availability for rush (<10 day) turnaround and for all but standard reporting format.

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK, IE, 8AM IS 0800, 4 PM IS 1600)

RELINQUISHED BY SAMPLER 1. <i>Melinda Clark</i>	DATE 4/28/25	TIME 14:22	RECEIVED BY 1. <i>John Clark</i>	DATE 4/28/25	TIME 14:22	DELIVERY: ☐ EETP COURIER ☐ CLIENT ☐ UPS ☐ FEDEX ☐ OTHER	Custody Seal Number
RELINQUISHED BY 2.	DATE	TIME	RECEIVED BY 2.	DATE	TIME	Rec'd Temp.: _____ Initials: _____ Ice Y / N Location: _____	
RELINQUISHED BY 3.	DATE	TIME	RECEIVED BY 3.	DATE	TIME	COMMENTS:	
RELINQUISHED BY 4.	DATE	TIME	RECEIVED BY 4.	DATE	TIME		
RELINQUISHED BY 5.	DATE	TIME	RECEIVED BY 5.	DATE	TIME		

Eurofins Environment Testing Philadelphia,

795 Horsham Road
Horsham, PA 19044-0962
Phone: 215-355-3900

Chain of Custody Record



Environment Testing

Client Information (Sub Contract Lab)		Sampler: N/A		Lab PM: Dougherty, Erin		Carrier Tracking No(s): N/A		COC No: 630-17563.1							
Client Contact: Shipping/Receiving		Phone: N/A		E-Mail: Erin.Dougherty@et.eurofinsus.com		State of Origin: New Jersey		Page: Page 1 of 9							
Company: Eurofins Lancaster Laboratories Environm				Accreditations Required (See note): NELAP - New Jersey				Job #: 630-109285-1							
Address: 2425 New Holland Pike, City: Lancaster State, Zip: PA, 17601		Due Date Requested: 5/12/2025 TAT Requested (days): N/A		Analysis Requested						Preservation Codes:					
Phone: 717-656-2300(Tel)		PO #: N/A		Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) 200.8/MTL_ND_Prep (MOD) Lead						Total Number of containers		Other: N/A			
Email: N/A		WO #: N/A													
Project Name: Margate City Schools - Lead - 7804 Amherst		Project #: 63008066													
Site: N/A		SSOW#: N/A													
Sample Identification - Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=water, S=solid, O=oil, BT=tissue, A=air)		Special Instructions/Note:					
						Preservation Code:									
TWF01 (630-109285-1)		4/15/25		05:09 Eastern		G		Drinking Water		1					
THWS01 (630-109285-2)		4/15/25		05:12 Eastern		G		Drinking Water		1					
THWS02 (630-109285-3)		4/15/25		05:14 Eastern		G		Drinking Water		1					
TWF02 (630-109285-4)		4/15/25		05:16 Eastern		G		Drinking Water		1					
TPS01 (630-109285-5)		4/15/25		05:18 Eastern		G		Drinking Water		1					
THWS03 (630-109285-6)		4/15/25		05:20 Eastern		G		Drinking Water		1					
THWS04 (630-109285-7)		4/15/25		05:22 Eastern		G		Drinking Water		1					
THB01 (630-109285-8)		4/15/25		05:26 Eastern		G		Drinking Water		1					
THWS05 (630-109285-9)		4/15/25		05:30 Eastern		G		Drinking Water		1					
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.															
Possible Hazard Identification						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)									
Unconfirmed						☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months									
Deliverable Requested: I, II, III, IV, Other (specify)						Primary Deliverable Rank: 1									
Special Instructions/QC Requirements:															
Empty Kit Relinquished by:				Date:		Time:		Method of Shipment:							
Relinquished by: Edwin Rhodes				Date/Time: 4/18/25 16:30		Company: EETP		Received by: K+J3 Courier							
Relinquished by:				Date/Time:		Company:		Date/Time: 4/18/25 16:30							
Relinquished by:				Date/Time:		Company:		Date/Time: 4/18/25 2200							
Custody Seals Intact: Yes No				Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks: R-17.6 C-17.6		R5.4-15.3 C5.4-15.3							

Eurofins Environment Testing Philadelphia,

795 Horsham Road

Horsham, PA 19044-0962

Phone: 215-355-3900

Chain of Custody Record



Environment Testing

Client Information (Sub Contract Lab)		Sampler: N/A		Lab PM: Dougherty, Erin		Carrier Tracking No(s): N/A		COC No: 630-17563.2			
Client Contact: Shipping/Receiving		Phone: N/A		E-Mail: Erin.Dougherty@et.eurofins.com		State of Origin: New Jersey		Page: Page 2 of 9			
Company: Eurofins Lancaster Laboratories Environm				Accreditations Required (See note): NELAP - New Jersey				Job #: 630-109285-1			
Address: 2425 New Holland Pike,		Due Date Requested: 5/12/2025		Analysis Requested						Preservation Codes:	
City: Lancaster		TAT Requested (days): N/A									
State, Zip: PA, 17601											
Phone: 717-656-2300(Tel)		PO #: N/A									
Email: N/A		WO #: N/A									
Project Name: Margate City Schools - Lead - 7804 Amherst		Project #: 63008066		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		200.B/MTL_ND_Prep (MOD) Lead		Total Number of containers	
Site: N/A		SSOW#: N/A								Other: N/A	
Sample Identification - Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=comp, G=grab)		Matrix (W=water, S=solid, O=soil, BT=Tissue, A=Air)		Special Instructions/Note:	
THWS06 (630-109285-10)		4/15/25		05:32 Eastern		G		Drinking Water		1	
TWC01 (630-109285-11)		4/15/25		05:35 Eastern		G		Drinking Water		1	
TPS02 (630-109285-12)		4/15/25		05:38 Eastern		G		Drinking Water		1	
TPS03 (630-109285-13)		4/15/25		05:41 Eastern		G		Drinking Water		1	
TKS01 (630-109285-14)		4/15/25		05:45 Eastern		G		Drinking Water		1	
THWS07 (630-109285-15)		4/15/25		05:47 Eastern		G		Drinking Water		1	
THWS08 (630-109285-16)		4/15/25		05:49 Eastern		G		Drinking Water		1	
TKS02 (630-109285-17)		4/15/25		05:53 Eastern		G		Drinking Water		1	
TKS03 (630-109285-18)		4/15/25		05:54 Eastern		G		Drinking Water		1	
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.											
Possible Hazard Identification						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)					
Unconfirmed						☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months					
Deliverable Requested: I, II, III, IV, Other (specify)						Primary Deliverable Rank: 1					
Empty Kit Relinquished by:						Special Instructions/QC Requirements					
Date:						Method of Shipment:					
Relinquished by: Edwin Rhodes						Received by: E+D Courier					
Date/Time: 4/18/25 16:20						Date/Time: 4/18/25 16:20					
Company: EETP						Company: E+D					
Relinquished by:						Received by:					
Date/Time:						Date/Time:					
Company:						Company:					
Relinquished by:						Received by:					
Date/Time:						Date/Time: 4/18/25 2200					
Company:						Company: E+D					
Custody Seals Intact: ☐ Yes ☐ No						Custody Seal No.: AR1					
						Cooler Temperature(s) °C and Other Remarks: 13.5-15.3 C, 5.2-15.3					

Eurofins Environment Testing Philadelphia,

795 Horsham Road

Horsham, PA 19044-0962

Phone: 215-355-3900

Chain of Custody Record



Environment Testing

Client Information (Sub Contract Lab)		Sampler: N/A		Lab PM: Dougherty, Erin		Carrier Tracking No(s): N/A		COC No: 630-17563.3			
Client Contact: Shipping/Receiving		Phone: N/A		E-Mail: Erin.Dougherty@et.eurofinsus.com		State of Origin: New Jersey		Page: Page 3 of 9			
Company: Eurofins Lancaster Laboratories Environm				Accreditations Required (See note): NELAP - New Jersey				Job #: 630-109285-1			
Address: 2425 New Holland Pike,		Due Date Requested: 5/12/2025		Analysis Requested						Preservation Codes:	
City: Lancaster		TAT Requested (days): N/A									
State, Zip: PA, 17601											
Phone: 717-656-2300(Tel)		PO #: N/A									
Email: N/A		WO #: N/A									
Project Name: Margate City Schools - Lead - 7804 Amherst		Project #: 63008066		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		200.8/MTL_ND_Prep (MOD) Lead		Total Number of Containers	
Site: N/A		SSOW#: N/A								Other: N/A	
Sample Identification - Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)		Special Instructions/Note:	
TKS04 (630-109285-19)		4/15/25		05:55 Eastern		G		Drinking Water		1	
TKS05 (630-109285-20)		4/15/25		05:56 Eastern		G		Drinking Water		1	
TWC02 (630-109285-21)		4/15/25		05:59 Eastern		G		Drinking Water		1	
THWS09 (630-109285-22)		4/15/25		06:05 Eastern		G		Drinking Water		1	
THWS10 (630-109285-23)		4/15/25		06:06 Eastern		G		Drinking Water		1	
THWS11 (630-109285-24)		4/15/25		06:06 Eastern		G		Drinking Water		1	
THWS12 (630-109285-25)		4/15/25		06:07 Eastern		G		Drinking Water		1	
THWS13 (630-109285-26)		4/15/25		06:07 Eastern		G		Drinking Water		1	
THWS14 (630-109285-27)		4/15/25		06:08 Eastern		G		Drinking Water		1	
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.											
Possible Hazard Identification						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)					
Unconfirmed						☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months					
Deliverable Requested: I, II, III, IV, Other (specify)						Primary Deliverable Rank: 1					
Empty Kit Relinquished by:						Special Instructions/QC Requirements:					
Relinquished by: Edwin Rhodes				Date/Time: 4/15/25 16:30		Company: EETP		Received by: ETB Carrier		Date/Time: 4/15/25 16:30	
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: ☐ Yes ☐ No				Custody Seal No.: ARI		Cooler Temperature(s) °C and Other Remarks: R-S 4-15.3 C-S 2-15.3					

Eurofins Environment Testing Philadelphia,

795 Horsham Road

Horsham, PA 19044-0962

Phone: 215-355-3900

Chain of Custody Record



Environment Testing

Client Information (Sub Contract Lab)		Sampler: N/A		Lab PM: Dougherty, Erin		Carrier Tracking No(s): N/A		COC No: 630-17563.4			
Client Contact: Shipping/Receiving		Phone: N/A		E-Mail: Erin.Dougherty@et.eurofinsus.com		State of Origin: New Jersey		Page: Page 4 of 9			
Company: Eurofins Lancaster Laboratories Environm				Accreditations Required (See note): NELAP - New Jersey				Job #: 630-109285-1			
Address: 2425 New Holland Pike,		Due Date Requested: 5/12/2025		Analysis Requested						Preservation Codes:	
City: Lancaster		TAT Requested (days): N/A									
State, Zip: PA, 17601											
Phone: 717-656-2300(Tel)		PO #: N/A									
Email: N/A		WO #: N/A									
Project Name: Margate City Schools - Lead - 7804 Amherst		Project #: 63008066		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		200.8/MTL_ND_Prep (MOD) Lead		Total Number of containers	
Site: N/A		SSOW#: N/A								Other: N/A	
Sample Identification - Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=comp, G=grab)		Matrix (Water, Sealed, On-site/oil, BT=Issue, A=Air)		Special Instructions/Note:	
THWS15 (630-109285-28)		4/15/25		06:18 Eastern		G		Drinking Water		1	
THWS16 (630-109285-29)		4/15/25		06:19 Eastern		G		Drinking Water		1	
THWS17 (630-109285-30)		4/15/25		06:20 Eastern		G		Drinking Water		1	
THWS18 (630-109285-31)		4/15/25		06:21 Eastern		G		Drinking Water		1	
THWS19 (630-109285-32)		4/15/25		06:23 Eastern		G		Drinking Water		1	
THWS250 (630-109285-33)		4/15/25		06:24 Eastern		G		Drinking Water		1	
TWC03 (630-109285-34)		4/15/25		06:27 Eastern		G		Drinking Water		1	
TWC04 (630-109285-35)		4/15/25		06:28 Eastern		G		Drinking Water		1	
TPS05 (630-109285-36)		4/15/25		06:36 Eastern		G		Drinking Water		1	
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.											
Possible Hazard Identification						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)					
Unconfirmed						☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months					
Deliverable Requested: I, II, III, IV, Other (specify)						Special Instructions/QC Requirements:					
Primary Deliverable Rank: 1											
Empty Kit Relinquished by:				Date:		Time:		Method of Shipment:			
Relinquished by: Edwin Rhodes				Date/Time: 4/18/25 16:30		Company: EETP		Received by: KTB Courier		Date/Time: 4/18/25 16:30	
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:				Date/Time:		Company:		Received by: [Signature]		Date/Time: 4/12/25 2200	
Custody Seals Intact: Δ Yes Δ No				Custody Seal No.: AR 7		Cooler Temperature(s) °C and Other Remarks: R: 3.4-15.3 C: 5-215.3					

Eurofins Environment Testing Philadelphia,

795 Horsham Road
Horsham, PA 19044-0962
Phone: 215-355-3900

Chain of Custody Record



Environment Testing

Client Information (Sub Contract Lab)		Sampler: N/A		Lab PM: Dougherty, Erin		Carrier Tracking No(s): N/A		COC No: 630-17563.5			
Client Contact: Shipping/Receiving		Phone: N/A		E-Mail: Erin.Dougherty@et.eurofinsus.com		State of Origin: New Jersey		Page: Page 5 of 9			
Company Eurofins Lancaster Laboratories Environm				Accreditations Required (See note): NELAP - New Jersey				Job #: 630-109285-1			
Address: 2425 New Holland Pike,		Due Date Requested: 5/12/2025		Analysis Requested						Preservation Codes: -	
City: Lancaster		TAT Requested (days): N/A									
State, Zip: PA, 17601											
Phone: 717-656-2300(Tel)		PO #: N/A									
Email: N/A		WO #: N/A									
Project Name: Margate City Schools - Lead - 7804 Amherst		Project #: 63008066		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		200.8/MTL_ND_Prep (MOD) Lead		Total Number of Containers	
Site: N/A		SSOW#: N/A								Other: N/A	
Sample Identification - Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=water, S=solid, O=oil, BT=tissue, A=air)		Special Instructions/Note:	
TPS06 (630-109285-37)		4/15/25		06:41 Eastern		G		Drinking Water		1	
TPS07 (630-109285-38)		4/15/25		06:43 Eastern		G		Drinking Water		1	
TPS08 (630-109285-39)		4/15/25		06:44 Eastern		G		Drinking Water		1	
TPS09 (630-109285-40)		4/15/25		06:53 Eastern		G		Drinking Water		1	
TPS10 (630-109285-41)		4/15/25		06:54 Eastern		G		Drinking Water		1	
TPS11 (630-109285-42)		4/15/25		06:55 Eastern		G		Drinking Water		1	
TPS12 (630-109285-43)		4/15/25		06:55 Eastern		G		Drinking Water		1	
TPS13 (630-109285-44)		4/15/25		06:56 Eastern		G		Drinking Water		1	
TPS14 (630-109285-45)		4/16/25		06:22 Eastern		G		Drinking Water		1	
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.											
Possible Hazard Identification						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)					
Unconfirmed						☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months					
Deliverable Requested: I, II, III, IV, Other (specify)						Primary Deliverable Rank: 1					
Special Instructions/QC Requirements:											
Empty Kit Relinquished by:				Date:		Time:		Method of Shipment:			
Relinquished by: Edwin Rhodes				Date/Time: 4/18/25 16:20		Company: EETP		Received by: KTB Carrier		Date/Time: 4/18/25 16:20	
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: Δ Yes Δ No				Custody Seal No.: AR1		Cooler Temperature(s) °C and Other Remarks: R: 5.4-15.3 C: 5.2-15.3					

Eurofins Environment Testing Philadelphia,

795 Horsham Road
Horsham, PA 19044-0962
Phone: 215-355-3900

Chain of Custody Record



Environment Testing

Client Information (Sub Contract Lab)		Sampler: N/A		Lab PM: Dougherty, Erin		Carrier Tracking No(s): N/A		COC No: 630-17563.6			
Client Contact: Shipping/Receiving		Phone: N/A		E-Mail: Erin.Dougherty@et.eurofinsus.com		State of Origin: New Jersey		Page: Page 6 of 9			
Company: Eurofins Lancaster Laboratories Environm				Accreditations Required (See note): NELAP - New Jersey				Job #: 630-109285-1			
Address: 2425 New Holland Pike,		Due Date Requested: 5/12/2025		Analysis Requested						Preservation Codes:	
City: Lancaster		TAT Requested (days): N/A									
State, Zip: PA, 17601											
Phone: 717-656-2300(Tel)		PO #: N/A									
Email: N/A		WO #: N/A									
Project Name: Margate City Schools - Lead - 7804 Amherst		Project #: 63008066		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		200.8/MTL_ND_Prep (MOD) Lead		Total Number of containers	
Site: N/A		SSOW#: N/A								Other: N/A	
Sample Identification - Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)		Special Instructions/Note:	
TPS15 (630-109285-46)		4/16/25		06:23 Eastern		G		Drinking Water		1	
TPS16 (630-109285-47)		4/16/25		06:25 Eastern		G		Drinking Water		1	
TPS17 (630-109285-48)		4/16/25		06:26 Eastern		G		Drinking Water		1	
TPS18 (630-109285-49)		4/16/25		06:27 Eastern		G		Drinking Water		1	
TPS19 (630-109285-50)		4/16/25		06:27 Eastern		G		Drinking Water		1	
TPS20 (630-109285-51)		4/16/25		06:28 Eastern		G		Drinking Water		1	
THB03 (630-109285-52)		4/16/25		06:30 Eastern		G		Drinking Water		1	
THWS21 (630-109285-53)		4/16/25		06:40 Eastern		G		Drinking Water		1	
THWS22 (630-109285-54)		4/16/25		06:41 Eastern		G		Drinking Water		1	
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.											
Possible Hazard Identification						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)					
Unconfirmed						☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months					
Deliverable Requested: I, II, III, IV, Other (specify)						Primary Deliverable Rank: 1					
Special Instructions/QC Requirements:											
Empty Kit Relinquished by:				Date:		Time:		Method of Shipment:			
Relinquished by: Edwin Rhodes				Date/Time: 4/18/25 16:20		Company: EETP		Received by: ETS Courier			
Relinquished by:				Date/Time:		Company:		Date/Time: 4/18/25 16:20			
Relinquished by:				Date/Time:		Company:		Date/Time: 4/12/25 22:00			
Custody Seals Intact: ☐ Yes ☐ No				Custody Seal No.: ARI		Cooling Temperature(s) °C and Other Remarks: R.S. 4153 C.S. 2-15.3					

Eurofins Environment Testing Philadelphia,

795 Horsham Road

Horsham, PA 19044-0962

Phone: 215-355-3900

Chain of Custody Record



Environment Testing

Client Information (Sub Contract Lab)		Sampler: N/A		Lab PM: Dougherty, Erin		Carrier Tracking No(s): N/A		COC No: 630-17563.7			
Client Contact: Shipping/Receiving		Phone: N/A		E-Mail: Erin.Dougherty@et.eurofinsus.com		State of Origin: New Jersey		Page: Page 7 of 9			
Company: Eurofins Lancaster Laboratories Environm				Accreditations Required (See note): NELAP - New Jersey				Job #: 630-109285-1			
Address: 2425 New Holland Pike,		Due Date Requested: 5/12/2025		Analysis Requested						Preservation Codes:	
City: Lancaster		TAT Requested (days): N/A									
State, Zip: PA, 17601											
Phone: 717-656-2300(Tel)		PO #: N/A									
Email: N/A		WO #: N/A									
Project Name: Margate City Schools - Lead - 7804 Amherst		Project #: 63008066		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		200.8/MTL_ND_Prep (MOD) Lead		Total Number of containers	
Site: N/A		SSOW#: N/A								Other: N/A	
Sample Identification - Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=comp, G=grab)		Matrix (W=water, S=solid, O=soil, BT=tissue, A=air)		Special Instructions/Note:	
THWS23 (630-109285-55)		4/16/25		06:42 Eastern		G		Drinking Water		1	
TCS01 (630-109285-56)		4/16/25		06:44 Eastern		G		Drinking Water		1	
THWS24 (630-109285-57)		4/16/25		06:47 Eastern		G		Drinking Water		1	
TCS02 (630-109285-58)		4/16/25		06:49 Eastern		G		Drinking Water		1	
TWC05 (630-109285-59)		4/16/25		06:51 Eastern		G		Drinking Water		1	
THB04 (630-109285-60)		4/16/25		06:55 Eastern		G		Drinking Water		1	
TSL01 (630-109285-61)		4/16/25		06:57 Eastern		G		Drinking Water		1	
THWS26 (630-109285-62)		4/16/25		06:58 Eastern		G		Drinking Water		1	
TKS06 (630-109285-63)		4/16/25		06:59 Eastern		G		Drinking Water		1	
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.											
Possible Hazard Identification						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)					
Unconfirmed						☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months					
Deliverable Requested: I, II, III, IV, Other (specify)						Primary Deliverable Rank: 1					
Special Instructions/QC Requirements:											
Empty Kit Relinquished by:				Date:		Time:		Method of Shipment:			
Relinquished by: Edwin Rhodes				Date/Time: 4/18/25 16:20		Company: EETP		Received by: KTB Courier		Date/Time: 4/18/25 16:20	
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: ☐ Yes ☐ No				Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks: 12.5-15.3C 3-2-15.3					

Eurofins Environment Testing Philadelphia,

795 Horsham Road

Horsham, PA 19044-0962

Phone: 215-355-3900

Chain of Custody Record



Environment Testing

Client Information (Sub Contract Lab)		Sampler: N/A		Lab PM: Dougherty, Erin		Carrier Tracking No(s): N/A		COC No: 630-17563.8							
Client Contact: Shipping/Receiving		Phone: N/A		E-Mail: Erin.Dougherty@et.eurofinsus.com		State of Origin: New Jersey		Page: Page 8 of 9							
Company: Eurofins Lancaster Laboratories Environm				Accreditations Required (See note): NELAP - New Jersey				Job #: 630-109285-1							
Address: 2425 New Holland Pike, City: Lancaster State, Zip: PA, 17601		Due Date Requested: 5/12/2025 TAT Requested (days): N/A		Analysis Requested						Preservation Codes:					
Phone: 717-656-2300(Tel)		PO #: N/A		Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) 200.8/MTL_ND_Prep (MOD) Lead						Total Number of containers		Other: N/A			
Email: N/A		WO #: N/A													
Project Name: Margate City Schools - Lead - 7804 Amherst		Project #: 63008066													
Site: N/A		SSOW#: N/A													
Sample Identification - Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=comp, G=grab)		Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)		Special Instructions/Note:					
						Preservation Code:									
TKS07 (630-109285-64)		4/16/25		06:59 Eastern		G		Drinking Water		1					
TKS08 (630-109285-65)		4/16/25		07:00 Eastern		G		Drinking Water		1					
TIMK (630-109285-66)		4/16/25		07:01 Eastern		G		Drinking Water		1					
THWS27 (630-109285-67)		4/16/25		07:02 Eastern		G		Drinking Water		1					
TWC06 (630-109285-68)		4/16/25		07:06 Eastern		G		Drinking Water		1					
TWC07 (630-109285-69)		4/16/25		07:07 Eastern		G		Drinking Water		1					
TWC08 (630-109285-70)		4/16/25		07:08 Eastern		G		Drinking Water		1					
THWS28 (630-109285-71)		4/16/25		07:18 Eastern		G		Drinking Water		1					
THWS29 (630-109285-72)		4/16/25		07:20 Eastern		G		Drinking Water		1					
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.															
Possible Hazard Identification										Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)					
Unconfirmed										☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months					
Deliverable Requested: I, II, III, IV, Other (specify)										Primary Deliverable Rank: 1					
Special Instructions/QC Requirements:															
Empty Kit Relinquished by:				Date:		Time:		Method of Shipment:							
Relinquished by: Edwin Rhodes				Date/Time: 4/28/25 16:20		Company: EETP		Received by: KTB Courier							
Relinquished by:				Date/Time:		Company:		Date/Time: 4/28/25 16:20							
Relinquished by:				Date/Time:		Company:		Date/Time: 4/28/25 2200							
Custody Seals Intact: Δ Yes Δ No				Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks: R:5.4-15.3 C:5.2-15.3									

eurolins | Environment Testing

5/12/2025