



### CERTIFICATE OF ANALYSIS

**Customer :** Garden State Environmental  
555 South Broad Street, Suite K  
Glen Rock, NJ 07452

**Project ID :** Rahway #9248 - Veterans Field House, 232 Central Ave, Rahway, NJ 07065

**PAS Project ID :** P25-03552

**Matrix :** Drinking Water  
**Report Date :** 5/19/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03552-01	V-2-S1A	Lead	0.960 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 11:18	5/7/25 19:12
P25-03552-02	V-2-ICE1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 11:19	5/7/25 19:16
P25-03552-03	V-2-S2A	Lead	1.77 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 11:21	5/7/25 19:21
P25-03552-04	V-4-24-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 11:25	5/7/25 19:25

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result

\* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Kelly Hogan - Quality Assurance Officer

