



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Rahway #9248 - Alternative School (ACE), 244 Central Ave, Rahway, NJ 07065

Matrix : Drinking Water

PAS Project ID : P25-03553

Report Date : 5/19/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03553-01	ACE-1-SSA	Lead	14.3	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 11:04	5/7/25 19:30
P25-03553-02	ACE-2-F1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 11:06	5/7/25 19:34
P25-03553-03	ACE-4-24-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 11:08	5/7/25 19:39

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

