



### CERTIFICATE OF ANALYSIS

**Customer :** Garden State Environmental  
555 South Broad Street, Suite K  
Glen Rock, NJ 07452

**Project ID :** Rahway #9248 - Grover Cleveland ES, 486 E Milton Ave, Rahway, NJ 07065

**Matrix :** Drinking Water

**PAS Project ID :** P25-03555

**Report Date :** 5/19/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03555-01	GC-1-F4A	Lead	1.66 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:29	5/8/25 16:22
P25-03555-02	GC-1-F3A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:30	5/8/25 16:38
P25-03555-03	GC-1-S15A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:38	5/8/25 16:50
P25-03555-04	GC-1-S14A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:38	5/8/25 16:54
P25-03555-05	GC-1-H-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:39	5/8/25 16:58
P25-03555-06	GC-1-S16A	Lead	1.87 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:40	5/8/25 17:02
P25-03555-07	GC-1-S13A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:41	5/8/25 17:06
P25-03555-08	GC-1-F7A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:43	5/8/25 17:10
P25-03555-09	GC-1-F8A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:44	5/8/25 17:14
P25-03555-10	GC-1-F9A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:45	5/8/25 17:18
P25-03555-11	GC-1-S30A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:46	5/8/25 17:22
P25-03555-12	GC-1-S2A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:49	5/8/25 17:34
P25-03555-13	GC-1-S1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:50	5/8/25 17:38
P25-03555-14	GC-1-F22A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:52	5/8/25 17:42
P25-03555-15	GC-1-BF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 08:53	5/8/25 17:47
P25-03555-16	GC-2-S49A	Lead	1.45 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 09:01	5/8/25 17:51
P25-03555-17	GC-2-F18A	Lead	1.87 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 09:02	5/8/25 17:55
P25-03555-18	GC-2-F17A	Lead	2.93	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 09:03	5/8/25 17:59
P25-03555-19	GC-2-F12A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 09:05	5/8/25 18:03
P25-03555-20	GC-2-F13A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 09:07	5/8/25 18:07
P25-03555-21	GC-2-F14A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 09:09	5/8/25 18:19
P25-03555-22	GC-2-F15A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 09:10	5/8/25 18:56
P25-03555-23	GC-2-F16A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 09:11	5/8/25 19:00
P25-03555-24	GC-4-24-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/24/25 09:15	5/8/25 19:04

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result

\* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Kelly Hogan - Quality Assurance Officer



part of  
**ALS Limited**

**CHAIN  
OF  
CUSTODY**

Customer: Garden State Environmental  
 Address: 555 S. Broad St.  
 Glen Rock, NJ 07452  
 Phone: (201) 652-1119 Office

School Name: **Rahway #9248 - Grover Cleveland ES**  
 School Address: **486 E Milton Ave, Rahway, NJ 07065**  
 Sampled By: *Caroline Poskrobko*  
 Print Name: **Caroline Poskrobko**  
 RESULTS TO: **labreports@gseconsultants.com**

Sample ID Location	Date: 4/24/2025 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
GC-1-F4A; Rm 100	8:29 AM	DW	Grab			1	250 ml Plastic	Lead	P25-03555-01
GC-1-F3A; Rm 101	8:30 AM	DW	Grab			1	250 ml Plastic	Lead	02
GC-1-S15A; Kitchen 3 COMP Right	8:38 AM	DW	Grab			1	250 ml Plastic	Lead	03
GC-1-S14A; Kitchen 3 COMP Left	8:38 AM	DW	Grab			1	250 ml Plastic	Lead	04
GC-1-H-01A; Kitchen 3 COMP	8:39 AM	DW	Grab			1	250 ml Plastic	Lead	05
GC-1-S16A; Kitchen Island	8:40 AM	DW	Grab			1	250 ml Plastic	Lead	06
GC-1-S13A; Kitchen Left Wall	8:41 AM	DW	Grab			1	250 ml Plastic	Lead	07
GC-1-F7A; Rm 116	8:43 AM	DW	Grab			1	250 ml Plastic	Lead	08
GC-1-F8A; Rm 114	8:44 AM	DW	Grab			1	250 ml Plastic	Lead	09
GC-1-F9A; Rm 108	8:45 AM	DW	Grab			1	250 ml Plastic	Lead	10
GC-1-S30A; Faculty Rm	8:46 AM	DW	Grab			1	250 ml Plastic	Lead	11
GC-1-S2A; Nurse Near Fridge	8:49 AM	DW	Grab			1	250 ml Plastic	Lead	12
GC-1-S1A; Nurse Island	8:50 AM	DW	Grab			1	250 ml Plastic	Lead	13
GC-1-F22A; Near Door 3	8:52 AM	DW	Grab		X	1	250 ml Plastic	Lead	14
GC-1-BF-01A; Near Door 3	8:53 AM	DW	Grab		X	1	250 ml Plastic	Lead	P25-03555-15

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of 2

Deliverables: PDF Std.  PDF Reduce  PDF Full  EDD  Date/Time Preserved with HNO3: **5/5/25 16:09**

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Caroline Poskrobko	<i>Caroline Poskrobko</i>	GSE	4/29/2025, 1:35 PM
Received:	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	5/8/25 10:38 AM
Relinquished:	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	5/8/25
Received:	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	5/2/25 1:35
Relinquished:	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	5/2/25 1:55
Received:	<i>Lynn Sburro</i>	<i>Lynn Sburro</i>	<i>[Signature]</i>	



part of  
**ALS Limited**

**CHAIN  
OF  
CUSTODY**

Customer: Garden State Environmental  
 Address: 555 S. Broad St.  
 Glen Rock, NJ 07452  
 Phone: (201) 652-1119 Office

School Name: **Rahway #9248 - Grover Cleveland ES**  
 School Address: **486 E Milton Ave, Rahway, NJ 07065**  
 Sampled By: *Caroline Poskrobko*  
 Print Name: **Caroline Poskrobko**  
 RESULTS TO: **labreports@gseconsultants.com**

Sample ID Location	Date: 4/24/2025 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Pretest	# Containers	Glass or Plastic	Analysis	LAB ID
GC-2-S49A; Faculty Rm	9:01 AM	DW	Grab			1	250 ml Plastic	Lead	P25-03555-16
GC-2-F18A; Room 200	9:02 AM	DW	Grab			1	250 ml Plastic	Lead	17
GC-2-F17A; Room 201	9:03 AM	DW	Grab			1	250 ml Plastic	Lead	18
GC-2-F12A; Rm 216	9:05 AM	DW	Grab			1	250 ml Plastic	Lead	19
GC-2-F13A; Rm 215	9:07 AM	DW	Grab			1	250 ml Plastic	Lead	20
GC-2-F14A; Rm 214	9:09 AM	DW	Grab			1	250 ml Plastic	Lead	21
GC-2-F15A; Rm 208	9:10 AM	DW	Grab			1	250 ml Plastic	Lead	22
GC-2-F16A; Rm 202	9:11 AM	DW	Grab			1	250 ml Plastic	Lead	23
GC-4-24-FBA; Field Blank	9:15 AM	DW	Grab			1	250 ml Plastic	Lead	P25-03555-24
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Deliverables: PDF Std.  PDF Reduce  PDF Full  EDD  Date/Time Preserved with HNO3: **5/15/25 16:09**

**MATRIX CODES:** GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

**PRESERVATION CODES:** 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Caroline Poskrobko	<i>Caroline Poskrobko</i>	GSE	4/29/2025; 1:35 PM
Received:	<i>Matt [Signature]</i>	<i>Matt [Signature]</i>	<i>Yale</i>	5/2/25 10:38 AM
Relinquished:	<i>Matt [Signature]</i>	<i>Matt [Signature]</i>		5/2/25
Received:	<i>Tony Hoops</i>	<i>Tony Hoops</i>		5/2/25
Relinquished:	<i>Tony Hoops</i>	<i>Tony Hoops</i>		5/2/25
Received:	<i>Lynn Souwa</i>	<i>Lynn Souwa</i>		16:53