



### CERTIFICATE OF ANALYSIS

**Customer :** Garden State Environmental  
555 South Broad Street, Suite K  
Glen Rock, NJ 07452

**Project ID :** Rahway #9248 - Rahway HS, 1012 Madison Ave, Rahway, NJ 07065  
**PAS Project ID :** P25-03530

**Matrix :** Drinking Water  
**Report Date :** 5/19/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03530-01	RHS-1-F6A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:30	5/12/25 13:07
P25-03530-02	RHS-1-BF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:30	5/12/25 13:25
P25-03530-03	RHS-1-S30A	Lead	3.47	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:35	5/12/25 13:50
P25-03530-04	RHS-1-F20A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:37	5/12/25 13:54
P25-03530-05	RHS-1-F7A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:38	5/12/25 13:59
P25-03530-06	RHS-1-F8A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:43	5/12/25 14:03
P25-03530-07	RHS-1-F8AA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:43	5/12/25 14:08
P25-03530-08	RHS-1-F10A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:48	5/12/25 14:12
P25-03530-09	RHS-1-F10AA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:48	5/12/25 14:16
P25-03530-10	RHS-1-F9A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:49	5/12/25 14:21
P25-03530-11	RHS-1-F9AA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:50	5/12/25 14:25
P25-03530-12	RHS-1-WC-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:52	5/12/25 14:39
P25-03530-13	RHS-1-BF-03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:52	5/12/25 14:44
P25-03530-14	RHS-1-S1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:56	5/12/25 14:48
P25-03530-15	RHS-1-S2A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:57	5/12/25 14:53
P25-03530-16	RHS-1-S3A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:57	5/12/25 14:57
P25-03530-17	RHS-1-PF-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:59	5/12/25 15:02
P25-03530-18	RHS-1-S4A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 08:59	5/12/25 15:07
P25-03530-19	RHS-1-F4A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:02	5/12/25 15:11
P25-03530-20	RHS-1-BF-04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:02	5/12/25 15:16
P25-03530-21	RHS-1-S11A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:04	5/12/25 15:29
P25-03530-22	RHS-1-IM-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:05	5/12/25 15:47
P25-03530-23	RHS-1-S10A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:09	5/12/25 15:51
P25-03530-24	RHS-1-DS-01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:09	5/12/25 15:56
P25-03530-25	RHS-1-F2A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:11	5/12/25 16:00
P25-03530-26	RHS-1-F3A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:14	5/12/25 16:04
P25-03530-27	RHS-1-S28A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:21	5/12/25 16:18
P25-03530-28	RHS-1-S27A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:22	5/12/25 16:22
P25-03530-29	RHS-1-S29A	Lead	1.20 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:23	5/12/25 16:27
P25-03530-30	RHS-1-S26A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:24	5/12/25 16:31
P25-03530-31	RHS-1-S25A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:24	5/12/25 16:35
P25-03530-32	RHS-1-S24A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:25	5/12/25 16:40
P25-03530-33	RHS-1-S19A	Lead	1.77 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:35	5/12/25 16:44
P25-03530-34	RHS-1-S18A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:36	5/12/25 16:49
P25-03530-35	RHS-1-S23A	Lead	1.62 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:36	5/12/25 17:11
P25-03530-36	RHS-1-S22A	Lead	1.06 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:36	5/12/25 17:15
P25-03530-37	RHS-1-S20A	Lead	1.06 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:37	5/12/25 17:20
P25-03530-38	RHS-1-S21A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:38	5/12/25 17:24
P25-03530-39	RHS-2-F12A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:40	5/12/25 17:29
P25-03530-40	RHS-2-F13A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:41	5/12/25 17:33
P25-03530-41	RHS-3-F15A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:50	5/12/25 17:37
P25-03530-42	RHS-3-BF-05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:50	5/12/25 18:04
P25-03530-43	RHS-3-F16A	Lead	4.04	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:51	5/12/25 18:08
P25-03530-44	RHS-3-F17A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:53	5/12/25 18:13
P25-03530-45	RHS-3-BF-02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:54	5/12/25 18:17
P25-03530-46	RHS-4-22-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/25 09:55	5/12/25 18:22

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result

\* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Kelly Hogan - Quality Assurance Officer