

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
01-1-KIT-S-KC-01	1&9	7/16/2016	< 2.0
01-1-KIT-W-KC-02	1&9	7/16/2016	< 2.0
01-1-KIT-W-KC-03	1&9	7/16/2016	< 2.0
01-1-KIT-W-KC-04	1&9	7/16/2016	< 2.0
01-1-KIT-S-KC-05	1&9	7/16/2016	< 2.0
01-1-KIT-S-KC-06	1&9	7/16/2016	3.3
01-1-KIT-N-KC-07	1&9	7/16/2016	< 2.0
01-1-KIT-S-HS-01	1&9	7/16/2016	< 2.0
01-1-KIT-N-KC-08	1&9	7/16/2016	2.4
01-1-KIT-S-FP-01	1&9	7/16/2016	201
01-1-KIT-S-FP-02	1&9	7/16/2016	4.9
01-1-KIT-S-HS-02	1&9	7/16/2016	< 2.0
01-1-CAF-S-WC	1&9	7/16/2016	< 2.0
01-1-HESL-W-WC	1&9	7/16/2016	< 2.0
01-1-NUR-S-NS	1&9	7/16/2016	< 2.0
01-1-NUR-S-IM	1&9	7/16/2016	< 1.0
01-1-NUR-E-BF	1&9	7/16/2016	< 2.0
01-1-LIBO-N-HS	1&9	7/16/2016	3.5
01-1-HW302-W-WC	1&9	7/16/2016	4.2
01-1-GB-S-BF-01	1&9	7/16/2016	< 2.0
01-1-RR-W-CF	1&9	7/16/2016	16.8
01-1-FWB-S-BF-01	1&9	7/16/2016	< 2.0
01-1-HPOOL-N-WC	1&9	7/16/2016	< 2.0
01-1-PO-W-BF	1&9	7/16/2016	< 2.0
01-1-POOL-W-DW	1&9	7/16/2016	2.5
01-1-GLR-E-BF-02	1&9	7/16/2016	< 2.0
01-1-GLR-E-DW	1&9	7/16/2016	3.9
01-1-BLR-E-BF-01	1&9	7/16/2016	4.8
01-1-BLR-E-DW	1&9	7/16/2016	< 2.0
01-1-BB-W-BF-01	1&9	7/16/2016	< 2.0
01-1-BB-W-BF-02	1&9	7/16/2016	< 2.0
01-1-GO-W-BF	1&9	7/16/2016	8.6
01-1-505-E-DW	1&9	7/16/2016	2.8
01-1-504-E-DW	1&9	7/16/2016	188
01-1-503-E-DW	1&9	7/16/2016	210
01-1-502-S-DW	1&9	7/16/2016	31.2
01-1-501-S-DW	1&9	7/16/2016	8.1
01-1-500-S-DW	1&9	7/16/2016	4
01-1-302-E-DW	1&9	7/16/2016	4.8
01-1-303-E-CF	1&9	7/16/2016	2.2
01-1-304-E-CF	1&9	7/16/2016	8.3
01-1-306-S-DW	1&9	7/16/2016	33
01-1-307-S-CF	1&9	7/16/2016	28.9
01-1-308-W-CF	1&9	7/16/2016	2.8
01-1-309-W-CF	1&9	7/16/2016	< 2.0
01-1-310-W-CF	1&9	7/16/2016	< 2.0
01-1-HW310-E-WC	1&9	7/16/2016	< 2.0
01-1-BB-S-BF-01	1&9	7/16/2016	< 2.0
01-1-311-N-FL	1&9	7/16/2016	< 2.0
01-1-321-S-CF	1&9	7/16/2016	3.7
01-1-321-S-BF	1&9	7/16/2016	6.7
01-1-300-S-CF	1&9	7/16/2016	2.2
01-1-300-N-BF	1&9	7/16/2016	2.4
01-1-301-W-CF-01	1&9	7/16/2016	2.4
01-1-KGB-S-BF	1&9	7/16/2016	< 2.0
01-1-HW313-E-WC	1&9	7/16/2016	< 2.0
01-1-314-N-DW	1&9	7/16/2016	4.6
01-1-BBCST-S-BF-01	1&9	7/16/2016	3.1
01-1-HWBBCST-W-WC	1&9	7/16/2016	< 2.0
01-1-GBP-N-BF-01	1&9	7/16/2016	< 2.0
01-1-GBP-N-BF-02	1&9	7/16/2016	2.7
01-1-PO-S-HS	1&9	7/16/2016	8.4
01-1-PO-S-BF	1&9	7/16/2016	< 2.0
01-1-HWO-E-WC	1&9	7/16/2016	< 2.0
01-1-DCDR-W-HS	1&9	7/16/2016	13
01-1-DCE1-S-HS	1&9	7/16/2016	< 2.0
01-1-DCE2-S-HS	1&9	7/16/2016	3.6
01-1-DCE3-S-HS	1&9	7/16/2016	2.1
01-1-DCS-E-HS	1&9	7/16/2016	7.3
01-1-NUR2-E-HS-1	1&9	7/16/2016	< 2.0
01-1-NUR2-N-HS-2	1&9	7/16/2016	2.9
01-1-NUR2-N-HS-3	1&9	7/16/2016	3.5
01-1-NUR2-S-BF	1&9	7/16/2016	27
01-1-NUR2-E-IM	1&9	7/16/2016	< 2.0
01-1-106-W-DW	1&9	7/16/2016	6.2
01-1-106-W-BF	1&9	7/16/2016	14.4
01-1-107-W-DW	1&9	7/16/2016	3.3

Water Test Results 2016

01-1-107-E-BF	1&9	7/16/2016	2.3
01-1-108-W-DW	1&9	7/16/2016	3.3
01-1-108-W-BF	1&9	7/16/2016	4.2
01-1-H108-E-WC	1&9	7/16/2016	< 2.0
01-1-H115-E-WC	1&9	7/16/2016	< 2.0
01-1-115-E-BF	1&9	7/16/2016	< 2.0
01-1-115-W-DW	1&9	7/16/2016	< 2.0
01-1-114-W-BF	1&9	7/16/2016	3.9
01-1-114-E-DW	1&9	7/16/2016	< 2.0
01-1-H112-W-WC	1&9	7/16/2016	< 2.0
01-1-113-E-BF	1&9	7/16/2016	2.2
01-1-113-W-DW	1&9	7/16/2016	< 2.0
01-1-112-W-BF	1&9	7/16/2016	2.9
01-1-112-E-DW	1&9	7/16/2016	< 2.0
01-1-111-N-DW	1&9	7/16/2016	5.6
01-1-111-N-BF	1&9	7/16/2016	3.2
01-1-110-N-DW	1&9	7/16/2016	5.9
01-1-110-S-BF	1&9	7/16/2016	4.9
01-1-109-N-DW	1&9	7/16/2016	3.1
01-1-109-W-BF	1&9	7/16/2016	3
01-1-100-E-DW	1&9	7/16/2016	2.8
01-1-100-E-BF	1&9	7/16/2016	5.2
01-1-101-E-DW	1&9	7/16/2016	2.8
01-1-101-W-BF	1&9	7/16/2016	2.2
01-1-102-E-DW	1&9	7/16/2016	2.4
01-1-102-E-BF	1&9	7/16/2016	2.3
01-1-103-S-DW	1&9	7/16/2016	5.2
01-1-103-S-BF	1&9	7/16/2016	13.9
01-1-104-S-DW	1&9	7/16/2016	5.2
01-1-104-N-BF	1&9	7/16/2016	5.3
01-1-105-S-DW	1&9	7/16/2016	3
01-1-105-S-BF	1&9	7/16/2016	2.1
01-1-HE9-N-WC	1&9	7/16/2016	< 2.0
01-1-G02-W-BF	1&9	7/16/2016	2.1
01-2-409-E-DW	1&9	7/16/2016	23.8
01-2-408-E-DW	1&9	7/16/2016	44.3
01-2-407-E-DW	1&9	7/16/2016	9
01-2-H407-W-WC	1&9	7/16/2016	9.2
01-2-GB-S-BF-01	1&9	7/16/2016	< 2.0
01-2-MB406-N-BF	1&9	7/16/2016	< 2.0
01-2-WB406-S-BF	1&9	7/16/2016	< 2.0
01-2-405-N-DW	1&9	7/16/2016	2.6
01-2-404-N-DW	1&9	7/16/2016	42.8
01-2-403-N-DW	1&9	7/16/2016	13
01-2-H402-E-WC	1&9	7/16/2016	< 2.0
01-2-MB-S-BF-01	1&9	7/16/2016	3.8
01-2-MB-S-BF-02	1&9	7/16/2016	4.2
01-2-402-W-CF	1&9	7/16/2016	2.2
01-2-401-W-CF	1&9	7/16/2016	3.6
01-2-400-W-DW	1&9	7/16/2016	5.6
01-2-200-E-DW	1&9	7/16/2016	2.2
01-2-200-E-BF	1&9	7/16/2016	10.9
01-2-201-E-DW	1&9	7/16/2016	< 2.0
01-2-201-W-BF	1&9	7/16/2016	2.7
01-2-202-E-CF	1&9	7/16/2016	< 2.0
01-2-202-E-BF	1&9	7/16/2016	7.9
01-2-MBFR-W-BF	1&9	7/16/2016	2.5
01-2-WBFR-E-BF	1&9	7/16/2016	2.5
01-2-HFR-E-WC	1&9	7/16/2016	< 2.0
01-2-203-S-DW	1&9	7/16/2016	5.3
01-2-203-S-BF	1&9	7/16/2016	5.2
01-2-204-S-DW	1&9	7/16/2016	< 2.0
01-2-204-W-BF	1&9	7/16/2016	6
01-2-205-S-DW	1&9	7/16/2016	12.4
01-2-205-S-BF	1&9	7/16/2016	176
01-2-205A-E-HS	1&9	7/16/2016	12
01-2-206-W-DW	1&9	7/16/2016	4.5
01-2-206-W-BF	1&9	7/16/2016	10
01-2-207-W-DW	1&9	7/16/2016	4.3
01-2-207-E-BF	1&9	7/16/2016	10.2
01-2-208-W-DW	1&9	7/16/2016	3.1
01-2-208-W-BF	1&9	7/16/2016	8.6
01-2-H208-E-WC	1&9	7/16/2016	< 2.0
01-1-KIT-N-BF	1&9	7/16/2016	< 2.0
01-TCU-119-E-CF	1&9	7/16/2016	2.7
01-TCU-119-S-WC	1&9	7/16/2016	< 2.0
01-TCU-119-W-BF	1&9	7/16/2016	23
01-TCU-118-W-CF	1&9	7/16/2016	< 2.0
01-TCU-118-S-WC	1&9	7/16/2016	< 2.0

Water Test Results 2016

01-TCU-118-E-BF	1&9	7/16/2016	< 2.0
01-TCU-117-E-CF	1&9	7/16/2016	< 2.0
01-TCU-117-N-WC	1&9	7/16/2016	< 2.0
01-TCU-117-W-BF	1&9	7/16/2016	< 2.0
01-TCU-116-W-CF	1&9	7/16/2016	< 2.0
01-TCU-116-N-WC	1&9	7/16/2016	< 2.0
01-TCU-116-E-BF	1&9	7/16/2016	< 2.0
01-TCU-120-W-CF	1&9	7/16/2016	< 2.0
01-TCU-120-N-WC	1&9	7/16/2016	< 2.0
01-TCU-121-E-CF	1&9	7/16/2016	< 2.0
01-TCU-121-N-WC	1&9	7/16/2016	3
01-TCU-121-W-BF	1&9	7/16/2016	< 2.0
01-TCU-122-W-CF	1&9	7/16/2016	< 2.0
01-TCU-122-S-WC	1&9	7/16/2016	< 2.0
01-TCU-122-E-BF	1&9	7/16/2016	< 2.0
01-TCU-123-E-CF	1&9	7/16/2016	< 2.0
01-TCU-123-S-WC	1&9	7/16/2016	< 2.0
01-TCU-123-W-BF	1&9	7/16/2016	< 2.0

ROOM / LOCATION ID

- BB = Boys Bathroom
- BBCST = Boys Bathroom by CST Room
- BLR = Boys Locker Room
- DCDR = Dental Clinic Dark Room
- DCE = Dental Clinic Exam Room
- FR = Faculty Room
- FWB = Faculty Womens Bathroom
- GB = Girls Bathroom
- GLR = Girls Locker Room
- GO = Gym Office
- GO2 = Gym Office 2 by Exit 9
- GPO = Girls Bathroom by Principals Office
- HE9 = Hallway by Exit 9
- HESL = Hallway across from ESL Room
- HPOOL = Hallway by Pool
- HW = Hallway (if precedes room location)
- HWBBCST = Hallway by Boys Bathroom by CST Room
- HWO = Hallway by Main Office
- KGB = Kindergarten Girls Bathroom
- KIT = Kitchen
- LIBO = Library Office
- MB = Mens Bathroom
- MBFR = Mens Faculty Bathroom
- NUR = Nurses Office
- PO = Pool Office
- PO = Principals Office
- POOL = Pool Room
- RR = Resource Room
- TCU = Temporary Classroom Unit
- TR = Teachers Lounge / Cafeteria
- WB = Womens Bathroom
- WBFR = Womens Faculty Bathroom

OUTLET TYPE

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Faucet, Cold
- NS = Nurses Sink
- TF = Teachers Faucet
- WC = Water Cooler

Water Testing Results After Remediation 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
01-1-KIT-S-FP-01-R-1	1&9	8/23/2016	3.9
01-1-RR-W-CF-R-1	1&9	8/23/2016	6.2
01-1-504-E-DW-R-1	1&9	8/23/2016	2.5
01-1-503-E-DW-R-1	1&9	8/23/2016	< 2.0
01-1-502-S-DW-R-1	1&9	8/23/2016	2.9
01-1-307-S-CF-R-1	1&9	8/23/2016	3.1
01-2-205-S-BF-R-1	1&9	8/23/2016	10.8
01-2-409-E-DW-R-1	1&9	8/23/2016	4.9
01-2-408-E-DW-R-1	1&9	8/23/2016	4.7
01-2-404-N-DW-R-1	1&9	8/23/2016	6.2
01-TCU-119-W-BF-R-1	1&9	8/23/2016	< 2.0

ROOM / LOCATION ID

KIT = Kitchen

RR = Resource Room

TCU = Temporary Classroom Unit

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

FP = Food Prep