

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
5-GFL-HB01-W-WC	5B	8/3/2016	< 2.0
5-GFL-BR-N-BF-1	5B	8/3/2016	5.5
5-GFL-B02-N-BF	5B	8/3/2016	6.9
5-GFL-B02-N-CF	5B	8/3/2016	3.4
5-GFL-B04-E-CF	5B	8/3/2016	33.9
5-GFL-B04-W-BF	5B	8/3/2016	4.0
5-GFL-B03-N-CF	5B	8/3/2016	3.2
5-GFL-B03-W-BF	5B	8/3/2016	< 2.0
5-GFL-KIT-N-FP	5B	8/3/2016	2.6
5-GFL-KIT-N-KS	5B	8/3/2016	< 2.0
5-GFL-KIT-N-HS	5B	8/3/2016	3.8
5-GFL-B06-N-CF	5B	8/3/2016	3.7
5-GFL-B06-W-BF	5B	8/3/2016	2.4
5-GFL-B05-N-CF	5B	8/3/2016	2.6
5-GFL-B05-E-BF	5B	8/3/2016	< 2.0
5-GFL-B01-W-BF	5B	8/3/2016	2.1
5-GFL-B01-S-CF	5B	8/3/2016	5.5
5-GFL-GR-S-BF-1	5B	8/3/2016	19.5
5-GFL-GR-S-BF-2	5B	8/3/2016	2.1
5-1FL-106-S-HS	5B	8/3/2016	< 2.0
5-1FL-107-E-BF	5B	8/3/2016	< 2.0
5-1FL-107-E-CF	5B	8/3/2016	5.8
5-1FL-109-S-BF	5B	8/3/2016	< 2.0
5-1FL-109-W-CF	5B	8/3/2016	8.6
5-1FL-FR-N-HS	5B	8/3/2016	139
5-1FL-101-S-BF	5B	8/3/2016	4.7
5-1FL-101-E-CF	5B	8/3/2016	12.1
5-1FL-H102-S-WC	5B	8/3/2016	< 2.0
5-1FL-102-E-CF	5B	8/3/2016	13.5
5-1FL-102-S-BF	5B	8/3/2016	4.1

ROOM / LOCATION ID

BR = Boys Restroom

FR = Faculty Room (Back Stage; hidden, likely not flushed)

GR = Girls Restroom

H = Hallway (if precedes room location)

KIT = Kitchen

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

FP = Food Prep

HS = Hand Sink

Water Test Results 2016

KS = Kitchen Sink

WC = Water Cooler