

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
6-1-WKS-N-BF	6	7/21/2016	3.1
6-1-FDR-N-KC	6	7/21/2016	< 2.0
6-1-FDR-N-HS	6	7/21/2016	< 2.0
6-1-KIT-E-KC-01	6	7/21/2016	< 2.0
6-1-KIT-E-KC-02	6	7/21/2016	1.3
6-1-KIT-W-KC-03	6	7/21/2016	< 2.0
6-1-KIT-W-KC-04	6	7/21/2016	< 2.0
6-1-KIT-W-HS	6	7/21/2016	< 2.0
6-1-KIT-W-KC-05	6	7/21/2016	4.7
6-1-KIT-N-KC-06	6	7/21/2016	< 2.0
6-1-CAF-N-DW-01	6	7/21/2016	< 2.0
6-1-CAF-S-DW-02	6	7/21/2016	< 2.0
6-1-BB-N-BF-01	6	7/21/2016	< 2.0
6-1-GB-S-BF-02	6	7/21/2016	< 2.0
6-1-136-N-CF	6	7/21/2016	3.6
6-1-134-N-CF	6	7/21/2016	3.8
6-1-CR-S-HS	6	7/21/2016	< 2.0
6-1-H134-W-DW	6	7/21/2016	2.3
6-1-132-N-CF	6	7/21/2016	8.1
6-1-129-SE-DW	6	7/21/2016	3.5
6-1-130-SW-DW	6	7/21/2016	< 2.0
6-1-130-W-BF	6	7/21/2016	2
6-1-WTB-N-BF-01	6	7/21/2016	< 2.0
6-1-WTB-N-BF-03	6	7/21/2016	< 2.0
6-1-H120-S-WC	6	7/21/2016	< 2.0
6-1-121-S-DW	6	7/21/2016	< 2.0
6-1-121-S-CF	6	7/21/2016	< 2.0
6-1-121-N-BF	6	7/21/2016	< 2.0
6-1-120-S-BF	6	7/21/2016	< 2.0
6-1-120-N-DW	6	7/21/2016	< 2.0
6-1-120-N-CF	6	7/21/2016	< 2.0
6-1-GLR-S-BF-01	6	7/21/2016	8.6
6-1-GYM-E-DW-01	6	7/21/2016	< 2.0
6-1-GYM-E-DW-02	6	7/21/2016	< 2.0
6-1-GO-N-BF	6	7/21/2016	15.6
6-1-BLR-W-BF	6	7/21/2016	< 2.0
6-1-113-E-CF-01	6	7/21/2016	13
6-1-113-E-CF-02	6	7/21/2016	4.5
6-1-113-W-CF-03	6	7/21/2016	978
6-1-H112-NW-DW	6	7/21/2016	< 2.0
6-1-BB-N-BF-01	6	7/21/2016	< 2.0
6-1-BB-N-BF-03	6	7/21/2016	< 2.0
6-1-116-E-CF-01	6	7/21/2016	< 2.0
6-1-116-E-CF-02	6	7/21/2016	3
6-1-MR-N-BF	6	7/21/2016	< 2.0

Water Test Results 2016

6-2-H216-SW-DW	6	7/21/2016	< 2.0
6-2-217-E-BF	6	7/21/2016	< 2.0
6-2-212-N-LS	6	7/21/2016	94.4
6-2-BB-N-BF-01	6	7/21/2016	< 2.0
6-2-H208-NW-DW	6	7/21/2016	< 2.0
6-2-202-NW-DW	6	7/21/2016	< 2.0
6-2-202-W-BF-01	6	7/21/2016	< 2.0
6-2-202-W-BF-02	6	7/21/2016	< 2.0
6-2-NUR-S-NS	6	7/21/2016	< 2.0
6-2-NUR-E-NS	6	7/21/2016	< 2.0
6-2-NUR-N-BF	6	7/21/2016	< 2.0
6-2-NUR-W-IM	6	7/21/2016	< 2.0
6-2-BB-S-BF-01	6	7/21/2016	< 2.0
6-2-GB-N-BF-01	6	7/21/2016	< 2.0
6-2-242-W-CF	6	7/21/2016	7.8
6-2-240-W-CF	6	7/21/2016	2.6
6-2-H240-W-DW	6	7/21/2016	< 2.0
6-2-238-W-CF	6	7/21/2016	4
6-2-236-S-CF	6	7/21/2016	569
6-2-234-S-CF	6	7/21/2016	10.3
6-2-231A-NE-CF	6	7/21/2016	14.6
6-2-H231-SE-DW	6	7/21/2016	< 2.0
6-2-230-W-CF	6	7/21/2016	12.4
6-2-GB-E-BF-01	6	7/21/2016	< 2.0
6-2-GB-E-BF-02	6	7/21/2016	< 2.0
6-2-H224-E-DW	6	7/21/2016	< 2.0
6-3-H316-NE-DW	6	7/21/2016	< 2.0
6-3-317-W-CF	6	7/21/2016	2.4
6-3-317-E-BF	6	7/21/2016	8.3
6-3-BB-N-BF-01	6	7/21/2016	3
6-3-BB-N-BF-02	6	7/21/2016	2.7
6-3-H308-NW-DW	6	7/21/2016	< 2.0
6-3-306-S-CF	6	7/21/2016	10.3
6-3-304-S-CF	6	7/21/2016	24.3
6-3-302B-S-CF	6	7/21/2016	8.3
6-3-302-S-CF	6	7/21/2016	14
6-3-342-W-CF	6	7/21/2016	10.5
6-3-GB-S-BF-01	6	7/21/2016	3.5
6-3-BB-S-BF-01	6	7/21/2016	< 2.0
6-3-VPO-S-BF	6	7/21/2016	2.8
6-3-340-W-CF	6	7/21/2016	32.2
6-3-H340-W-DW	6	7/21/2016	4.3
6-3-336-S-CF	6	7/21/2016	4.2
6-3-338-W-CF	6	7/21/2016	47.9
6-3-334-S-CF	6	7/21/2016	2.6
6-3-H330-SE-DW	6	7/21/2016	< 2.0
6-3-GB-E-BF-01	6	7/21/2016	< 2.0

Water Test Results 2016

6-3-GB-E-BF-02	6	7/21/2016	< 2.0
6-3-GB-E-BF-03	6	7/21/2016	< 2.0
6-3-H324-E-DW	6	7/21/2016	8.5
6-TCU-107-W-DW	6	7/21/2016	4
6-TCU-107-S-CF	6	7/21/2016	< 2.0
6-TCU-107-N-BF	6	7/21/2016	< 2.0
6-TCU-105-N-DW	6	7/21/2016	< 2.0
6-TCU-105-E-CF	6	7/21/2016	< 2.0
6-TCU-105-W-BF	6	7/21/2016	< 2.0
6-TCU-106-N-DW	6	7/21/2016	< 2.0
6-TCU-106-E-CF	6	7/21/2016	< 2.0
6-TCU-106-W-BF	6	7/21/2016	< 2.0

ROOM / LOCATION ID

BB = Boys Bathroom

BLR = Boys Locker Room

CAF = Cafeteria

CR = Custodian Room

GB = Girls Bathroom

GLR = Girls Locker Room

GO = Gym Office

FDR = Faculty Dining Room

H = Hallway (if precedes room location)

KIT = Kitchen

MR = Mechanical Room Bathroom

NUR = Nurses Office

TCU = Temporary Classroom Unit

VPO = Vice Principals Office

WKS = Womens Kitchen Staff

WTB = Womens Teacher Bathroom

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

HS = Hand Sink

IM = Ice Machine

KC = Kitchen Faucet, Cold

LS = Library Sink

NS = Nurses Sink