

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
7-B-Boiler Bath-S-BF	7	7/13/2016	< 2.0
7-B-GB-W-BF-1	7	7/13/2016	< 2.0
7-B-B1HW-E-DUW	7	7/13/2016	11.0
7-B-B1-E-BF	7	7/13/2016	< 2.0
7-B-B10-S-WC	7	7/13/2016	< 2.0
7-B-B3-E-BF	7	7/13/2016	3.1
7-B-B9-E-BF	7	7/13/2016	33.0
7-B-GYM3-N-DW1	7	7/13/2016	< 2.0
7-B-GYM3-N-DW2	7	7/13/2016	3.6
7-B-B5-S-BF	7	7/13/2016	< 2.0
7-B-B6-S-BF	7	7/13/2016	< 2.0
7-G-G6-W-CF	7	7/13/2016	29.0
7-G-G6-W-DW	7	7/13/2016	2.9
7-G-G6-W-BF	7	7/13/2016	3.5
7-G-G5-E-CF	7	7/13/2016	7.1
7-G-G5-E-DW	7	7/13/2016	< 2.0
7-G-G5-E-BF	7	7/13/2016	8.0
7-G-G4-W-TL-1	7	7/13/2016	28.0
7-G-G4-W-TL-2	7	7/13/2016	9.9
7-G-G3-W-CF	7	7/13/2016	2.4
7-G-G3-W-BF	7	7/13/2016	2.6
7-G-G3-W-DW	7	7/13/2016	< 2.0
7-G-HWCAF2-S-DW	7	7/13/2016	3.3
7-G-CAF2-N-DW-1	7	7/13/2016	6.4
7-G-CAF2-E-DW-2	7	7/13/2016	3.9
7-G-CAF2-S-DW-3	7	7/13/2016	2.2
7-G-G1-S-CF	7	7/13/2016	9.4
7-G-G1-S-DW	7	7/13/2016	< 2.0
7-G-G1-W-BF	7	7/13/2016	16.0
7-G-CAF1-N-HS	7	7/13/2016	< 2.0
7-G-KIT-N-KC-1	7	7/13/2016	2.2
7-G-KIT-N-KC-2	7	7/13/2016	3.7
7-G-KIT-E-FP	7	7/13/2016	2.3
7-G-KIT-S-HS	7	7/13/2016	< 2.0
7-G-KIT-S-KC-1	7	7/13/2016	< 2.0
7-G-KIT-S-KC-2	7	7/13/2016	< 2.0
7-G-KIT-S-KC-3	7	7/13/2016	< 2.0
7-G-G9-E-HS	7	7/13/2016	< 2.0
7-G-G9-W-BF	7	7/13/2016	3.0
7-G-BB-W-BF	7	7/13/2016	< 2.0
7-G-HWG9-W-DW	7	7/13/2016	5.2
7-G-G16-N-NS-1	7	7/13/2016	2.2
7-G-G16-W-NS-2	7	7/13/2016	< 2.0
7-G-G10-E-BF	7	7/13/2016	10.0
7-G-SEC-N-HS	7	7/13/2016	< 2.0

Water Test Results 2016

7-G-GB-E-BF	7	7/13/2016	2.0
7-G-HWG12-S-DW	7	7/13/2016	< 2.0
	7		
7-1-ELEHW-W-DW	7	8/2/2016	9.2
7-1-GB-E-BF-1	7	8/2/2016	18.8
7-1-GB-W-BF-2	7	8/2/2016	17.5
7-1-HW125-W-DW	7	8/2/2016	17.0
7-1-122-N-HS	7	8/2/2016	< 2.0
7-1-121-N-HS	7	8/2/2016	6.2
7-1-119-E-BF	7	8/2/2016	< 2.0
7-1-118-W-BF	7	8/2/2016	< 2.0
7-1-110-E-BF-1	7	8/2/2016	< 2.0
7-1-110-W-BF-2	7	8/2/2016	< 2.0
7-1-110-S-TL	7	8/2/2016	< 2.0
7-1-108-E-CF	7	8/2/2016	22.1
7-1-107-W-CF	7	8/2/2016	62.1
7-1-106-S-CF	7	8/2/2016	5.8
7-1-BB-E-BF-1	7	8/2/2016	< 2.0
7-1-BB-N-BF-2	7	8/2/2016	< 2.0
7-1-HW110-N-DW	7	8/2/2016	2.6
7-1-GB-E-BF-1	7	8/2/2016	< 2.0
7-1-GB-E-BF-2	7	8/2/2016	6.0
7-1-GB-E-BF-4	7	8/2/2016	< 2.0
7-1-HW115-N-DW	7	8/2/2016	< 2.0
7-1-HW-119-N-DW	7	8/2/2016	< 2.0
7-1-127-S-CF	7	8/2/2016	7.2
7-1-BB-E-BF-1	7	8/2/2016	5.6
7-1-BB-E-BF-2	7	8/2/2016	12.0
7-1-ELEHW-E-DW	7	8/2/2016	67.0
7-2-ELEHW-E-DW-1	7	8/2/2016	5.1
7-2-GB-E-BF-1	7	8/2/2016	3.5
7-2-HW228-W-DW	7	8/2/2016	2.6
7-2-225-N-HS	7	8/2/2016	8.0
7-2-224-N-HS	7	8/2/2016	< 2.0
7-2-215CONF-E-BF	7	8/2/2016	4.1
7-2-214-S-BF	7	8/2/2016	< 2.0
7-2-BB-E-BF-1	7	8/2/2016	< 2.0
7-2-BB-N-BF-3	7	8/2/2016	8.2
7-2-HW214-N-DW	7	8/2/2016	< 2.0
7-2-HW217-N-DW	7	8/2/2016	16.2
7-2-GB-N-BF-1	7	8/2/2016	3.6
7-2-GB-N-BF-2	7	8/2/2016	< 2.0
7-2-HW222-N-DW	7	8/2/2016	2.5
7-2-BB-W-BF-1	7	8/2/2016	< 2.0
7-2-BB-W-BF-3	7	8/2/2016	< 2.0
7-2-ELEHW-E-DW-2	7	8/2/2016	8.3
7-3-ELEHW-W-DW-1	7	8/2/2016	6.2

Water Test Results 2016

7-3-GB-E-BF-1	7	8/2/2016	2.4
7-3-GB-E-BF-4	7	8/2/2016	< 2.0
7-3-HW304-W-DW	7	8/2/2016	8.7
7-3-BB-W-BF-1	7	8/2/2016	< 2.0
7-3-BB-W-BF-4	7	8/2/2016	< 2.0
7-3-ELEHW-W-DW-2	7	8/2/2016	98.3
7-4-ELEHW-E-DW-1	7	8/2/2016	18.3
7-4-GB-E-BF-1	7	8/2/2016	< 2.0
7-4-HW404-W-DW	7	8/2/2016	3.2
7-4-BB-E-BF-3	7	8/2/2016	< 2.0
7-4-BB-W-BF-1	7	8/2/2016	< 2.0
7-4-TB-E-BF	7	8/2/2016	< 2.0
7-4-ELEHW-E-DW-2	7	8/2/2016	17.5

ROOM / LOCATION ID

BB = Boys Bathroom

Boiler Bath = Boiler Room Bathroom

CAF = Cafeteria

ELEHW = Elevator Hallway

GB = Girls Bathroom

HW = Hallway (if preceding room location)

KIT = Kitchen

SEC= Security Room

TB = Teachers Bathroom

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

KC = Kitchen Faucet, Cold

NS = Nurses Sink

TL = Teachers Lounge

WC = Water Cooler