

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
12-1-KIT-W-FP-1	12	7/22/2016	3.2
12-1-KIT-W-FP-2	12	7/22/2016	< 2.0
12-1-KIT-W-HS	12	7/22/2016	< 2.0
12-1-CAF-B-S-BF	12	7/22/2016	2.9
12-1-98-S-CF	12	7/22/2016	2.8
12-1-NUR-E-NS	12	7/22/2016	< 2.0
12-1-NUR-E-BF-1	12	7/22/2016	5.7
12-1-NUR-W-BF-2	12	7/22/2016	3.7
12-1-BT-E-BF-1	12	7/22/2016	< 2.0
12-1-BT-E-BF-3	12	7/22/2016	< 2.0
12-1-H113-N-DW-1	12	7/22/2016	< 2.0
12-1-H113-N-DW-2	12	7/22/2016	2.4
12-1-GT-W-BF-1	12	7/22/2016	< 2.0
12-1-GT-W-BF-E	12	7/22/2016	< 2.0
12-1-103-W-CF	12	7/22/2016	< 2.0
12-1-106-N-CF	12	7/22/2016	7.2
12-1-106-N-BF	12	7/22/2016	< 2.0
12-1-104-S-BF	12	7/22/2016	< 2.0
12-1-101-W-CF	12	7/22/2016	2.5
12-1-101-N-BF	12	7/22/2016	< 2.0
12-1-H100-E-WC	12	7/22/2016	< 2.0
12-1-99-E-BF	12	7/22/2016	< 2.0
12-1-99-W-DW	12	7/22/2016	< 2.0
12-1-100-E-DW	12	7/22/2016	< 2.0
12-1-100-W-BF	12	7/22/2016	< 2.0
12-2-H201-N-DW	12	7/22/2016	2.8
12-2-201-S-CF	12	7/22/2016	< 2.0
12-2-201-N-BF-1	12	7/22/2016	2
12-2-201-E-DW	12	7/22/2016	< 2.0
12-2-201-S-BF-2	12	7/22/2016	3.1
12-2-H202-S-DW	12	7/22/2016	2.7
12-2-202-N-CF	12	7/22/2016	5.2
12-2-202-W-DW	12	7/22/2016	< 2.0
12-2-202-N-BF-2	12	7/22/2016	2.4
12-2-202-S-BF-1	12	7/22/2016	40
12-2-H211-S-DW	12	7/22/2016	3.5
12-2-MOR-S-BF	12	7/22/2016	< 2.0
12-2-212-S-CF	12	7/22/2016	10.2
12-2-PO-E-BF	12	7/22/2016	< 2.0
12-2-GT-E-BF-1	12	7/22/2016	< 2.0
12-2-H213-S-DW-1	12	7/22/2016	< 2.0
12-2-H213-S-DW-2	12	7/22/2016	< 2.0
12-2-BF-W-BF-1	12	7/22/2016	< 2.0
12-2-BF-W-BF-4	12	7/22/2016	< 2.0
12-2-213-S-CF	12	7/22/2016	< 2.0

Water Test Results 2016

12-2-209-N-CF	12	7/22/2016	< 2.0
12-2-GYM-W-DW	12	7/22/2016	2
12-2-210-N-CF	12	7/22/2016	3.2
12-3-308-N-CF	12	7/22/2016	2.9
12-3-GUID-N-BF	12	7/22/2016	< 2.0
12-3-307-N-CF	12	7/22/2016	8.4
12-3-BT-W-BF-1	12	7/22/2016	< 2.0
12-3-BT-W-BF-4	12	7/22/2016	< 2.0
12-3-303-S-CF	12	7/22/2016	3.2
12-3-H303-S-DW-1	12	7/22/2016	< 2.0
12-3-H303-S-DW-2	12	7/22/2016	< 2.0
12-3-GT-W-BF-1	12	7/22/2016	< 2.0
12-M-TCU2-E-DW	12	7/22/2016	< 2.0
12-M-TCU2-S-CF	12	7/22/2016	< 2.0
12-M-TCU2-S-BF	12	7/22/2016	< 2.0
12-M-TCU1-E-DW	12	7/22/2016	< 2.0
12-M-TCU1-N-CF	12	7/22/2016	< 2.0
12-M-TCU1-S-BF	12	7/22/2016	< 2.0

ROOM / LOCATION ID

BT = Boys Toilet

CAF = Faculty Bathroom

GT = Girls Toilet

GUID = Guidance Bathroom

H = Hallway (if precedes room location)

KIT = Kitchen

MOR = Main Office Receiving

NUR = Nurses Office

PO = Principals Office

TCU = Temporary Classroom Unit

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

NS = Nurses Sink

WC = Water Cooler