

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
14-B-CUST0-E-BF	14	7/20/2016	3.1
14-B-GT02-E-BF-1	14	7/20/2016	2.4
14-B-HGT02-N-DW	14	7/20/2016	17.4
14-B-BT01-W-BF-1	14	7/20/2016	< 2.0
14-B-7B4-S-CF	14	7/20/2016	2.4
14-B-HBT03-N-DW	14	7/20/2016	< 2.0
14-B-BT03-N-BF-1	14	7/20/2016	2.6
14-B-BT03-S-BF-2	14	7/20/2016	< 2.0
14-B-GT04-N-BF	14	7/20/2016	2.2
14-B-NUR-E-NS	14	7/20/2016	6.3
14-B-NUR-N-BF	14	7/20/2016	< 2.0
14-B-WT08-N-BF	14	7/20/2016	< 2.0
14-B-BTN11-W-BF-1	14	7/20/2016	< 2.0
14-B-BTN11-W-BF-2	14	7/20/2016	< 2.0
14-B-H11-N-WC-2	14	7/20/2016	3.2
14-B-H11-N-WC-1	14	7/20/2016	4.1
14-B-GTN11-E-BF-1	14	7/20/2016	< 2.0
14-B-H8-S-DW	14	7/20/2016	< 2.0
14-B-8-N-CF	14	7/20/2016	3.6
14-B-9-E-DW	14	7/20/2016	< 2.0
14-B-9-S-CF	14	7/20/2016	< 2.0
14-B-10-W-DW	14	7/20/2016	16.6
14-B-10-S-CF	14	7/20/2016	< 2.0
14-B-H10-N-DW	14	7/20/2016	3
14-B-BT05-W-BF-1	14	7/20/2016	3.3
14-B-GT06-E-BF-1	14	7/20/2016	< 2.0
14-B-GT06-E-BF-2	14	7/20/2016	< 2.0
14-B-GYM-S-DW-1	14	7/20/2016	5.1
14-B-GYMO-E-BF	14	7/20/2016	2
14-B-GYM-N-DW-2	14	7/20/2016	2.9
14-B-GYMMR-N-BF	14	7/20/2016	< 2.0
14-B-GYMWR-N-BF	14	7/20/2016	2.1
14-B-KIT-S-HS	14	7/20/2016	2.5
14-B-KIT-E-FP-1	14	7/20/2016	< 2.0
14-B-KIT-E-FP-2	14	7/20/2016	< 2.0
14-B-KIT-E-FP-3	14	7/20/2016	< 2.0
14-1-110-N-CF	14	7/20/2016	4.8
14-1-H109-S-DW	14	7/20/2016	6.7
14-1-109-N-CF	14	7/20/2016	6.2
14-1-108-N-CF	14	7/20/2016	4.7
14-1-AUDO-W-TF	14	7/20/2016	8.7
14-1-H108-S-DW	14	7/20/2016	< 2.0
14-1-GT102-W-BF-3	14	7/20/2016	< 2.0
14-1-BT103-E-BF-1	14	7/20/2016	< 2.0
14-1-T104-S-BF	14	7/20/2016	< 2.0

Water Test Results 2016

14-1-PO-N-BF	14	7/20/2016	2.9
14-1-H106-E-DW	14	7/20/2016	< 2.0
14-1-112-E-BF	14	7/20/2016	3.4
14-1-GT101-W-BF	14	7/20/2016	3.7
14-1-H102-N-DW	14	7/20/2016	3.5
14-1-101-S-BF	14	7/20/2016	< 2.0
14-2-H202-N-DW	14	7/20/2016	3.6
14-2-H206-E-DW	14	7/20/2016	< 2.0
14-2-211-W-TF	14	7/20/2016	< 2.0
14-2-212-E-BF	14	7/20/2016	398
14-2-T201-W-BF	14	7/20/2016	2.5
14-2-T202-E-BF	14	7/20/2016	< 2.0
14-2-BT203-E-BF-1	14	7/20/2016	< 2.0
14-2-GT204-W-BF-3	14	7/20/2016	< 2.0
14-2-H208-S-DW	14	7/20/2016	< 2.0
14-2-208-N-CF	14	7/20/2016	< 2.0
14-2-209-N-CF	14	7/20/2016	< 2.0
14-2-H209-S-DW	14	7/20/2016	< 2.0
14-2-210-N-CF	14	7/20/2016	< 2.0
14-3-H305-E-DW	14	7/20/2016	5.3
14-3-H302-N-DW	14	7/20/2016	3.1
14-1-AUDRO-N-TF	14	7/20/2016	103

ROOM / LOCATION ID

AUDO = Auditorium Office

AUDOR = Auditorium Rear Office

BT = Boys Toilet

BTN = Bathroom Near (room ID)

CUSTO = Custodial Office

GT = Girls Toilet

GYMMR = Gym Mens Room

GYMO = Gym Office

GYMWR = Gym Womens Room

H = Hallway (if precedes room location)

KIT = Kitchen

NUR = Nurses Office

PO = Principals Office

T104 = Teachers Toilet

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

Water Test Results 2016

NS = Nurses Sink
TF = Teachers Faucet
WC = Water Cooler