Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
15-B-GB-S-BF-1	15	7/15/2016	< 2
15-B-GB-S-BF-2	15	7/15/2016	< 2
15-B-BB-N-BF	15	7/15/2016	< 2
15-B-12-N-DW	15	7/15/2016	< 2
15-B-12-N-BF	15	7/15/2016	< 2
15-B-KIT-S-HS	15	7/15/2016	2.8
15-B-KIT-S-KC-1	15	7/15/2016	< 2
15-B-KIT-S-KC-2	15	7/15/2016	< 2
15-B-KIT-S-KC-3	15	7/15/2016	< 2
15-B-003-E-DW	15	7/15/2016	< 2
15-B-003-N-BF	15	7/15/2016	< 2
15-B-HW003-N-DW	15	7/15/2016	< 2
15-B-005-W-DW	15	7/15/2016	< 2
15-B-005-S-BF	15	7/15/2016	< 2
15-B-CO-W-05	15	7/15/2016	< 2
15-B-BB-S-BF-2	15	7/15/2016	< 2
15-B-BB-S-BT-4	15	7/15/2016	< 2
15-B-GB-S-BF-1	15	7/15/2016	2.5
15-B-GB-N-BF-3	15	7/15/2016	< 2
15-1-NUR-N-BF	15	7/15/2016	< 2
15-1-NUR-W-NS	15	7/15/2016	< 2
15-1-HWNUR-S-DW	15	7/15/2016	< 2
15-1-FL-E-TS	15	7/15/2016	< 2
15-1-FL-E-BF	15	7/15/2016	< 2
15-1-104-S-CF	15	7/15/2016	200
15-1-HW105-W-DW	15	7/15/2016	2.2
15-1-107-N-CF	15	7/15/2016	130
15-1-108-S-BF	15	7/15/2016	2.9
15-1-HW108-W-DW	15	7/15/2016	2.8
15-1-109-N-BF	15	7/15/2016	7.4
15-1-HW12-N-DW	15	7/15/2016	2.1
15-2-210-N-CF	15	7/15/2016	21
15-2-209-N-CF	15	7/15/2016	< 2
15-2-HW212-N-DW	15	7/15/2016	< 2
15-2-HW208-W-DW	15	7/15/2016	< 2
15-2-208-S-CF	15	7/15/2016	6.1
15-2-207-W-BF	15	7/15/2016	2.5
15-2-HW206-W-DW	15	7/15/2016	< 2
15-2-HW202-N-DW	15	7/15/2016	< 2
15-TCU-1-E-BF	15	7/15/2016	< 2
15-TCU-1-S-DW	15	7/15/2016	< 2
15-TCU-1-W-CF	15	7/15/2016	< 2
15-TCU-2-E-BF	15	7/15/2016	< 2
15-TCU-2-S-DW	15	7/15/2016	< 2
15-TCU-2-W-CF	15	7/15/2016	< 2

Water Test Results 2016

15-TCU-3-N-BF	15	7/15/2016	< 2
15-TCU-3-E-DW	15	7/15/2016	< 2
15-TCU-3-S-CF	15	7/15/2016	< 2

ROOM / LOCATION ID

BB = Boys Bathroom
CO = Coaches Office
FL = Faculty Lounge
GB = Girls Bathroom
HW = Hallway (if proceeds a room number)
KIT = Kitchen
NUR = Nurses office
TCU = Trailer Classroom Unit

OUTLET TYPE

BF = Bathroom Faucet
CF = Classroom Faucet
DW = Drinking Water Fountain
HS = Hand Sink
KC = Kitchen Faucet
NS = Nurses Sink
OS = Office Sink
TS = Teachers Sink