

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
16-B-BR-W-BF-2	16	7/14/2016	< 2
16-B-BR-W-BF-8	16	7/14/2016	< 2
16-B-B3-N-CF	16	7/14/2016	2.2
16-1-H5-S-DW	16	7/14/2016	< 2
16-1-NOR-E-BF	16	7/14/2016	< 2
16-1-HNUR-S-DW	16	7/14/2016	< 2
16-1-HGYM-E-DW	16	7/14/2016	< 2
16-2-H8-S-DW	16	7/14/2016	< 2
16-2-8-E-CF	16	7/14/2016	< 2
16-2-TR-S-BF	16	7/14/2016	< 2
16-2-TR-W-TS	16	7/14/2016	85
16-2-H10-S-DW	16	7/14/2016	< 2
16-B-HB1-W-DW	16	7/14/2016	< 2
16-B-B1-N-CF	16	7/14/2016	< 2
16-B-GR-W-BF1-1	16	7/14/2016	4.3
16-B-GR-E-BF-5	16	7/14/2016	< 2
16-B-TK-N-TF	16	7/14/2016	< 2
16-B-SBR-W-BF	16	7/14/2016	< 2
16-B-SGR-E-BF	16	7/14/2016	< 2
16-B-KIT-S-FP-1	16	7/14/2016	< 2
16-B-KIT-S-FP-2	16	7/14/2016	< 2
16-B-KIT-W-HS	16	7/14/2016	< 2
16-M-4-S-BF	16	7/14/2016	< 2
16-M-3/4-W-WC	16	7/14/2016	< 2
16-M-3-N-BF	16	7/14/2016	< 2
16-M-10-N-CF	16	7/14/2016	< 2
16-M-10-N-WC	16	7/14/2016	< 2
16-M-10-N-BF	16	7/14/2016	< 2
16-M-9-N-CF	16	7/14/2016	< 2
16-M-9-N-WC	16	7/14/2016	< 2
16-M-9-W-BF	16	7/14/2016	< 2
16-M-8-W-WC	16	7/14/2016	< 2
16-M-8-N-BF	16	7/14/2016	< 2
16-M-7-N-WC	16	7/14/2016	< 2
16-M-7-W-BF	16	7/14/2016	< 2
16-M-6-N-WC	16	7/14/2016	< 2
16-M-6-W-BF	16	7/14/2016	< 2
16-M-5-N-WC	16	7/14/2016	< 2
16-M-5-E-BF	16	7/14/2016	2.7
16-M-1/2-W-WC	16	7/14/2016	< 2
16-M-1-E-BF	16	7/14/2016	< 2
16-M-2-N-BF	16	7/14/2016	< 2

Water Test Results 2016

ROOM / LOCATION ID

BR = Boys Restroom

GR = Girls Restroom

H = Hallway by room (if precedes a room number)

HB1 = Hall by Room B-1

HGYM = Hall by Gym

HNUR = Hall by Nurses Office

KIT = Kitchen

M = Modular Classroom Units

NUR = Nurses office

SBR = Small Boys Restroom

SGR = Small Girls Restroom

TR = Teachers (Faculty) Bathroom

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

TS = Teachers Sink

WC = Water Cooler