

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
18-1-GYM-S-DW	18	7/20/2016	< 2.0
18-1-NUR-S-BF	18	7/20/2016	< 2.0
18-1-GB-E-BF-01	18	7/20/2016	< 2.0
18-1-102-S-BF	18	7/20/2016	4.2
18-1-102-E-DW	18	7/20/2016	< 2.0
18-1-102-N-BF	18	7/20/2016	2.9
18-1-H104-NW-DW-01	18	7/20/2016	17.9
18-1-H104-NW-DW-02	18	7/20/2016	9.2
18-1-M1-E-BF	18	7/20/2016	< 2.0
18-1-HM1-W-WC-01	18	7/20/2016	< 2.0
18-1-HM1-W-WC-02	18	7/20/2016	< 2.0
18-1-M2-W-BF	18	7/20/2016	< 2.0
18-1-HMP1-E-WC	18	7/20/2016	< 2.0
18-1-MP1-E-BF	18	7/20/2016	< 2.0
18-1-MP1-W-DW	18	7/20/2016	< 2.0
18-1-MP2-W-BF	18	7/20/2016	< 2.0
18-1-MP2-E-DW	18	7/20/2016	< 2.0
18-1-116-S-BF	18	7/20/2016	< 2.0
18-1-PO-W-BF	18	7/20/2016	21.6
18-1-MB-N-BF-01	18	7/20/2016	< 2.0
18-1-MB-N-BF-04	18	7/20/2016	< 2.0
18-1-H114-SW-WC-01	18	7/20/2016	< 2.0
18-1-H114-SW-WC-02	18	7/20/2016	5.1
18-1-137-N-BF	18	7/20/2016	< 2.0
18-1-137-E-DW	18	7/20/2016	< 2.0
18-1-134-N-BF	18	7/20/2016	< 2.0
18-1-134-W-DW	18	7/20/2016	< 2.0
18-1-134-S-CF	18	7/20/2016	< 2.0
18-1-137-S-CF	18	7/20/2016	< 2.0
18-1-KIT-W-KC-01	18	7/20/2016	< 2.0
18-1-KIT-S-KC-02	18	7/20/2016	< 2.0
18-1-KIT-S-KC-03	18	7/20/2016	< 2.0
18-1-KIT-E-KC-04	18	7/20/2016	< 2.0
18-1-KIT-S-KHS	18	7/20/2016	< 2.0
18-1-KIT-S-HS	18	7/20/2016	< 2.0
18-1-SA-N-KC	18	7/20/2016	< 2.0
18-1-SA-N-HS	18	7/20/2016	< 2.0
18-1-KIT-N-BF	18	7/20/2016	< 2.0
18-1-124-N-TS	18	7/20/2016	< 2.0
18-2-222-E-CF	18	7/20/2016	< 2.0
18-2-219-N-CF-01	18	7/20/2016	< 2.0
18-2-219-N-CF-02	18	7/20/2016	2.2
18-2-219-N-CF-03	18	7/20/2016	< 2.0
18-2-219-N-CF-04	18	7/20/2016	< 2.0
18-2-218-N-CF	18	7/20/2016	< 2.0

Water Test Results 2016

18-2-224-S-CF	18	7/20/2016	6.2
18-2-TTO-S-CF-01	18	7/20/2016	22.7
18-2-TTO-S-CF-02	18	7/20/2016	2.4
18-2-TTO-S-CF-03	18	7/20/2016	8.3
18-2-H214-SW-DW-01	18	7/20/2016	< 2.0
18-2-H214-SW-DW-02	18	7/20/2016	5.5
18-2-MB-N-BF-02	18	7/20/2016	2.7
18-2-SB-N-BF	18	7/20/2016	< 2.0
18-2-WB-S-BF-01	18	7/20/2016	4.3
18-2-H204-NW-DW-01	18	7/20/2016	2.4
18-2-H204-NW-DW-02	18	7/20/2016	< 2.0
18-1-NUR-N-IM	18	7/20/2016	< 1.0

ROOM / LOCATION ID

BB = Boys Bathroom

GB = Girls Bathroom

H = Hallway (if precedes room location)

KIT = Kitchen

MB = Mens Bathroom

NUR = Nurses Office

PO = Principals Office Bathroom

SB = Staff Bathroom

WB = Womens Bathroom

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

HS = Hand Sink

IM = Ice Machine

KC = Kitchen, Cold Faucet

KHS = Kitchen Hand Sink

TS = Teachers Sink (Faculty Dining Room)

WC = Water Cooler