

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
21-1-DWA-S-HS	21	7/26/2016	10.4
21-1-DWA-E-DS	21	7/26/2016	2.2
21-1-KIT-W-HS-1	21	7/26/2016	4
21-1-KIT-S-FP-1	21	7/26/2016	< 2.0
21-1-KIT-N-FP-2	21	7/26/2016	< 2.0
21-1-KIT-S-HS-2	21	7/26/2016	2
21-1-KIT-S-FP-3	21	7/26/2016	< 2.0
21-1-KIT-N-FP-4	21	7/26/2016	< 2.0
21-1-KIT-N-BF	21	7/26/2016	< 2.0
21-1-126-S-TF	21	7/26/2016	< 2.0
21-1-126-S-BF	21	7/26/2016	< 2.0
21-1-129-N-DW	21	7/26/2016	< 2.0
21-1-129-W-BF	21	7/26/2016	< 2.0
21-1-125-S-DW	21	7/26/2016	< 2.0
21-1-125-S-BF	21	7/26/2016	< 2.0
21-1-123-E-DW	21	7/26/2016	< 2.0
21-1-123-S-BF	21	7/26/2016	4.6
21-1-119-W-DW	21	7/26/2016	< 2.0
21-1-119-N-BF	21	7/26/2016	< 2.0
21-1-120-E-CF	21	7/26/2016	< 2.0
21-1-117-S-DW	21	7/26/2016	< 2.0
21-1-117-W-BF	21	7/26/2016	2.6
21-1-113-N-DW	21	7/26/2016	< 2.0
21-1-113-E-BF	21	7/26/2016	2.6
21-1-112A-E-TF	21	7/26/2016	< 2.0
21-1-112C-N-BF	21	7/26/2016	< 2.0
21-1-106-N-BF-7	21	7/26/2016	3.9
21-1-106A-S-BF	21	7/26/2016	< 2.0
21-1-H107-W-DW-1	21	7/26/2016	< 2.0
21-1-H107-W-DW-2	21	7/26/2016	< 2.0
21-1-104A-N-BF	21	7/26/2016	2.1
21-1-104-S-BF-1	21	7/26/2016	< 2.0
21-1-130-N-NS	21	7/26/2016	< 2.0
21-1-130A-E-NS	21	7/26/2016	2.8
21-1-130-E-BF	21	7/26/2016	< 2.0
21-1-GYM-W-DW-1	21	7/26/2016	< 2.0
21-1-GYM-W-DW-2	21	7/26/2016	< 2.0
21-1-135A-N-BF	21	7/26/2016	2.3
21-1-135C-S-BF-3	21	7/26/2016	10.2
21-1-135E-N-BF	21	7/26/2016	8.4
21-1-135G-S-BF-3	21	7/26/2016	2.8
21-2-H205-W-DW-2	21	7/26/2016	< 2.0
21-2-H205-W-DW-1	21	7/26/2016	< 2.0
21-2-206-N-BF-8	21	7/26/2016	< 2.0
21-2-206A-S-BF	21	7/26/2016	< 2.0

Water Test Results 2016

21-2-205-W-TF	21	7/26/2016	< 2.0
21-2-204A-N-BF	21	7/26/2016	< 2.0
21-2-204-S-BF-2	21	7/26/2016	2.1
21-2-203-N-CF	21	7/26/2016	35.9
21-3-306-N-BF-8	21	7/26/2016	2.5
21-3-H306-W-DW-2	21	7/26/2016	< 2.0
21-3-H306-W-DW-1	21	7/26/2016	< 2.0
21-3-306A-S-BF	21	7/26/2016	2.7
21-3-304A-N-BF	21	7/26/2016	2.7
21-3-304-S-BF-1	21	7/26/2016	< 2.0
21-3-304-N-BF-7	21	7/26/2016	< 2.0

ROOM / LOCATION ID

DWA = Dishwashing Area

H = Hallway (if precedes room location)

KIT = Kitchen

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DS = Dish Sink

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

NS = Nurses Sink

TF = Teachers Faucet