

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
25-B-LB-S-BF	25	7/23/2016	3.4
25-B-MB-N-BF	25	7/23/2016	6.3
25-1-HBR-N-BF	25	7/23/2016	< 2.0
25-1-1-N-DW	25	7/23/2016	7.3
25-1-NUR-N-BF	25	7/23/2016	< 2.0
25-1-NUR-W-BF	25	7/23/2016	< 2.0
25-1-BB-S-BF-01	25	7/23/2016	< 2.0
25-1-HGYM-W-DW-01	25	7/23/2016	< 2.0
25-1-HGYM-W-DW-02	25	7/23/2016	< 2.0
25-1-HGYM-W-DW-03	25	7/23/2016	< 2.0
25-1-HGYM-W-DW-04	25	7/23/2016	< 2.0
25-1-GB-N-BF-01	25	7/23/2016	< 2.0
25-1-H11-S-WC	25	7/23/2016	< 2.0
25-1-11-N-DW	25	7/23/2016	< 2.0
25-1-11-S-BF	25	7/23/2016	< 2.0
25-1-10-S-DW	25	7/23/2016	< 2.0
25-1-10-N-BF	25	7/23/2016	< 2.0
25-1-FL-S-TS	25	7/23/2016	< 2.0
25-1-FL-W-BF	25	7/23/2016	< 2.0
25-1-FL-E-BF	25	7/23/2016	< 2.0
25-1-HCAF-E-WC-01	25	7/23/2016	< 2.0
25-1-HCAF-E-WC-02	25	7/23/2016	< 2.0
25-1-GB-N-BF-01	25	7/23/2016	< 2.0
25-1-BB-S-BF-01	25	7/23/2016	< 2.0
25-1-KIT-S-KC-01	25	7/23/2016	< 2.0
25-1-KIT-E-KC-02	25	7/23/2016	< 2.0
25-1-KIT-W-HS-01	25	7/23/2016	< 2.0
25-1-KIT-N-KC-04	25	7/23/2016	< 2.0
25-1-KIT-W-KC-03	25	7/23/2016	< 2.0
25-1-KIT-N-KC-05	25	7/23/2016	< 2.0
25-1-KIT-S-HS-02	25	7/23/2016	< 2.0
25-1-KIT-S-KC-06	25	7/23/2016	20.2
25-1-KIT-W-BF	25	7/23/2016	< 2.0
25-1-103-N-DW	25	7/23/2016	< 2.0
25-1-103-E-BF	25	7/23/2016	< 2.0
25-1-102-N-DW	25	7/23/2016	< 2.0
25-1-102-W-BF	25	7/23/2016	< 2.0
25-1-101-E-CF-01	25	7/23/2016	< 2.0
25-1-101-E-CF-02	25	7/23/2016	< 2.0
25-1-101-E-CF-03	25	7/23/2016	4.1
25-1-101-W-BF	25	7/23/2016	< 2.0
25-2-HLIB-W-WC-01	25	7/23/2016	< 2.0
25-2-HLIB-W-WC-02	25	7/23/2016	< 2.0
25-2-205-N-CF	25	7/23/2016	8.5
25-2-204-N-CF	25	7/23/2016	5.5

Water Test Results 2016

25-2-203-N-CF	25	7/23/2016	< 2.0
25-2-202-N-CF	25	7/23/2016	2.6
25-2-201-N-CF	25	7/23/2016	< 2.0
25-2-GB-N-BF-01	25	7/23/2016	< 2.0
25-2-BB-S-BF-01	25	7/23/2016	< 2.0
25-3-HELE-W-WC-01	25	7/23/2016	< 2.0
25-3-HELE-W-WC-02	25	7/23/2016	< 2.0
25-3-305-N-CF	25	7/23/2016	< 2.0
25-3-304-N-CF	25	7/23/2016	5.9
25-3-303-N-CF	25	7/23/2016	< 2.0
25-3-302-N-CF	25	7/23/2016	9.9
25-3-301-N-CF	25	7/23/2016	< 2.0
25-3-GB-N-BF-01	25	7/23/2016	< 2.0
25-3-BB-S-BF-01	25	7/23/2016	< 2.0
25-3-HBF-N-BF	25	7/23/2016	3.9
25-3-308-W-CF	25	7/23/2016	10.7
25-TCU-1-E-CF	25	7/23/2016	< 2.0
25-TCU-1-N-DW	25	7/23/2016	< 2.0
25-TCU-1-W-BF	25	7/23/2016	< 2.0
25-TCU-2-E-CF	25	7/23/2016	< 2.0
25-TCU-2-N-DW	25	7/23/2016	< 2.0
25-TCU-2-W-BF	25	7/23/2016	< 2.0

ROOM / LOCATION ID

BB = Boys Bathroom

CAF = Cafeteria

ELE = Elevator

FL = Faculty Lounge

GB = Girls Bathroom

H = Hallway (if precedes room location)

HBF = Hallway Bathroom

KIT = Kitchen

LB = Ladies Bathroom

LIB = Library

MB = Mens Bathroom

NUR = Nurses Office

TCU = Temporary Classroom Unit

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

HS = Hand Sink

KC = Kitchen Faucet, Cold

TS = Teachers Sink

Water Test Results 2016

WC = Water Cooler