

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
26-1FL-KITCHEN-N-BF	26	7/21/2016	< 2.0
26-1FL-KITCHEN-E-HS-1	26	7/21/2016	< 2.0
26-1FL-KITCHEN-E-KS-1	26	7/21/2016	< 2.0
26-1FL-KITCHEN-W-KS-2	26	7/21/2016	< 2.0
26-1FL-KITCHEN-E-KS-3	26	7/21/2016	< 2.0
26-1FL-KITCHEN-E-KT	26	7/21/2016	< 2.0
26-1FL-107-W-KS	26	7/21/2016	< 2.0
26-1FL-107-W-BS	26	7/21/2016	< 2.0
26-1FL-106-N-CF	26	7/21/2016	< 2.0
26-1FL-106-E-BF	26	7/21/2016	< 2.0
26-1FL-105-N-CF	26	7/21/2016	< 2.0
26-1FL-105-W-BF	26	7/21/2016	< 2.0
26-1FL-BRE-N-BF-2	26	7/21/2016	< 2.0
26-1FL-GRE-S-BF-2	26	7/21/2016	< 2.0
26-1FL-104-E-BF	26	7/21/2016	< 2.0
26-1FL-104-N-CF	26	7/21/2016	< 2.0
26-1FL-103-N-CF	26	7/21/2016	< 2.0
26-1FL-103-W-BS	26	7/21/2016	< 2.0
26-1FL-102-N-CF	26	7/21/2016	< 2.0
26-1FL-102-E-BF	26	7/21/2016	< 2.0
26-1FL-MO-N-BF	26	7/21/2016	< 2.0
26-1FL-MO-S-BF	26	7/21/2016	< 2.0
26-1FL-NO-S-IM	26	7/21/2016	< 1.0
26-1FL-NO-N-NS	26	7/21/2016	< 2.0
26-1FL-NO-N-BF	26	7/21/2016	< 2.0
26-1FL-HGYM-N-DW-1	26	7/21/2016	< 2.0
26-1FL-HGYM-N-DW-2	26	7/21/2016	< 2.0
26-1FL-GRG-E-BF-1	26	7/21/2016	< 2.0
26-1FL-BRG-W-BF-1	26	7/21/2016	< 2.0
26-2FL-201-N-CF	26	7/21/2016	< 2.0
26-2FL-202-N-CF	26	7/21/2016	< 2.0
26-2FL-203-N-CF	26	7/21/2016	< 2.0
26-2FL-204-N-CF	26	7/21/2016	< 2.0
26-2FL-FLAV-E-BF	26	7/21/2016	< 2.0
26-2FL-205-N-CF	26	7/21/2016	< 2.0
26-2FL-206-N-CF	26	7/21/2016	< 2.0
26-2FL-GBR-E-BF-1	26	7/21/2016	< 2.0
26-2FL-BBR-W-BF-1	26	7/21/2016	< 2.0
26-2FL-H212-N-DW-1	26	7/21/2016	< 2.0
26-2FL-H212-N-DW-2	26	7/21/2016	< 2.0
26-2FL-207-E-CF	26	7/21/2016	< 2.0
26-2FL-208-E-CF	26	7/21/2016	< 2.0
26-3FL-301-N-CF	26	7/21/2016	< 2.0
26-3FL-302-N-CF	26	7/21/2016	< 2.0
26-3FL-303-N-CF	26	7/21/2016	< 2.0

Water Test Results 2016

26-3FL-304-N-CF	26	7/21/2016	< 2.0
26-3FL-306-N-CF	26	7/21/2016	< 2.0
26-3FL-305-N-CF	26	7/21/2016	35.7
26-3FL-GBR-E-BF-1	26	7/21/2016	< 2.0
26-3FL-BBR-W-BF-1	26	7/21/2016	< 2.0
26-3FL-H312-N-DW-1	26	7/21/2016	< 2.0
26-3FL-H312-N-DW-2	26	7/21/2016	< 2.0
26-3FL-312-E-CF	26	7/21/2016	< 2.0
26-3FL-308-W-CF	26	7/21/2016	< 2.0
26-3FL-307-E-CF	26	7/21/2016	7.7

ROOM / LOCATION ID

BBR = Boys Bathroom

BRE = Boys Room East

BRG = Boys Room Gym

FLAV = Faculty Lavatory

GBR = Girls Bathroom

GRE = Girls Room East

GRG = Girls Room Gym

H = Hallway (if precedes room location)

MO = Main Office

NO = Nurses Office

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

HS = Hand Sink

IM = Ice Machine

KS = Kitchen Sink

KT = Kettle

NS = Nurses Sink