

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
28-1-152-N-BF	28	8/3/2016	< 2.0
28-1-152-S-BF	28	8/3/2016	< 2.0
28-1-H152-S-DW-1	28	8/3/2016	< 2.0
28-1-H152-S-DW-2	28	8/3/2016	< 2.0
28-1-GYM-NW-DW-1	28	8/3/2016	< 2.0
28-1-GYM-NW-DW-2	28	8/3/2016	< 2.0
28-1-GYM-SE-DW-1	28	8/3/2016	2.2
28-1-GYM-SE-DW-2	28	8/3/2016	< 2.0
28-1-149-E-CF-1	28	8/3/2016	4.0
28-1-149-W-CF-2	28	8/3/2016	6.4
28-1-148-E-CF	28	8/3/2016	< 2.0
28-1-148-N-DW	28	8/3/2016	< 2.0
28-1-148-W-BF	28	8/3/2016	< 2.0
28-1-146-W-CF	28	8/3/2016	< 2.0
28-1-146-N-DW	28	8/3/2016	< 2.0
28-1-146-W-BF	28	8/3/2016	< 2.0
28-1-145-E-CF	28	8/3/2016	< 2.0
28-1-145-N-DW	28	8/3/2016	< 2.0
28-1-145-E-BF	28	8/3/2016	< 2.0
28-1-BLR-N-DW-1	28	8/3/2016	< 2.0
28-1-BLR-N-DW-2	28	8/3/2016	< 2.0
28-1-BLR-S-BF-1	28	8/3/2016	2.5
28-1-158-E-BF	28	8/3/2016	< 2.0
28-1-159-W-BF	28	8/3/2016	< 2.0
28-1-GLR-N-DW-1	28	8/3/2016	< 2.0
28-1-GLR-N-DW-2	28	8/3/2016	< 2.0
28-1-GLR-N-BF-1	28	8/3/2016	< 2.0
28-1-143-W-CF	28	8/3/2016	< 2.0
28-1-143-N-DW	28	8/3/2016	< 2.0
28-1-143-W-BF	28	8/3/2016	< 2.0
28-1-142-E-CF	28	8/3/2016	< 2.0
28-1-142-N-DW	28	8/3/2016	< 2.0
28-1-142-E-BF	28	8/3/2016	< 2.0
28-1-140-W-CF	28	8/3/2016	< 2.0
28-1-140-N-DW	28	8/3/2016	< 2.0
28-1-140-W-BF	28	8/3/2016	< 2.0
28-1-BB-W-BF-1	28	8/3/2016	< 2.0
28-1-GB-E-BF-1	28	8/3/2016	< 2.0
28-1-HMO-W-DW-1	28	8/3/2016	< 2.0
28-1-HMO-W-DW-2	28	8/3/2016	< 2.0
28-1-MO-S-OS	28	8/3/2016	< 2.0
28-1-MO-S-BF	28	8/3/2016	< 2.0
28-1-131-S-NS	28	8/3/2016	< 2.0
28-1-131F-W-NS	28	8/3/2016	< 2.0
28-1-131-S-BF	28	8/3/2016	< 2.0

Water Test Results 2016

28-1-CAF-S-WC-1	28	8/3/2016	16.3
28-1-CAF-S-WC-2	28	8/3/2016	3.5
28-1-130-E-CF	28	8/3/2016	< 2.0
28-1-130-N-DW	28	8/3/2016	< 2.0
28-1-130-E-BF	28	8/3/2016	< 2.0
28-1-128-W-CF	28	8/3/2016	< 2.0
28-1-128-N-DW	28	8/3/2016	< 2.0
28-1-128-W-BF	28	8/3/2016	< 2.0
28-1-127-E-CF	28	8/3/2016	< 2.0
28-1-127-N-DW	28	8/3/2016	< 2.0
28-1-127-E-BF	28	8/3/2016	< 2.0
28-1-125-W-CF	28	8/3/2016	< 2.0
28-1-125-N-DW	28	8/3/2016	< 2.0
28-1-125-W-BF	28	8/3/2016	< 2.0
28-1-124-E-CF	28	8/3/2016	< 2.0
28-1-124-N-DW	28	8/3/2016	< 2.0
28-1-124-E-BF	28	8/3/2016	< 2.0
28-1-122-W-CF	28	8/3/2016	< 2.0
28-1-122-N-DW	28	8/3/2016	< 2.0
28-1-122-E-BF	28	8/3/2016	< 2.0
28-1-H115-E-WC-1	28	8/3/2016	< 2.0
28-1-H115-E-WC-2	28	8/3/2016	< 2.0
28-1-102-S-CF	28	8/3/2016	< 2.0
28-1-105-E-TS	28	8/3/2016	< 2.0
28-1-KIT-N-HS-1	28	8/3/2016	3.6
28-1-KIT-W-HS-2	28	8/3/2016	4.6
28-1-KIT-W-HS-3	28	8/3/2016	< 2.0
28-1-KIT-S-FP-1	28	8/3/2016	< 2.0
28-1-KIT-N-FP-2	28	8/3/2016	< 2.0
28-1-KIT-W-FP-3	28	8/3/2016	< 2.0
28-1-KIT-N-BF	28	8/3/2016	< 2.0
28-1-109-S-BF	28	8/3/2016	< 2.0
28-2-H227-N-DW-1	28	8/3/2016	< 2.0
28-2-H227-N-DW-2	28	8/3/2016	< 2.0
28-2-GB-W-BF-1	28	8/3/2016	< 2.0
28-2-BB-E-BF-3	28	8/3/2016	< 2.0
28-2-BB-E-BF-4	28	8/3/2016	< 2.0
28-2-FB-N-BF	28	8/3/2016	< 2.0
28-2-205-S-TS	28	8/3/2016	< 2.0
28-2-H205-N-DW-1	28	8/3/2016	< 2.0
28-2-H205-N-DW-2	28	8/3/2016	< 2.0
28-3-H316-N-DW-1	28	8/3/2016	< 2.0
28-3-H316-N-DW-2	28	8/3/2016	< 2.0
28-3-BB-GB-W-BF-1	28	8/3/2016	< 2.0
28-3-GB-W-BF-5	28	8/3/2016	< 2.0
28-3-BB-E-BF-1	28	8/3/2016	< 2.0
28-3-BB-E-BF-4	28	8/3/2016	3.5

Water Test Results 2016

28-3-FB-N-BF	28	8/3/2016	< 2.0
28-3-330-W-TS	28	8/3/2016	3.2
28-3-300-W-CF	28	8/3/2016	13.0

ROOM / LOCATION ID

BB = Boys Bathroom

BLR = Boys Locker Room

CAF = Cafeteria

FB = Faculty Bathroom

GB = Girls Bathroom

GLR = Girls Locker Room

H = Hallway (if precedes room location)

HMO = Hallway by Main Office

KIT = Kitchen

MO = Main Office

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

NS = Nurses Sink

OS = Office Sink

TS = Teachers Sink

WC = Water Cooler