

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
80-1-BRB-N-BF	80	7/15/2016	< 2
80-1-CAF-N-WC	80	7/15/2016	< 2
80-1-BRC-N-BF	80	7/15/2016	< 2
80-B-HGYM-N-DW	80	7/15/2016	2.8
80-1-CAF-E-HS-1	80	7/15/2016	6.5
80-1-CAF-E-HS-2	80	7/15/2016	14
80-1-KIT-N-HS	80	7/15/2016	11
80-1-KIT-N-FP-1	80	7/15/2016	< 2
80-1-KIT-N-FP-2	80	7/15/2016	14
80-1-KIT-N-FP-3	80	7/15/2016	2
80-1-KIT-S-FP-4	80	7/15/2016	4.2
80-1-KIT-S-FP-5	80	7/15/2016	2.6
80-1-TR-W-TF	80	7/15/2016	< 2
80-1-GR-W-BF-3	80	7/15/2016	2.2
80-1-H104-E-WC	80	7/15/2016	< 2
80-1-H114-E-WC	80	7/15/2016	< 2
80-1-BRE-E-BF	80	7/15/2016	2.2
80-1-120-E-CF-11	80	7/15/2016	800
80-2-GR-N-BF-5	80	7/15/2016	< 2
80-2-220-W-CF-10	80	7/15/2016	12
80-2-H214-W-WC	80	7/15/2016	< 2
80-2-FBR-W-BF	80	7/15/2016	< 2
80-2-NUR-W-BF	80	7/15/2016	< 2
80-2-PBR-N-BF	80	7/15/2016	< 2
80-2-BR-S-BF-3	80	7/15/2016	< 2
80-2-HGYM-N-WC	80	7/15/2016	< 2
80-3-FBR-N-BF-1	80	7/15/2016	3.5
80-2-HPO-W-WC	80	7/15/2016	< 2
80-3-320-W-CF	80	7/15/2016	< 2
80-3-GR-N-BF-5	80	7/15/2016	< 2
80-3-H314-W-WC	80	7/15/2016	< 2
80-3-TR-W-BF-1	80	7/15/2016	96
80-3-GO-W-BF	80	7/15/2016	< 2
80-3-H304-W-WC	80	7/15/2016	< 2
80-3-BR-S-BF-3	80	7/15/2016	< 2
80-1-CUST-W-BF	80	7/15/2016	< 2
80-M-B-S-CF	80	7/15/2016	< 2
80-M-COM-E-WC	80	7/15/2016	< 2
80-M-GR-S-BF	80	7/15/2016	3
80-M-BR-N-BF	80	7/15/2016	6.1
80-M-TR-W-BF	80	7/15/2016	8.5

ROOM / LOCATION ID

BR = Boys Restroom

Water Test Results 2016

BRB = Boiler Room Bathroom
BRC = Boys Restroom by Cafeteria
BRE = Bathroom by Elevator
CAF = Cafeteria
COM = Common Area between Classes
CUST = Custodial Office Bathroom
FBR = Faculty Bathroom
GO = Guidance Office
GR = Girls Restroom
HPO = Hall across from Principals Office
KIT = Kitchen
NUR = Nurses office
PBR = Principals Bathroom
TR = Teachers (Faculty) Bathroom

OUTLET TYPE

BF = Bathroom Faucet
CF = Classroom Faucet
DW = Drinking Water Fountain
FP = Food Prep
HS = Hand Sink
NS = Nurses Sink
TF = Teachers Faucet
WC = Water Cooler