

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
84-1-H019-S-DW	84	7/21/2016	< 2.0
84-1-028-E-BF-1	84	7/21/2016	2.3
84-1-028-E-BF-3	84	7/21/2016	< 2.0
84-1-030-N-BF	84	7/21/2016	2.1
84-1-H032-W-DW	84	7/21/2016	2.8
84-1-034-E-CF	84	7/21/2016	95.9
84-1-037-N-TF	84	7/21/2016	< 2.0
84-1-037-M-N-TF	84	7/21/2016	< 2.0
84-1-037-W-S-TF	84	7/21/2016	< 2.0
84-1-039-N-NS	84	7/21/2016	< 2.0
84-1-039-W-BF	84	7/21/2016	< 2.0
84-1-BLR-N-DW	84	7/21/2016	< 2.0
84-1-BLR-W-BF	84	7/21/2016	2.1
84-1-H041-S-DW	84	7/21/2016	6.1
84-1-017-S-CF	84	7/21/2016	< 2.0
84-1-017-S-WC	84	7/21/2016	< 2.0
84-1-014-N-BF-2	84	7/21/2016	< 2.0
84-1-013-S-BF	84	7/21/2016	2.4
84-1-007-S-BF-2	84	7/21/2016	37
84-1-003A-N-TF	84	7/21/2016	11.6
84-1-003-S-CF-1	84	7/21/2016	4
84-1-002-S-WC	84	7/21/2016	< 2.0
84-1-006B-N-CF	84	7/21/2016	6.7
84-1-006-S-CF	84	7/21/2016	< 2.0
84-1-012-N-BF	84	7/21/2016	< 2.0
84-1-012A-N-WC	84	7/21/2016	3
84-2-CAF-W-WC-1	84	7/21/2016	< 2.0
84-2-CAF-W-DW	84	7/21/2016	39.4
84-2-CAF-W-WC-2	84	7/21/2016	< 2.0
84-2-126F-E-DS-1	84	7/21/2016	< 2.0
84-2-126F-W-DS-2	84	7/21/2016	4.2
84-2-KIT-E-FP-1	84	7/21/2016	< 2.0
84-2-KIT-W-FP-2	84	7/21/2016	2.2
84-2-KIT-W-FP-3	84	7/21/2016	2.1
84-2-KIT-W-FP-4	84	7/21/2016	< 2.0
84-2-KIT-W-HS	84	7/21/2016	< 2.0
84-2-KIT-W-FP-5	84	7/21/2016	< 2.0
84-2-125E-S-BF-1	84	7/21/2016	< 2.0
84-2-H117-N-DW	84	7/21/2016	< 2.0
84-2-119-S-CF	84	7/21/2016	13
84-2-121-S-CF	84	7/21/2016	11
84-2-122-E-CF	84	7/21/2016	9.6
84-2-115-S-BF-1	84	7/21/2016	< 2.0
84-2-115-S-BF-4	84	7/21/2016	< 2.0
84-110A-W-TF	84	7/21/2016	< 2.0

Water Test Results 2016

84-2-101A-S-BF	84	7/21/2016	< 2.0
84-2-109-S-BF-4	84	7/21/2016	2.2
84-2-H108-S-DW	84	7/21/2016	< 2.0
84-2-104-S-CF	84	7/21/2016	< 2.0
84-2-107B-N-CF	84	7/21/2016	< 2.0
84-2-NSDR-S-BF	84	7/21/2016	7.7
84-2-NSDR-W-CF	84	7/21/2016	3.7
84-2-SDR-N-CF	84	7/21/2016	84.2
84-2-SDR-W-CF	84	7/21/2016	10.6
84-3-225-E-BF-1	84	7/21/2016	< 2.0
84-3-227-N-BF-1	84	7/21/2016	< 2.0
84-3-227-N-BF-3	84	7/21/2016	2.1
84-3-H228-W-DW	84	7/21/2016	< 2.0
84-3-231A-W-TF	84	7/21/2016	< 2.0
84-3-231B-W-BF	84	7/21/2016	< 2.0
84-3-231-C-W-BF-1	84	7/21/2016	< 2.0
84-3-H234-S-DW	84	7/21/2016	4.7
84-3-235-W-WC	84	7/21/2016	2
84-3-235-S-BF-1	84	7/21/2016	2.1
84-3-235-S-BF-2	84	7/21/2016	27.3
84-3-235-S-BF-3	84	7/21/2016	2.6
84-3-222-D-W-TF	84	7/21/2016	4.4
84-3-209-S-BF-1	84	7/21/2016	4.2
84-3-218-S-BF-1	84	7/21/2016	2.4
84-3-218-S-BF-3	84	7/21/2016	12.7
84-3-H208-S-DW	84	7/21/2016	< 2.0
84-3-201-E-CF-1	84	7/21/2016	3.6
84-3-201-E-CF-2	84	7/21/2016	4.3
84-3-205-S-CF	84	7/21/2016	15.6
84-3-207-E-CF-1	84	7/21/2016	6
84-3-207-E-CF-2	84	7/21/2016	2.2
84-3-206-N-CF	84	7/21/2016	< 2.0
84-4-300A-N-BF	84	7/21/2016	2.2
84-4-H300-S-DW	84	7/21/2016	< 2.0
84-4-302-S-CF-1	84	7/21/2016	22.4
84-4-303-S-CF-1	84	7/21/2016	8.9
84-4-302P-E-TF	84	7/21/2016	21.7
84-4-304-S-CF-1	84	7/21/2016	18.2
84-4-305-W-CF-1	84	7/21/2016	26
84-4-306-E-CF-1	84	7/21/2016	147
84-4-311-E-BF-1	84	7/21/2016	< 2.0
84-4-313-N-BF-1	84	7/21/2016	3

ROOM / LOCATION ID

BLR = Boys Locker Room

CAF = Cafeteria

Water Test Results 2016

H = Hallway (if precedes room location)

KIT = Kitchen

NSDR = North Stage Dressing Room

SDR = Stage Dressing Room

P = Prep Room (if following a room location)

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DS = Dishwashing Sink

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

NS = Nurses Sink

TF = Teachers Faucet

WC = Water Cooler