

Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
86-1-CAF-N-DW	86	8/4/2016	76.0
86-1-11-W-BF	86	8/4/2016	17.5
86-1-11-S-DW	86	8/4/2016	5.0
86-1-MO-E-TF	86	8/4/2016	10.7
86-1-FMR-S-BF	86	8/4/2016	4.0
86-1-FLR-N-BF	86	8/4/2016	3.3
86-1-LOB-W-DW-1	86	8/4/2016	5.2
86-1-LOB-W-DW-2	86	8/4/2016	2.2
86-1-TR-E-DW	86	8/4/2016	< 2.0
86-1-HBR-N-BF-1	86	8/4/2016	4.5
86-1-HBR-N-BF-2	86	8/4/2016	7.9
86-1-HGR-N-BF-1	86	8/4/2016	8.5
86-1-4-W-DW	86	8/4/2016	< 2.0
86-1-4-W-TF	86	8/4/2016	26.1
86-1-5-W-BF	86	8/4/2016	8.1
86-1-KIT-N-FP-1	86	8/4/2016	18.4
86-1-KIT-W-FP-2	86	8/4/2016	16.5
86-1-KIT-E-FP-3	86	8/4/2016	29.8
86-1-KIT-E-FP-4	86	8/4/2016	52.4
86-1-KIT-N-FP-5	86	8/4/2016	12.7
86-1-KIT-N-FP-6	86	8/4/2016	32.0
86-1-KIT-N-HS	86	8/4/2016	17.6
86-1-NUR-S-NS	86	8/4/2016	19.7
86-1-NUR-W-BF	86	8/4/2016	22.7
86-1-2-E-CF-1	86	8/4/2016	10.7
86-1-2-E-CF-2	86	8/4/2016	23.5
86-1-2-W-DW	86	8/4/2016	< 2.0
86-1-2-W-BF	86	8/4/2016	18.3
86-2-HGR-N-BF-1	86	8/4/2016	21.7
86-2-HGR-N-BF-2	86	8/4/2016	3.9
86-2-HBR-S-BF-1	86	8/4/2016	11.7
86-2-HBR-S-BF-2	86	8/4/2016	9.7
86-2-25-S-CF	86	8/4/2016	37.5
86-2-23-N-CF	86	8/4/2016	8.1
86-2-22-W-VF	86	8/4/2016	5.2
86-2-HALL-E-DW-1	86	8/4/2016	3.6
86-2-HALL-E-DW-2	86	8/4/2016	3.8
86-2-20-N-BF	86	8/4/2016	13.2
86-2-20-E-TF	86	8/4/2016	21.1

ROOM / LOCATION ID

BR = Boys Restroom

CAF = Cafeteria

FLR = Faculty Ladies Room

Water Test Results 2016

FMR = Faculty Mens Room

GR = Girls Restroom

H = Hallway (if precedes room location)

KIT = Kitchen

LOB = Lobby

MO = Main Office

NUR = Nurses Office

TR = Teachers Room

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

KT = Kettle

NS = Nurses Sink

TF = Teachers Faucet